

## **General Disclaimer**

### **One or more of the Following Statements may affect this Document**

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

Keep  
9-3620  
Hamilton  
Standard  
DIVISION OF UNITED AIRCRAFT CORPORATION  
U  
A®

MSP-14256  
14257

CR-115568  
SVHSER-6040

This Report  
Contains Computer  
Program Documentation

# FINAL REPORT

## DESICCANT HUMIDITY CONTROL SYSTEM

JUNE 1972

See 3  
54  
Proprietary

Prepared Under Contract No. NAS 9-11971

by

HAMILTON STANDARD  
DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT

for

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION  
MANNED SPACECRAFT CENTER  
HOUSTON, TEXAS

by

Dr. Peter J. Lunde

and

Frank L. Kester



N75-17097  
Unclass  
09472  
63/54  
CSCL 06K  
(NASA-CR-115568) DESICCANT HUMIDITY CONTROL  
SYSTEM Final Report, 21 Jun. 1971 - 21 Jun.  
1972 (Hamilton Standard Div.) 350 P HC  
\$9.50



FINAL REPORT

DESICCANT HUMIDITY CONTROL SYSTEM

JUNE 1972

Prepared Under Contract No. NAS 9-11971

by

HAMILTON STANDARD  
DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT

for

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION  
MANNED SPACECRAFT CENTER  
HOUSTON, TEXAS

by

Dr. Peter J. Lunde

and

Frank L. Kester

ABSTRACT

A new water vapor and carbon dioxide sorbent material (designated 'HS-C') has been developed for potential application to the Space Shuttle and tested at full scale. Capacities of two percent for carbon dioxide and four percent for water vapor were achieved using Space Shuttle cabin adsorption conditions and a space vacuum for desorption. Performance testing showed that water vapor can be controlled by varying the air process flow, while maintaining the ability to remove carbon dioxide.

A 2000 hour life test was successfully completed, as were tests for sensitivity to cleaning solvent vapors, vibration resistance, and flammability.

A system design for the Space Shuttle showed a 200 pound weight advantage over competitive systems and an even larger advantage for longer missions.

FOREWORD

This report has been prepared by the Hamilton Standard Division of United Aircraft Corporation for the National Aeronautics and Space Administration's Manned Spacecraft Center in accordance with Contract NAS 9-11971. The report covers work accomplished between June 21, 1971 and the date of issue.

Appreciation is expressed to the Technical Monitors, Mr. Richard J. Gillen and Mr. Frank Collier of NASA, Manned Spacecraft Center, for their guidance and advice.

This program was conducted under the direction of Mr. Fred H. Greenwood, Program Manager, and Dr. Peter J. Lunde, Program Engineer, with the assistance of:

Mr. Robert Balinskas  
Dr. Phillip J. Birbara  
Mr. Frank Kester  
Mr. Henry J. Kolnsberg  
Mr. Donald R. McCann  
Mr. Armand Ruby  
Mr. Alfred J. Weiss

TABLE OF CONTENTS

	<u>Page No.</u>
<u>SUMMARY</u>	3
<u>INTRODUCTION</u>	5
<u>OBJECTIVES</u>	7
Material Review and Evaluation Objectives	7
Computer Program Objective	7
Laboratory Concept Development Objective	7
Design Concept Development Objective	7
<u>CONCLUSIONS</u>	9
<u>RECOMMENDATIONS</u>	11
<u>SUMMARY REPORT</u>	13
Desiccant Material Selection	13
Material Review and Evaluation	13
Secondary Properties	16
Computer Program	16
Laboratory Concept Development	19
Small Scale Tests	19
Large Scale Tests (Series I)	19
Large Scale Tests (Series II)	27
Large Scale Tests (Series III)	27
Design Concept Development	35



TABLE OF CONTENTS (Continued)

	<u>Page No.</u>
<u>MATERIAL SELECTION AND PROPERTIES</u>	41
Small Scale Apparatus Description	41
Objectives and Capabilities	41
Apparatus Description	41
Main Flow	41
Sampling	43
Test Canisters	46
Canister Temperature Control	46
Timing Sequence	46
Calibration	46
System Pressure	47
Inlet Gas Flow Rate	47
Sample Weight	47
Adsorption Time	47
Inlet and Outlet CO <sub>2</sub> and Water Vapor Partial Pressure	47
Calculations	50
Material Description	54
Evaluation	57
Material Variations	57
Substrate	57
Coating Weight	58
Coating Composition	58
Selected HS-C Material	58

TABLE OF CONTENTS (Continued)

	<u>Page No.</u>
HS-C Life Test	60
Solvent Tests	60
Objectives	60
Experimental Method	60
Results	62
Conclusions	62
Structural Tests	62
Flammability Tests	64
Results	64
Discussion	64
Toxicant Test	67
Discussion	67
Bromine	67
Ammonia	68
Toluene	68
Conclusion	68
Recommendations	68
<u>COMPUTER PROGRAM DESCRIPTION</u>	69
Introduction	69
Description and Mathematical Model	69
Adsorption and Desorption	69
Vacuum Desorption Pressure Distribution	73
Mathematical Formulation	74
Heat Transfer	76

TABLE OF CONTENTS (Continued)

	<u>Page No.</u>
Method of Solution	77
Program Capabilities	78
Program Options	78
Program Restrictions	79
Input/Output Parameters	79
Program Flow Charts	79
Program Symbol Definitions	80
Program Source Listings	80
Sample Case	80
<u>LABORATORY CONCEPT DEVELOPMENT</u>	81
Small Scale Development Tests	81
Test Objectives	81
Test Accuracy	82
Differences Between Large and Small Scale Tests	82
Test Canisters	82
Parametric Data Description	82
CO <sub>2</sub> Feed Concentration	86
Dew Point	86
Adsorption/Desorption Temperature	86
Inlet Flow Rate	86
Cycle Time	87
Large Scale Equipment Description	87

TABLE OF CONTENTS (Continued)

	<u>Page No.</u>
Large Scale Test Canister	92
Test Parameters	92
Flow Pattern	92
Calibrations	97
Large Scale Tests	102
Objectives	102
Experimental Method	105
Data Summary	105
Calculations	105
Parametric Data Discussion	108
Desorption Time, Temperature and Vacuum	108
Design for Desorption	109
Inlet CO <sub>2</sub> Concentration	109
<u>HS-C SYSTEM DESIGN CONCEPT DEVELOPMENT</u>	115
Concept Design	115
<u>APPENDIX A</u> Plan of Test & Test Data - HS-C Structural Tests	A-i
<u>APPENDIX B</u> Reproducibility	B-i
<u>APPENDIX C</u> Plan of Test - Toxicant Testing	C-i
<u>APPENDIX D</u> Input/Output Parameters - Flow Charts for Computer Program	D-i
<u>APPENDIX E</u> Test Plans - Large Scale Tests	E-i
<u>APPENDIX F</u> Data Summary Sheets - Large Scale Tests	F-i



LIST OF FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page No.</u>
1	Effect of Coating Composition on HS-C Material	14
2	Effect of Coating Weight on HS-C Performance	15
3	IR&D Small Scale Tests - Life Test HS-C	17
4	HS-C Small Scale Parametric Tests - Effect of Partial Pressure CO <sub>2</sub> on Cyclic Capacity	20
5	HS-C Small Scale Parametric Tests - Effect of Humidity on Cyclic Capacity	21
6	HS-C Small Scale Parametric Tests - Effect of Adsorption/Desorption Temperature on Cyclic Capacity	22
7	HS-C Small Scale Parametric Tests - Effect of Gas Flow Rate on Cyclic Capacity	23
8	HS-C Small Scale Parametric Tests - Effect on Half Cycle Time on Cyclic Capacity	24
9	Test Canister Arrangement - Cover Removed	25
10	Test Canister Arrangement - Installed in Rig	26
11	HS-C Large Scale Parametric Tests - Effect of Air Inlet Temperature on Cyclic Capacity	28
12	HS-C Large Scale Tests - Effect of Bed Temperature on Cyclic Capacity	29
13	HS-C Large Scale Parametric Tests - Effect of Inlet Humidity on Cyclic Capacity	30
14	HS-C Large Scale Parametric Tests - Effect of Partial Pressure of CO <sub>2</sub> on Cyclic Capacity	31
15	HS-C Large Scale Parametric Tests - % CO <sub>2</sub> and H <sub>2</sub> O Capacity vs Air Inlet Flow	32
16	Large Scale Parametric Tests - Effect of Desorption Time on Cyclic Capacity at P <sub>CO<sub>2</sub></sub> = 5 mmHg	33
17	HS-C Large Scale Parametric Tests - Effect of Desorption Time on Cyclic Capacity	34

LIST OF FIGURES (Continued)

<u>Figure No.</u>	<u>Title</u>	<u>Page No.</u>
18	Sorbent Arrangement and Control	36
19	System Comparison HS-C and LiOH Condenser - (Mission Length - Days)	38
20	System Comparison HS-C and LiOH Condenser - (Crew Size)	39
21	Sorbent Evaluator	42
22	Small Scale Tests - Sample Chromatogram (One Analysis) Chart Speed 2 Divisions/Minute	44
23	Cyclic Test Data - Small Scale Apparatus	45
24	Gas Flow Calibration - Small Scale Tests	48
25	Small Scale Tests - CO <sub>2</sub> Calibration Gas Chromatograph	49
26	Small Scale Tests - H <sub>2</sub> O Calibration Gas Chromatograph	51
27	Sorbent Evaluator Calculation Sheet	55
28	Small Scale Tests - Breakthrough Curve Tracings from Chromatogram	56
29	Canister Heating/Cooling System	88
30	Large Scale Tests - Rig 88 Block Diagram	89
31	Large Scale Test Apparatus	90
32	Large Scale Test Apparatus	91
33	Test Canister Design Layout	93
34	Test Configuration Header Layout	94
35	Large Scale Tests - Flow Pattern Within Heat Exchanger	95
36	Large Scale Tests - Canister Pressure Drop Calibration - Trace No. 1 - Brown	98

LIST OF FIGURES (Continued)

<u>Figure No.</u>	<u>Title</u>	<u>Page No.</u>
37	Large Scale Tests - P <sub>CO<sub>2</sub></sub> Calibration	99
38	Large Scale Tests - Dew Point Calibration Trace No. 13 - Brown	100
39	Large Scale Tests - High Vacuum Pressure Gauge Calibration - Trace No. 14 - Red	101
40	Large Scale Tests - Rig Pressure Calibration Trace No. 23 - Blue	103
41	Large Scale Tests - Air Flow Calibration	104
42	Large Scale Parametric Tests - Humidity Calculations - Data Cycle 70 (Recorder Reading)	106
43	Large Scale Parametric Tests - Humidity Calculations - Data Cycle 70 (Converted Reading)	107
44	Large Scale Parametric Tests - Desorption Pressure vs Time	111
45	HS-C Large Scale Parametric Tests - $\Delta P$ vs Flow	112
46	HS-C Large Scale Parametric Tests - Cyclic Water Capacity	119
47	Coolant Loop Schematic	120
48	Schematic of Competitive System LiOH Condenser Used for Trade Study	121

LIST OF TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page No.</u>
I	HS-C Sorbent Material Structural Testing Results	18
II	HS-C Life Tests	61
III	Solvent Tests	63
IV	Sorbent Evaluator Calculation Sheet	83
V	Test Parameters	96
VI	Design Requirements	116
VII	Optimization Procedure	118



Hamilton  
Standard

U  
DIVISION OF UNITED AIRCRAFT CORPORATION  
A®

CR-115568  
SVHSER-6040

## DESICCANT HUMIDITY CONTROL SYSTEM

### SUMMARY

A new regenerable water vapor and carbon dioxide sorbent material has been developed and designated HS-C. Its ability to adsorb and subsequently vacuum desorb both gases simultaneously in a single homogeneous bed has been successfully demonstrated in a full scale test simulating Space Shuttle conditions.

Capacities of 2% for carbon dioxide and 4% for water vapor were achieved when 15 pounds of HS-C was prepared and parametrically tested in 5 and 10 pound lots under cabin adsorption and space vacuum conditions appropriate for the Space Shuttle mission. Performance testing showed that water vapor can be controlled by varying the HS-C process flow, while maintaining the ability for removal of carbon dioxide. Two hundred and nineteen hours of large scale performance testing were accumulated without degradation.

Small scale testing of HS-C was conducted for 2000 hours of cyclic performance without degradation. The material was shown to be insensitive to common cleaning vapors, and acceptable in flammability and vibration resistance. HS-C effluent gases were analyzed after heating to 180°F and 150-300  $\mu$ gms  $\text{NH}_3$  were evolved per gm of HS-C.

System design concepts applied using the Space Shuttle constraints showed that a system for simultaneous control of humidity and removal of  $\text{CO}_2$  is feasible. Furthermore, the System using HS-C has a total equivalent weight advantage of 200 pounds over a competitive lithium hydroxide condensing heat exchanger system for atmospheric regeneration. For longer missions than the basic 7 day Space Shuttle mission, the advantage of an HS-C system increases since HS-C is not consumed in the regeneration process.

## INTRODUCTION

Metabolic water vapor and carbon dioxide have historically been removed from the spacecraft cabin by a condensing heat exchanger and lithium hydroxide (LiOH), respectively. The condensing heat exchanger offers the possibility of water reclamation and the LiOH system adsorbs large quantities of CO<sub>2</sub> in a small bed. However, these advantages fade in the Space Shuttle because of the ready availability of fuel cell product water and the longer mission length and larger crew size, which require increasing quantities of the non-regenerable LiOH.

A new water vapor and carbon dioxide sorbent called HS-C has now been developed to remove the metabolic products from the cabin using a single sorbent bed. It can be regenerated by a dry gas purge or a hard vacuum (50 microns) at the adsorption temperature, or by a mild vacuum (1/2 psia) at higher temperatures (200°F).

HS-C is made from a spherical porous substrate (diameter about 0.5 mm), which is coated with a thick non-volatile liquid which chemically adsorbs CO<sub>2</sub> and H<sub>2</sub>O.

HS-C is currently of interest to the designers of the Space Shuttle life support system for removal of metabolic water and carbon dioxide from the cabin. Competing systems are the flight-proven lithium hydroxide, which requires careful preflight preparation of the high capacity non-regenerable material plus the usual condensing heat exchanger for humidity control; and a silica gel molecular sieve system which shares some of HS-C's system advantages but can be poisoned with water vapor.

The HS-C system is especially desirable because it requires no liquid loop connections, needing only space vacuum and electrical connections to perform within the cabin environment. The material need not be replaced between flights since it can be regenerated easily on the ground with a dry purge.

### OBJECTIVES

The basic objective of this program was to develop a regenerable desiccant system concept for controlling the humidity and CO<sub>2</sub> level in the cabin of a Space Shuttle vehicle. To support this objective it was necessary to develop HS-C from a laboratory scale research material to a first class contender for the Shuttle mission. The first large scale preparations were made, performance of a full sized bed was investigated, and other properties (fire, toxicity, structural capability, etc.) were evaluated. A computer description of the material was developed and trade-off studies were conducted, which showed the material's basic superiority over a LiOH system.

The program was divided into four tasks:

- Material selection, preparation and properties.
- Computer program.
- Laboratory concept development.
- Design concept development.

The objectives of each task are listed below.

#### MATERIAL REVIEW AND EVALUATION OBJECTIVES

- To review available HS-C desiccant/CO<sub>2</sub> control materials to assure selection of an HS-C formulation most suitable to the specified performance requirements.
- To prepare the quantities of HS-C required for small and large scale testing and for delivery to NASA.
- To conduct solvent tests to assure that HS-C shall not be affected by solvents normally used in Manned Spacecraft Programs.

#### COMPUTER PROGRAM OBJECTIVE

- To generate a base computer program modeling HS-C which will allow design parameter determination and concept selection.

#### LABORATORY CONCEPT DEVELOPMENT OBJECTIVE

- To perform laboratory level development tests to adequately verify the computer program accuracy and adequacy.



#### DESIGN CONCEPT DEVELOPMENT OBJECTIVE

- To develop a system design concept applicable to the Space Shuttle including schematics, component operating parameters, and redundancy features.

### CONCLUSIONS

1. HS-C preparations on a five to ten pound scale have been successfully made. Quality control procedures have been devised such that preparations of up to 100 pounds over a few months are practical.
2. HS-C properties can be tailored, to a degree, by the use of different coating agents and coating quantities.
3. HS-C has been cyclically tested for 2000 hours in a Shuttle-type cycle without degradation.
4. Vibration of HS-C produced no change in performance, pressure drop, or physical conditions.
5. Using atmospheric air, the flammability of HS-C was acceptable according to Category B of D-NA-0002, Procedures and Requirements for Flammability and Offgassing Evaluation of Manned Spacecraft Nonmetallic Materials. The material also passes Category C when a container is used which is representative of that projected for a spacecraft. Proper design of the flight canister must be assured before the configuration will be acceptable to NASA.
6. Common cleaning solvent vapors caused negligible performance degradation of HS-C.
7. 150 to 300  $\mu$ gm of ammonia per gram of HS-C were generated when heated to 180°F in accordance with Specification MSC-PA-D-67-13.
8. Other toxicants (toluene, brominated hydrocarbons) were found which originated in impurities in test apparatus or raw materials. These impurities can be removed by improved test and preparational procedures.
9. A computer program has been developed which can predict cyclic performance of HS-C beds in the Shuttle configuration.
10. Full scale tests of HS-C for Shuttle type operation show a capacity of 2% for carbon dioxide and 4% for water vapor with a 40 minute desorb and 40 minute adsorb at Shuttle nominal conditions.

11. HS-C capacity for water and carbon dioxide is independent of the inlet temperature and nearly independent of inlet carbon dioxide concentration above 3mmHG. HS-C capacity for carbon dioxide is independent of the bed temperature when the same temperature is used for adsorption and desorption. Nominal conditions were such that increased adsorption cycle time or inlet air flow had no effect on carbon dioxide capacity, although water capacity was increased. Important capacity increases for CO<sub>2</sub> were noted with increased desorption time, decreasing desorption pressure, decreased bed thickness, a smaller HS-C particle size. Important increases in water capacity were noted with increase of inlet air flow, humidity or bed temperature.
12. In a realistic Shuttle system, a full trade-off of the atmospheric regeneration system indicates that HS-C has a 200 pound weight advantage over a LiOH condensing heat exchanger system for designs with crew sizes of 2-14 men. Since the HS-C is completely regenerable, its weight advantage increases with mission time.
13. Water capacity sizes the HS-C system proposed for the Shuttle. Future HS-C material development should emphasize increased water capacity, not capacity for carbon dioxide.

RECOMMENDATIONS

1. The mechanism responsible for the off-gassing of ammonia from HS-C should be investigated and means for reducing or eliminating ammonia evolution should be pursued.
2. Full scale performance verification testing of HS-C material with reduced ammonia evolution should be verified.
3. Kinetic constants for the HS-C material to be used in the Space Shuttle simulation should be obtained for use with the computer program developed under this contract.
4. The utility of HS-C for a Space Shuttle mission should be demonstrated further by designing, fabricating and testing a two-canister breadboard system incorporating projected heat interchange equipment and finding the concentration of water and carbon dioxide achieved as these constituents are added to a cabin environment in simulation of various crew activities.

SUMMARY REPORT

This section summarizes the material presented in detail in later sections, but without experimental detail and supporting arguments.

## DESICCANT MATERIAL SELECTION

The first objective of this contract was to produce a candidate sorbent material and evaluate its sorptive qualities and secondary properties.

Material Review and Evaluation

HS-C designates a class of regenerable sorbent materials made by coating a porous spherical substrate with an amine based liquid which adsorbs both water and CO<sub>2</sub>.

A number of HS-C preparations were made to find the highest capacity material. Variations explored were:


- |                 |  |
|-----------------|--|
| Coating Agent:  | (1) Polyethylenimine (Molecular weight 1800) |
|                 | (2) Tetraethyleamine pentamine               |
| Coating Amount: | (1) Percent by weight                        |
| Substrate:      | (1) 24-28 mesh material (acrylic ester)      |
|                 | (2) 30-40 mesh material (acrylic ester)      |

Figure 1 shows the difference in performance for two coating agent compositions over a range of CO<sub>2</sub> inlet compositions. The Tetraethyleamine (TEPA) coating produces 10% better CO<sub>2</sub> capacity and 50% better water capacity than the Polyethylenimine (PEI) coating. PEI was nonetheless chosen for coating agent because there was little experience with TEPA, leading to doubts regarding secondary properties, such as toxicity and volatility. Polymerization of a TEPA coating in place is technically feasible and would undoubtedly solve such latent problems, but such work was beyond the scope of this program.

Coating weight variations were explored for the PEI coating. Figure 2 shows a typical curve from a coating optimization, showing that too little coating leaves some of the material uncoated, and too much clogs rather than coats the deeper substrate pores with PEI.

Substrate variation were made by using different sized substrate particles. The smaller particles (30-40 mesh) showed somewhat higher CO<sub>2</sub> and H<sub>2</sub>O capacity (Figure 2), an effect attributed to a better intra-particle diffusion rate.

# EFFECT OF COATING COMPOSITION ON HS-C PERFORMANCE



EFFECT OF COATING WEIGHT ON HS-C PERFORMANCE




FIGURE 2

Bed depth also has an important effect on performance. The deeper the bed, the more difficult the desorption, due to the longer inter-particle diffusion path length.

The HS-C preparations used for development testing are summarized below:

	<u>Bed Size</u>	<u>Particle Size</u>	<u>wt % PEI 18</u>	<u>Bed Depth</u>
Small scale tests (IR&D Material)	2 gm	24-28 mesh	24.2	4 in*
Large scale tests (Series I)	10 lb	24-28 mesh	24.2	3 in
Large scale tests (Series II)	5 lb	24-28 mesh	24.2	1-1/2 in
Large scale tests (Series III)	5 lb	30-40 mesh	20.6	1-1/2 in

### Secondary Properties

Under Hamilton Standard's general Independent Research & Development (IR&D) Atmosphere Revitalization development program a life test, a structural test, and a flammability test were run on the HS-C developed for Series I and II. As a part of this contract, tests were run to determine the poisoning effect of solvents on HS-C and to analyze the kinds of toxicants HS-C generates when heated 100°F above the normal operating temperature (180°F).

HS-C was cycled for 2000 hours without degradation of performance (Figure 3). Severe shaking of a loaded canister (simulating launch) produced no change in performance, physical condition, or pressure drop (Table I).

When common cleaning solvents were introduced into the sorbent feed gas, little effect was noted. A maximum of 10% degradation was noted at the extreme data scatter. Gases evolved on heating HS-C were found to be primarily in three categories. One of these was traced to test rig manometer fluid and one to an impurity in the substrate. The final impurity, ammonia, was an impurity in the HS-C coating. Except for the ammonia, it is believed that these gases can be eliminated by improved preparational procedures. Ammonia generation levels were 150-300  $\mu$ gms  $\text{NH}_3$  per gram of HS-C when tested in accordance with Specification MSC-PA-D-67-13.

### COMPUTER PROGRAM

A second objective of the contract was to develop a computer program describing HS-C performance for use in concept selection. A mathematical

\*Actually 2 inches, single end desorb.



IR&D SMALL SCALE TESTS  
LIFE TEST HS-C




FIGURE 3

HS-C SORBENT MATERIAL STRUCTURAL TESTING RESULTS

<u>Test</u>	<u>Parameter</u>	<u>Before Vibration</u>	<u>After Vibration</u>
Dusting Resistance	% Non-spherical Beads	1.35%	1.05%
Apparent Density	Grams/Milliliter	0.402	0.402
CO <sub>2</sub> Adsorption	% by Weight	1.69	1.71
H <sub>2</sub> O Adsorption	% by Weight	5.14	5.27
Pressure Drop	$\Delta P$ Across Vibration Test Canister	See Curve Below	




TABLE I

N1

model for HS-C adsorption and desorption performance was developed and combined with heat transfer relations and heat and material balances to construct a computer program which predicts water and CO<sub>2</sub> adsorption or desorption rates along the length of the bed, calculating effluent gas composition and residual bed loadings as a function of time.

Single adsorption or desorption cycles, or a succession of adsorption/desorption cycles can be calculated. The bed can be cooled or heated during adsorption and desorption by cross-flow heat exchange with constant temperature cooling or heating fluid, typically cabin air. Desorption can be handled by dry gas purge or by high vacuum. Output data is printed or if desired can be plotted using the standard computer output print and paper.

Kinetic constants were developed empirically by reference to those determined for an earlier material and the test results from this program.

#### LABORATORY CONCEPT DEVELOPMENT

A third objective of the contract was to verify computer program accuracy and adequacy through laboratory testing. The two HS-C materials selected in an earlier phase were tested in the laboratory in small scale (2 gm) and large scale (5 and 10 pounds) tests.

##### Small Scale Tests

The larger mesh size material was exhaustively tested on a small scale, with twelve tests exploring performance variations due to changes in CO<sub>2</sub> feed concentration, inlet dew point, adsorption/desorption temperature, inlet flow and cycle time.

CO<sub>2</sub> capacity fell appreciably when CO<sub>2</sub> concentration in the feed was below P<sub>CO2</sub> = 3 mmHg (Figure 4). Water capacity rose rapidly with increasing dew point, doubling between 40°F and 60°F (Figure 5). Desorption/adsorption temperature did not affect CO<sub>2</sub> capacity, but lower temperatures favored increased H<sub>2</sub>O capacity (Figure 6). Increased inlet gas flow increased performance up to the nominal conditions but not beyond, showing that mass transfer to the material was adequate at nominal conditions (Figure 7). Similarly, increasing cycle length improved capacity up to the nominal conditions, but a further increase made only a small improvement (Figure 8).

##### Large Scale Tests (Series I)

The larger mesh size HS-C material was tested in a large scale configuration (10 lbs of HS-C). The test canister was a modified fin-tube heat exchanger 14 x 14 x 3 inches with an air flow path three inches long (Figures 9 and 10), desorbed at both ends to a high capacity vacuum system. Fifteen parametric tests were run totaling 219 continuous hours of testing.

HS-C SMALL SCALE PARAMETRIC TESTS




FIGURE 4

HS-C SMALL SCALE PARAMETRIC TESTS  
EFFECT OF HUMIDITY ON CYCLIC CAPACITY




FIGURE 5



HS-C SMALL SCALE PARAMETRIC TESTS

EFFECT OF ADSORPTION/DESORPTION TEMP. ON CYCLIC CAPACITY

$P_{CO_2}$  - 3 MM HG  
AIR FLOW - 500 ML/MIN  
CANISTER PRESSURE - 28 IN. HG  
DEW POINT - 52 F  
DESORB TERMINAL PRESSURE - <50 MICRONS  
SAMPLE VOLUME - 5 ML  
2 IN. BED, SINGLE END DESORB  
SAMPLE WEIGHT - 1.98 GM  
CYCLE TIMES: 45 MINUTE ADSORB  
45 MINUTE DESORB

□ CALCULATED FOR FULL (45 MIN.) ADSORB  
○ CALCULATED FOR 2/3 (30 MIN.) ADSORB




FIGURE 6

HS-C SMALL SCALE PARAMETRIC TESTS  
EFFECT OF GAS FLOW RATE ON CYCLIC CAPACITY




FIGURE 7

## HS-C SMALL SCALE PARAMETRIC TESTS






FIGURE 8





TEST CANISTER ARRANGEMENT  
(COVER REMOVED)

FIGURE 9



TEST CANISTER ARRANGEMENT  
(INSTALLED IN RIG)



Performance changes resulting from changes in inlet air temperature, inlet dew point, bed adsorb/desorb temperature, inlet CO<sub>2</sub> concentration, inlet air flow, cycle time, and desorption pressure were explored.

Changes in inlet air temperature and bed adsorb/desorb temperature had little effect on performance (Figures 11 and 12). Changes in inlet CO<sub>2</sub> concentration did not affect H<sub>2</sub>O adsorption and vice versa (Figures 13, 14).

Other effects were qualitatively those expected from the small scale tests. Inlet dew point had a large effect on water capacity, almost doubling over a 10°F dew point change (Figure 13). Inlet CO<sub>2</sub> concentration affected capacity appreciably up to 3 mmHg, but only slightly above that pressure (Figure 14). Inlet air flow did not affect CO<sub>2</sub> capacity, but markedly affected the H<sub>2</sub>O capacity which was much further from saturation at the test conditions (Figure 15).

Cycle time affected performance considerably because of the importance of desorption time (Figure 16). A very long desorption time (overnight) gave 2.6% CO<sub>2</sub> capacity by weight. Two percent cyclic capacity was reached with a 80 minute desorption, while with 30 minutes desorption time, the capacity was about 1.6%. Water capacity was relatively unaffected, suggesting that water is desorbed more readily than CO<sub>2</sub>.

Desorption pressure was quite important, with HS-C requiring low vacuum for best performance (Figure 17).

#### Large Scale Tests (Series II)

Series II tests were run with 5 pounds of HS-C in the same test canister used for Series I. Bed thickness was reduced to 1-1/2 inches, enhancing CO<sub>2</sub> capacity by reducing the inter-particle pressure drop during desorption. The same HS-C material was used as for Series I. Twenty-two additional test hours were accumulated and variations in cycle time were explored (Figure 16). About 10% additional capacity was achieved by decreasing the bed thickness in this manner, giving cyclic capacities of 1.9% for CO<sub>2</sub> and 3.2% for water vapor at 45 minutes desorption time.

#### Large Scale Tests (Series III)

Five pounds of smaller mesh HS-C material was tested in the large scale canister. As in Run Series II, bed depth was 1.5 inches. 228 hours of continuous operation were accumulated at nine parametric test conditions. Figure 16 shows the enhancement of capacity which the smaller particles gave. A capacity of 2% for CO<sub>2</sub> and 5% for water vapor was achieved with a 40 minute desorption. When water vapor and carbon dioxide partial pressures and bed temperature were raised to high nominal conditions, 2.1% capacity for CO<sub>2</sub> and 4% for H<sub>2</sub>O were achieved.

HS-C LARGE SCALE PARAMETRIC TESTS




FIGURE 11

HS-C LARGE SCALE PARAMETRIC TESTS




FIGURE 12

HS-C LARGE SCALE PARAMETRIC TESTS

EFFECT OF INLET HUMIDITY ON CYCLIC CAPACITY

CANISTER PRESSURE - 14.7 PSIA

$P_{CO_2}$  - 3 MM HG

AIR INLET TEMPERATURE - 70°F

BED TEMPERATURE - 80°F

ADSORB TIME - 30 MINUTES

DESORB TIME - 45 MINUTES

⊙ 60 CFM

⊠ 40 CFM

△ 26 CFM

RUN SERIES I - 8.84 LB. 3 INCH BED

CYCLES 41, 70, 82, 87, 121, 124, 131

CAPACITY WT, %

5

4

3

2

1

0

DEW POINT, °F

40

50

60

.05

.10

.15

.20

.25

.30

INLET  $P_{H_2O}$ , PSIA

CO<sub>2</sub>

H<sub>2</sub>O

FIGURE 13





FIGURE 14



HS-C LARGE SCALE PARAMETRIC TESTS





HS-C LARGE SCALE PARAMETRIC TESTS

EFFECT OF DESORPTION TIME ON CYCLIC CAPACITY  
AT  $P_{CO_2} = 5$  MM HG

CANISTER PRESSURE - 14.7 PSIA

$P_{CO_2}$  - 5 MMHG

AIR FLOW - 40 CFM

AIR INLET TEMPERATURE - 70°F

BED TEMPERATURE - 80°F

INLET DEW POINT - 51°F

ADSORB TIME - 30 MINUTES

- RUN SERIES I - 8.84 LB. 3 INCH BED  
CYCLES 19, 21, 26, 91, 109, 113, 115, 137, 138, 147
- RUN SERIES II - 4.4 LB. 1-1/2 INCH BED  
CYCLE 12
- △ RUN SERIES III - 4.4 LB. 1-1/2 IN. BED  
CYCLE 30
- ▽ SAME AS △ BUT WITH:  $P_{CO_2} = 7$  MM, DEW POINT = 57°F  
CYCLE 190





FIGURE 16

HS-C LARGE SCALE PARAMETRIC TESTS  
EFFECT OF DESORPTION TIME ON CYCLIC CAPACITY



## DESIGN CONCEPT DEVELOPMENT


A final objective of the contract was to develop a system design concept applicable to the Space Shuttle. Figure 18 shows the proposed configuration of an HS-C system for the Space Shuttle. Four canisters are used, of which two are spares.

Incoming cabin air serves as a heat transfer fluid, exchanging heat between adsorbing and desorbing canisters, which are specially designed plate-fin heat exchangers. The air then enters the adsorbing canister and is exhausted to the cabin. The desorbing canister is valved to space vacuum through each end of the canister.

It was found that water capacity was controlling for the Shuttle application, i.e., CO<sub>2</sub> levels were held within tolerance if the bed was sized to remove the generated water vapor. Further, the cabin humidity can be controlled by varying air flow while the carbon dioxide removal rate is relatively unaffected. The results of the large scale tests (Series I) were transferred into water capacity-gas flow-dew point curves and processed by a Hamilton Standard optimizing design program which optimized the entire CO<sub>2</sub> and water removal system, including fan, pump, and radiator designs. A similar optimization was run for a LiOH system. Results are shown in Figures 19 and 20.

The lower expendable weight penalty associated with the HS-C system is shown by Figure 19. The weight differential between HS-C and the conventional LiOH condenser system varies from 200 pounds at a 7-day mission to almost 750 pounds at a 30-day mission.

In Figure 20, the effect of crew size is shown. The weight optimized HS-C system maintains a lower cabin dew point than the LiOH system. This permits the cabin air heat exchanger to operate with lower coolant temperatures without condensing. It also minimizes the need for coolant line insulation to prevent condensation in undesirable locations. As expected, the weight advantage of HS-C increases somewhat with crew size, but not as dramatically as with mission duration. The basic weight advantage would increase with improved water capacity, since in all cases the HS-C bed size was determined by the required water capacity as opposed to CO<sub>2</sub> removal requirements. The goals established at the inception of this program of 4% water and 2% CO<sub>2</sub> capacity should be modified since they do not produce the minimum weight HS-C system. TEPA based materials (Figure 1) for instance, have 50% greater water capacity than the PEI based material used for this program.



## SORBENT ARRANGEMENT AND CONTROL

FIGURE 18

Hamilton  
Standard

U  
A<sub>(R)</sub>

CR-115568  
SVHSIR-6040

Other advantages of HS-C include the "forget it" aspect between flights -- no replacement is necessary and poisoning constituents are not present in the normal atmosphere. The ease of ground regeneration through dry gas purge is also convenient, and the simplicity of the system, which lacks liquid lines of any sort and has no connections required beyond space vacuum and electricity, is very appealing from a design and reliability viewpoint.

The following pages discuss in more detail the material presented in the summary report.

SYSTEM COMPARISON HS-C AND L10H - CONDENSER  
MISSION LENGTH-DAYS




FIGURE 19




FIGURE 20

MATERIAL SELECTION AND PROPERTIES

## SMALL SCALE APPARATUS DESCRIPTION

Objectives and Capabilities

Development of the HS-C material has required a means for fast evaluation of the CO<sub>2</sub> and water capacity of small samples. The "Sorbent Evaluator" used for small scale tests was designed for this task. It evaluated 5 cc (about 2.0 gm HS-C) samples with a precision of  $\pm 5\%$  under fixed conditions. The apparatus is also capable of testing larger quantities of sorbent (limited by inlet flow of about 1 cfm), and can desorb under vacuum conditions (as for the Space Shuttle) or when heated at a mild vacuum (as for the Space Station).

The Sorbent Evaluator is a "two-can" system; i.e., it tests two samples at once, one adsorbing while the other desorbs. This arrangement is especially useful when comparison with a standard material is desired, for both beds see precisely the same conditions.

HS-C generally takes only three adsorption-desorption cycles to achieve a cyclical steady state. At the test condition of 45 minute absorb - 45 minute desorb generally employed, evaluation of a material therefore took about 5 hours.

Evaluation of performance was by periodic analysis by gas chromatograph of feed and effluent streams. The chromatograms were taken at three minute intervals and recorded closely together so that by connecting the peak heights a "breakthrough curve" was formed which was then graphically integrated to find CO<sub>2</sub> or water removal efficiency. Weight capacity was then calculated from inlet flow rate, inlet CO<sub>2</sub> partial pressure, and bed weight.

Apparatus Description

## Main Flow

Figure 21 shows the rig schematic, simplified by omission of certain unused plumbing.

Atmospheric air entered the flow regulator assembly (a), where it was reduced to the rig pressure of about 28 in Hg. After metering by rotameter (b), the air passed over room temperature water in the humidifier (c), and thus approached room temperature in dew point. The humidified air was cooled



SORBENT EVALUATOR




FIGURE 21

ORIGINAL PAGE IS  
OF POOR QUALITY

in the oversized air heat exchanger (d) to the required dew point as set by the cooling water temperature which was controlled by the refrigeration system. Carbon dioxide was metered into the air stream from a pressurized cylinder using a 50 foot capillary tube and pressure reducing regulator. At the low air flows used for this work (500 ml/min) the air was reheated to room temperature (about 70-75°F) by the uninsulated piping leading to the first cycling valve (f). With both valves (f) as shown, the air flowed through can #2, and in the alternate position the flow was through can #1. After leaving the second valve (f), the air was released to the diaphragm pump (f) by absolute pressure regulator (g) so as to maintain proper rig pressure (28 in. Hg). When can #2 (or #1) was desorbing, ullage was pumped out through a special vacuum pump (h) when solenoid valve (F) or (L) was activated. When the ullage was gone, the timed cycle closed these valves and opened valves (K) or (J) to desorb the bed using a larger vacuum system (i), which utilized a diffusion pump.

### Sampling

A bed effluent sample was withdrawn from the canister outlet during adsorption by appropriately energizing solenoid valve D or I. At the end of each adsorption the feed was sampled through a solenoid valve E. The sample flow passed through the chromatograph sampling valve and then back through the sample rotameter. Sample flow rate was controlled by a metering valve leading to a fixed lower pressure set by a back pressure regulator. Sample gas leaving this regulator was returned to atmospheric pressure by diaphragm pump (f). Sample analysis, by gas-liquid chromatograph, produced an analysis every three minutes.

To obtain the three minute cycle and proper peak heights from the gas chromatograph a special column switching timer system was used. The sampling valve was automatically actuated every three minutes, introducing a small (1/16 ml) test sample into the helium carrier gas, which was regulated to 40 psig. The helium flowed through a 12 foot column filled with Porapak Q and an eight foot tube filled with Porapak T, both held in an oven at 72°C. After 1-1/2 minutes the air and CO<sub>2</sub> peaks had emerged, and then the second column was valved out and eight feet of Porapak Q substituted to permit the water peaks to occur at about 2-1/2 minutes (rather than 5 minutes). Since the valve switching produced false peaks, the detector signal was switched out except when the actual peaks were seen by the thermal conductivity detector<sup>1</sup> on the Varian chromatograph. A typical resultant chromatogram is shown in Figure 22. A series of these, three minutes apart, produces the test data for a given cycle (Figure 23).

<sup>1</sup>Current was 200 ma.




FIGURE 22



### Test Canisters

The canisters were constructed of Swagelok fittings and 1/2 inch stainless steel tubing with appropriate screens to hold the HS-C in place. No effort was made to fill the entire volume between screens with HS-C.

### Canister Temperature Control

Canisters were maintained at a constant temperature by water coils wrapped around them. A carefully metered flow of water from the cooling system was heated electrically to the desired temperature (typically 75°F) and then returned to the water storage reservoir.

### Timing Sequence

Actuation of the cycled valves was by an electrical cam timer. Valves (e) were energized pneumatically, using nitrogen pressure. The cycling sequence was as follows:

<u>Step</u>	<u>Valves (e)</u>	<u>Valves (F,L)</u>	<u>Valves (I, D, or E)</u>	<u>Valves (J and K)</u>
1-Start Adsorb Can #2	as shown	closed	closed	closed
2-Ullage dump	as shown	as shown	open/closed/closed	closed
3-Adsorb Can #2, Desorb #1	as shown	closed	open/closed/closed	as shown
4-Feed Sample	as shown	closed	closed/closed/open	closed
5-Start Adsorb Can #1	reversed	closed	closed	closed
6-Ullage dump	reversed	reversed	closed/open/closed	closed
7-Adsorb Can #1, Desorb #2	reversed	closed	closed/open/closed	reversed
8-Feed Sample	reversed	closed	closed/closed/open	closed

### Calibration

Most of the temperature measurements from the Sorbent Evaluator were from uncalibrated copper-constantan thermocouples. These were observed to read room temperature accurately when first made.

Measurements important to the calculations of capacity were:

1. System Pressure
2. Inlet Gas Flow Rate
3. Sample Weight
4. Adsorption Time
5. Inlet and Outlet CO<sub>2</sub> and Water Vapor Partial Pressure

These were calibrated as follows.

#### System Pressure

A single 30 in. Hg absolute reference pressure gauge was used for this measurement. It was checked at zero pressure (during desorption) and atmospheric pressure (against a mercury column) and was found correct within  $\pm 1$  division or  $\pm 0.1$  in. Hg.

#### Inlet Gas Flow Rate

A wet test meter was placed at the rig inlet for rotameter calibration. The wet test meter was at atmospheric pressure and the rotameter was at the usual rig pressure of 28 in. Hg. Data, calculations and factory calibration are shown in Figure 24 along with the resultant calibration curve.

#### Sample Weight


Just after preparation of HS-C, a 10 ml sample was quickly weighed using a tared 10 ml graduate. The resultant density was noted and used in the calculations. A 5 ml sample was then used for all evaluations, eliminating the effect of weight gains during transfer and storage due to adsorption.


#### Adsorption Time

Adsorption time was measured from the recorder chart. Capacities were calculated for both the first 30 minutes of adsorb and for the full 45 minutes.

#### Inlet and Outlet CO<sub>2</sub> and Water Vapor Partial Pressure

Carbon Dioxide. - The chromatographic standard gas was available from earlier programs. Its calibration was checked using "spray" cans of certified calibration at atmospheric pressure. The data and calibrations are shown in Figure 25. After the standard gas mixture was calibrated the chromatographic columns were changed, and a new single point recalibration was made using the





SMALL SCALE TESTS  
CO<sub>2</sub> CALIBRATION  
GAS CHROMATOGRAPH

FIGURE 25



standard gas mixture. Periodic recalibration assured consistent data throughout the experimental program.

The calibration gas was introduced into the apparatus via the fourth (unmarked) sample solenoid valve. The calibrated gas flow rate was adjusted so that the sample flow rate and (downstream) pressure were identical to the rig normal samples. Calibrations were generally stable, drifting perhaps 5% at most in a month. The most recent calibration always was used for an evaluation.

Water Vapor:- Chromatographic calibrations were made with a Cambridge Dew Point hygrometer, but the accuracy of the instrument available for the small scale tests were questionable even though it was calibrated according to the manufacturer's recommendations. It was decided to ignore this instrument and use conservative data by assuming that the inlet dew point is equal to the lowest water temperature in the dew point condenser (Figure 21, TI-11). A calibration curve prepared in this fashion is shown as Figure 26.

### Calculations

#### Nomenclature

$V$  = air flow rate ml/min at rig P

$P_i$  = Partial Pressure species i

$H_i$  = Chromatographic peak ht species i

$P_{ical}$ ,  $H_{ical}$  = calibration partial pressure and peak ht

$P_T$  = rig pressure

$x_i$  = mol fr species i

$V_{iR}$  = species i flow removal, ml/min at rig pressure

$V_i$  = species i flow, ml/min at rig pressure

$W_i$  = wt flow species i, gms/min

$P_T$  = rig pressure, absolute units


$P_{atmstd}$  = pressure std atmosphere, same unit as  $P_T$

$M_i$  = molecular wt species i

$T$  = flow temp. °C

SAMPLE VOLUME: 1/16 ML  
HELIUM CARRIER 40 PSIG  
OVEN 72°C  
COLUMN - 12 FT PARAPAK Q  
+8 FT PARAPAK T  
DETECTOR CURRENT: 200 MA  
ATTENUATION: X2

△ DIRECT CALIBRATION FROM COOLING WATER TEMPERATURE  
⊙ CALIBRATED BY PEAK AREA RATIO ASSUMING PEAK  
AREA IS PROPORTIONAL TO  $P_{H_2O}$



SMALL SCALE TESTS  
H<sub>2</sub>O CALIBRATION  
GAS CHROMATOGRAPH

$$R = \frac{82.06 \text{ atm cm}^3}{\text{gm mol } ^\circ\text{K}}$$

$\omega_s$  = wt sample, gms

$v_s$  = volume sample, ml

$C_{wt}$  = capacity wt %

$C_{vol}$  = capacity gms species i/1000 ml sample

CO<sub>2</sub> or H<sub>2</sub>O partial pressure in the feed is:

$$P_i = \frac{H_i P_{ical}}{H_{ical}}$$

Expressed as mol fraction:

$$x_i = \frac{P_i}{P_T} = \frac{H_i P_{ical}}{P_T H_{ical}}$$

The flow rate of CO<sub>2</sub> or H<sub>2</sub>O flowing to the canister is then:

$$V_i = x_i V = \frac{V H_i P_{ical}}{P_T H_{ical}}$$

$E_i$  is the removal efficiency for the i species, so the volumetric gas adsorption rate is:

$$V_{iR} = \frac{E_i V_i}{100} = \frac{E_i V H_i P_{ical}}{100 P_T H_{ical}}$$

and the weight flow rate adsorbed is:

$$w_i = \frac{P_T}{100 P_{atmstd}} \frac{V_{iR}}{R} \frac{M_i}{(273 + T)} = \frac{M_i}{100 P_{atmstd}} \frac{E_i V H_i P_{ical}}{R (273 + T) H_{ical}}$$

Where the perfect gas law is expressed as:

$$\frac{PV}{P_{atmstd}} = \frac{W_i}{M_i} \frac{1}{RT}$$

From this expression a volume capacity and a weight capacity were calculated for the adsorption time period:

$$C_{vol} = \frac{W_{it}}{v_s} 1000$$

$$C_{wt} = \frac{C_{vol} v_s}{10 W_s}$$

Assuming 25°C feed, for CO<sub>2</sub>:

$$C_{vol} = 2.367 \times 10^{-5} \frac{H_{CO_2cal} P_{CO_2} E_{CO_2} Vt}{H_{CO_2cal} v_s}$$

where

$P_{CO_2cal}$  is partial pressure of CO<sub>2</sub> at calibration

$H_{CO_2cal}$  is peak ht at calibration

$H_{CO_2}$  is inlet peak ht in same units

$E_{CO_2}$  is CO<sub>2</sub> removal efficiency in percent

$V$  is air flow, ml/min at rig pressure

$t$  is time of sorption, min

$\omega_s$  is sample wt, gms

$v_s$  is sample volume, ml

For water vapor:

$$C_{vol} = 0.962 \times 10^{-5} \frac{E_{H_2O} Vt P_{H_2O}}{v_s}$$

$$C_{wt} = \frac{C_{vol}}{10} \frac{v_s}{\omega_s} \quad \text{where } E_{H_2O} = \text{removal efficiency for H}_2\text{O in percent}$$

$V$  = air flow, ml/min at rig pressure

$t$  = time of sorption, min

$P_{H_2O}$  = partial pressure of water vapor in feed, mmHg

$v_s$  = volume of sample, ml

$\omega_s$  = sample wt, gms

Both calculations depend on the linearity of the chromatographic peak heights with composition. Examination of Figures 25, 26 show that the CO<sub>2</sub> composition is linear with peak heights but the water is not. The maximum non-linearity introduces a maximum error of about 10% into an individual analysis, with zero error at zero concentration or near the feed concentration. The probable error in removal efficiency is about +5%, insignificant and equivalent in effect to a +1/2°F error in inlet dew point.

Calculation Sheet.- The Sorbent Evaluator calculation sheet (Figure 27) was used for all runs. Five calculations were handled on one sheet, along with all data except the actual breakthrough curves. A sample calculation is given below, keyed to letters (a-q) to aid in the description.

Sample and run identification were first noted (a). Then the rotameter reading and its calibrated flow rate (b), and then a conversion factor was applied to give flow in ml/min (or liters/min) (c). Adsorption and desorption conditions were next noted (d). Then the CO<sub>2</sub> feed chromatographic peak heights (e), calibration height (f), PCO<sub>2</sub> of the calibration gas (in mm Hg at rig pressure) (g), and a factor (h) (when using other than standard chromatographic attenuation) were recorded. Similarly for water vapor the feed peak height (i) was noted and equated with the dew point which generally was taken as the cooling water temperature to the dew point heat exchanger (j). The corresponding P<sub>H<sub>2</sub>O</sub> in mm Hg was then noted (k) from graph or table.

The removal efficiency was then calculated (l) by tracing on good tracing paper the breakthrough curves for water and CO<sub>2</sub> and applying the feed composition as shown in Figure 28. Using an analytical balance the total area, bypass area and adsorbed area were determined, enabling calculation of removal efficiency by ratio.


The factors determined above along with sample weight and volume were then inserted in the final equation for CO<sub>2</sub> (m) and H<sub>2</sub>O (n), leading to a volume capacity (p) and a weight capacity (q).

#### MATERIAL DESCRIPTION

HS-C is a proprietary sorbent made from commercially available raw materials. It consists of small (1/2 mm) spheres of a polymeric macro-reticular substrate which is coated with a thick, polymeric, liquid sorbent made from low molecular weight amines.

The substrate is Rohm & Haas XAD-7 sorbent. It is processed at Hamilton Standard by sieving, by washing with deionized distilled water and analytical grade methyl alcohol, and then coated with the liquid sorbent, Dow PEI-18 and dried. Ultra-pure water is needed for the washing procedure since traces of copper adversely affect adsorptive performance.






SMALL SCALE TESTS  
BREAKTHROUGH CURVE TRACINGS FROM CHROMATOGRAM

XAD-7 is a polymeric acrylic ester (a relative of Plexiglas and other acrylic plastics) in the form of small spheres (typically 1/2 mm and smaller) which have many microscopic fissures, etc. making them very porous. They are white in color, and crush with moderate difficulty using the flat side of a knife. They swell to twice dry volume when wet with water or alcohol.

The coating is Dow PEI-18, a polyethylenimine (PEI) of the chemical form:



It is thick and viscous (like cold molasses) with an average molecular weight of 1800 (hence PEI-18).

#### Evaluation

Prepared HS-C was evaluated in the small scale apparatus using a set cycle. These nominal conditions were:

Sample Size	5 ml
P <sub>CO2</sub>	3 mm Hg
Air Flow	500 ml/min
Air Pressure	28 in. Hg.
Air Dew Point	52°F
Bed Temperature	75°F
Desorb Pressure	50 microns or better at end of desorption
Cycle Times	45 minutes adsorption, 45 minutes desorption

The capacities were evaluated according to the procedures of the "Calculations" above. As originally reported in monthly reports, the small scale apparatus indicated capacities greater than those measured in the more accurate large scale tests. Subsequent to the large scale testing, the small scale rig was recalibrated and adjusted using standard gas mixture used for the large scale tests. Subsequent results appear to give quite good correlation at the design operating point.

#### MATERIAL VARIATIONS

##### Substrate

The XAD-7 shipped by Rohm & Haas was manufactured in batches, and these batches have differed in their adsorption rate and the particle size of the



finished HS-C. The maximum adsorption capacity, however, has been constant.

From a given batch of XAD-7, the largest particles will be 24 to 28 mesh. Smaller sizes (30-40 mesh) give a slight improvement (5%) in adsorption capacity while the larger substrate (24-28 mesh) has less pressure drop (Figure 2).

#### Coating Weight

With too little coating, all the available pore area is not coated with liquid. With too much coating, the excess liquid will tend to clog the pores of the substrate. There is, therefore, an optimum coating weight. Furthermore, this weight differs with substrate batch and particle size. Such capacity variations are shown in Figure 2.

#### Coating Composition

PEI-18 has been chosen as the HS-C coating of choice. Only limited tests with other related materials have been run, but it has been established that higher molecular weight polymers are not as effective.

Lower molecular weight polymers have a higher vapor pressure and have not been exhaustively explored. However, the simplest practical amine, TEPA Tetraethylenepentamine, showed improved capacities when compared to the optimized HS-C used in the large scale tests (Series I and II), especially at higher  $\text{CO}_2$  partial pressures. Figure 1 shows the improvement in capacity; about 5% at  $P_{\text{CO}_2} = 5$  mm Hg. Its vapor pressure is estimated to be 1 micron at room temperature; that of PEI-18 is unmeasurably low. Preliminary experiments indicate that the vapor pressure of TEPA can be lowered and the coating made insoluble by polymerizing the coating in place on the substrate. This procedure has been successfully applied to a PEI-18 coating rendering it insoluble and permitting steam desorption of the material in a  $\text{CO}_2$  concentrator application. This approach was not used here because the polymerization does not enhance the performance of PEI-18 preparation when operating in the vacuum desorb mode, nor is such polymerization necessary to keep the coating in place on the substrate.

#### Selected HS-C Material

Run Series I and II (See Large Scale Tests, Appendix F)

Substrate Mesh Size	24-28 mesh
Coating Agent	PEI-18
Coating Weight	24.2%
Density	0.384 gm/cc

## Run Series III (See Large Scale Tests, Appendix F)

Substrate Mesh Size	30-40 mesh
Coating Agent	PEI-18
Coating Weight	20.6%
Density	0.378 gm/cc

Reproducibility. - The techniques for preparing HS-C have been refined as a result of the requirement to manufacture a quantity of material during this program. Key improvements were made in washing, classifying, vacuum drying, and coating. The major contribution to uniformity resulting from the improved coating technique.

Present preparation techniques produce a material with performance variations of less than 5% overall when made to the same formulation. A table showing performance of the individual batches used for the 7-day test is shown in Appendix B.

## HS-C LIFE TEST

Prior to the start of the present program, a 2000 hour life test of an early formulation of HS-C material was run in the small scale test apparatus.

The nominal 45 minute adsorb, 45 minute desorb cycle was run, with capacity calculated for the first 30 minutes of adsorb only. Table II shows the performance during the test, which included a parametric study.

At the beginning of the test the capacity of the material for CO<sub>2</sub> and water measured 1.95% and 5.45% by weight. After 2000 hours, the capacities were 2.00% and 6.12%, respectively. Since these capacities were taken from the small scale apparatus, the CO<sub>2</sub> weight could not be measured directly, so the capacity levels are, as usual, somewhat higher than a large scale test would show. Figure 3 shows the capacity variance throughout the life test.

## SOLVENT TESTS

Objectives

Materials used in the spacecraft are likely to have been cleaned in organic solvents. It is important that sensitivity of the HS-C to such solvents be determined so that proper protection may be given the bed. The solvent tests were conducted to determine the effect of large quantities of gaseous solvent on bed performance.

Experimental Method

Incoming air to the small scale sorbent evaluator was passed over liquid solvent prior to entering the apparatus, tending to saturate the air to the vapor pressure of the solvent. In one case (Freon 113) the solvent vapor pressure was reduced by cooling to 50°F, otherwise room temperature solvent was used. The nominal adsorption/desorption conditions were run.<sup>1</sup>

Bed #1 was loaded with a preparation similar to those used for Run Series III of the large scale tests,<sup>2</sup> and bed #2 was loaded with material derived from an earlier batch of substrate used for Run Series I and II.

<sup>1</sup>See page 57

<sup>2</sup>See page 59



After cyclic equilibrium was reached, initial capacities were calculated, and then the beds were fed with solvent-contaminated air for 10 cycles and another capacity was taken. Then the solvent contamination was removed and the beds were cycled for about 6 recovery cycles and the capacity again measured.

### Results

Resultant data are given in Table III. Results are more erratic than usual with this apparatus because the solvents affected the chromatographic columns, confusing the analyses by shifting the baseline. Sometimes the solvent caused a slight ( $\pm 10\%$  for  $\text{CO}_2$ ,  $\pm 20\%$  for  $\text{H}_2\text{O}$ ) capacity increase and sometimes a decrease. There was little correspondence between beds 1 and 2 even though both saw the same feed composition. Apparent water capacity was most severely affected, probably because of the analysis problem, swinging  $\pm 20\%$  from the initial capacity, while  $\text{CO}_2$  capacity varied  $\pm 10\%$ .

### Conclusions

After exposure to all three solvents the beds recovered at least 90% of their original performance in both  $\text{CO}_2$  and  $\text{H}_2\text{O}$  capacity. At most, the effect was 10% performance loss, but even this figure is believed pessimistic because of the interference with chromatographic analysis produced by the solvents.

### STRUCTURAL TESTS

When HS-C serves aboard a space vehicle, it must be physically capable of withstanding the launch environment. HS-C structural soundness tests were therefore derived from the tests used for the LM LiOH canister, and these tests were run using HS-C in a LM canister as a part of Hamilton Standard's general  $\text{CO}_2$  and humidity control program (Independent Research and Development).

The complete test plan and results are given as Appendix A. In summary, four types of test were run before and after shaking the canister and no degradation was noted. The resistance to dusting was evaluated directly by microscopic examination, counting fractured HS-C particles, and indirectly by measuring canister pressure drop and apparent density. The adsorptive capacity of the material before and after shaking was also measured.

The results of these tests were all negative. Summary quantitative figures abstracted from Appendix A are given in Table I.

RIG NO.  
TYPE OF TEST  
W.P.I. NO.

## SOLVENT TESTS

PLAN OF TEST NO.  
SERIAL NO.

PART NO.

DATE  
ENGINEER  
OPERATORSUNITS →  
TIME

SOLVENT	Vol% in feed	Bed No.	Capacity of	Capacity in wt.% with Initial solvent recovery
PREGON 113	0.03	1	CO <sub>2</sub>	1.57 1.65 1.47
			H <sub>2</sub> O	4.09 4.43 4.21
		2	CO <sub>2</sub>	1.59 1.57 1.51
			H <sub>2</sub> O	4.36 4.27 3.89
TETRACHLORO-ETHYLENE	0.04	1	CO <sub>2</sub>	1.47 1.49 1.65
			H <sub>2</sub> O	4.21 3.49 4.31
		2	CO <sub>2</sub>	1.51 1.46 1.50
			H <sub>2</sub> O	3.89 3.37 4.30
TRICHLORO-ETHANE	0.04	1	CO <sub>2</sub>	1.65 1.49 1.54
			H <sub>2</sub> O	4.31 3.97 3.75
		2	CO <sub>2</sub>	1.50 1.63 1.42
			H <sub>2</sub> O	4.30 4.10 4.00

All tests:

Adsorption time: 45 minutes

Calculated for: 30 minutes

Desorption time: 45 minutes

Pressure: 28 in Hg

Air inlet temp: 69°F

Canister temp: 75°F

Desorption press: 40 μ (min.)

P<sub>CO<sub>2</sub></sub> (inlet): 3 mm Hg

Dew point (inlet): 52°F

Air flow rate: 500 ml/min

Sample size: 5 ml

(12 gm)

REMARKS:

BED 1 Preparation P-3930 (made from substrate used for Run Series III)  
 BED 2 Preparation P-4536 (made from substrate used for Run Series I & II)

PAGE NO.

REPORT NO.

## RESULTS OF SOLVENT TESTS

ORIGINAL PAGE IS  
OF POOR QUALITY

TABLE III

## FLAMMABILITY TESTS

HS-C is a nonmetallic material and therefore falls under the jurisdiction of D-NA-0002 (Procedures and Requirements for Flammability and Offgassing Evaluation of Manned Spacecraft Nonmetallic Materials).

As part of Hamilton Standard's general CO<sub>2</sub> and Humidity Control Program (Independent Research and Development) HS-C material was subjected to flammability tests, using the projected shuttle atmosphere of standard air.

<u>Results</u>		
<u>Test No.</u>	<u>Description</u>	<u>Results</u>
2	Downward Propagation Rate	Self extinguishing after 3/8" burn.
3	Flash and Fire Point	No visible flash below 400°F, no combustion below 450°F.
8	Materials in Vented Containers	No ignition when subject to the most severe ignition source.

Discussion

Test No. 2 and 3 are standard tests and were conducted following the procedure from D-NA-0002.

The flammability test for materials in vented containers is Test No. 8, the pertinent portions of which are quoted below:

Sample Preparation:

The container shall be the same size, geometry and material as the flight container.

The equipment to be tested shall be the same, with regard to the nonmetallics, as the flight equipment. Electronic parts and similar expensive metallic or ceramic entities may be simulated.

The equipment shall be packaged and positioned in the container in the same manner as in the flight article.


Ignition Source:

External Ignition - Any container without an internal ignition source.

Ignition Source - a flame source representative of the worst possible S/C fire shall be placed outside the container opposite the most combustible material in the test configuration. Sufficient energy shall be supplied to ignite the configuration or assure that it will not ignite in actual service. The contractor shall furnish analyses to support the selection of ignition sources.

The described test was performed on a representative HS-C canister configuration, which successfully passed. The details of this test are described below.


The proposed HS-C canister design is one which prevents both ignition and propagation. It consists of a plate fin type heat exchanger with relatively small passages, which contain the HS-C.





Screens are placed over both faces at the heat exchanger, and a metallic honeycomb is used to retain the screen. In this configuration, the screen acts as a flame barrier and the honeycomb prevents propagation. This is the configuration used for performance testing.

A representative model of the configuration described above was used for flammability testing. It consisted of three layers of honeycomb, the middle layer representing the heat exchanger.



With the passages in a vertical position, a gas burner flame was held under the test unit. After a period of about 15 seconds, the screen started to glow red and the honeycomb (aluminum) began to melt locally.

The HS-C material began to give off a white smoke. The flame was then removed. Within one minute after flame removal, the smoke evolution ceased. At no time was there a visible flame from the HS-C.

The unit was disassembled and the HS-C examined. Approximately one layer of HS-C (0.02") was discolored a light shade of brown.

## TOXICANT TEST

It is necessary, of course, that the HS-C effluent gas be safely breathable in normal operation and in failure modes. A sample of HS-C effluent gas was taken at the close of the large scale tests (Run Series I, cycle 150, p F-13) and analyzed. Similar gas samples were taken from HS-C used for Run Series I and II after heating to 180°F with a volume of atmospheric air simulating the spacecraft cabin according to a preliminary specification (see Hamilton Standard's Plan of Test, Appendix C). Later samples from Run Series III were tested to Specification MSC-PA-D-67-13, Addendum 1, 1A, 2, 2A, which calls for heating for 72 hours at 155° ± 5°F followed by a day's cooling prior to analysis. Analysis was made only for ammonia. Detailed results of the toxicant tests are given in Appendix C.

Discussion

The toxicant analysis in the air volume simulating the shuttle cabin levels after 1, 6, and 24 hours shows no clear trend of contaminant increase except for brominated hydrocarbons. Brominated hydrocarbons, ammonia and toluene are the only components which reach undesirable toxicant concentrations.

150 to 300  $\mu$ gms NH<sub>3</sub> per gram of HS-C were observed in the toxicant tests to specification MSC-PA-D-67-13, confirming the ammonia evolution observed in the earlier toxicant tests.

## Bromine

The source of the unsaturated brominated hydrocarbons cannot be HS-C, for bromine is not used in the manufacture of either substrate or coating agent. It is presumed that the contamination was caused by the heavy manometer fluid ABr<sub>4</sub> which was used in test rig 88. The main constituent of this material<sup>1</sup> is heavily brominated and boils at 151°C, but it is not reported in the gas analyses. The materials reported are the impurities to be expected during the manufacture of ABr<sub>4</sub> from acetylene and bromine.

<sup>1</sup>tetrabromoethane or commonly acetylene tetrabromide (ABr<sub>4</sub>)

### Ammonia

Ammonia almost certainly arises from the HS-C coating agent, which is an amine. Subsequent investigation has shown that the batch of coating agent used for Series I tests was contaminated during manufacture with ammonia (to about 0.2%), was manufactured in 1968. A newer (1970) batch of coating agent was obtained and used to make the HS-C for Run Series III, but tests conducted with this material also produced high ammonia levels.

### Toluene

Toluene is a known contaminant in the substrate. Most of it is washed from the bed during the alcohol wash. Remaining traces detected by the toxicant test probably were vaporized from the depths of the porous substrate. This material is expected to be removed if the HS-C is heated (without air) to 180°F for 24 hours. The HS-C prepared for Run Series I was heated to 135°F for 24 hours, and that for Run Series III for 48 hours.

### Conclusion

HS-C evolves 150-300  $\mu$ gms of ammonia per gram of HS-C when heated in air to 155°F and cooled for 24 hours. High levels of ammonia were also found when the HS-C was not cooled prior to analysis.

### Recommendations

Future HS-C preparations should be fully desorbed during preparation at more severe conditions than those expected in flight to remove all contaminants prior to contaminant evaluation. Means for reducing or eliminating ammonia evolution should be investigated.

COMPUTER PROGRAM DESCRIPTION

## INTRODUCTION

The HS-C computer program predicts water and CO<sub>2</sub> adsorption and desorption rates along the length of an HS-C bed, calculating effluent gas composition and residual bed loadings as a function of time. Single modes or a succession of adsorption/desorption cycles can be calculated.

The bed can be cooled/heated during adsorption/desorption by cross-flow heat exchange with a cooling/heating fluid. An option for infinite conductance and flow allows prediction of the performance of an isothermal bed. This may be used as a reference point to evaluate system performance.

Desorption can be by gas purge with a pure inert gas, or with a fixed vacuum. Concentration and (for vacuum desorption) pressure gradients are calculated along the length of the bed.

## DESCRIPTION AND MATHEMATICAL MODEL

The following mathematical description of the adsorption and desorption of both H<sub>2</sub>O and CO<sub>2</sub> on HS-C illustrates an application of the fundamental principles of surface chemistry and reaction kinetics to an adsorption phenomena.

Adsorption and Desorption




The rate of mass transport and sorption of gases flowing through a packed sorbent bed depends on the following adsorption considerations (desorption is assumed to be a reversal of the adsorption process):

1. Diffusion of the sorbates to the surface of the sorbent particles or beads (i.e., diffusion through the boundary layer).
2. Diffusion through the porous beads to the surface sites.
3. Rate of chemisorption at the surface site.


Experimental studies have shown that step 3, chemisorption, is the rate controlling mechanism. The chemisorption process equations in the mathematical model include the simultaneous adsorption of H<sub>2</sub>O and CO<sub>2</sub> in the material as well as a CO<sub>2</sub> enhancement reaction with adsorbed H<sub>2</sub>O.

The chemisorption reaction mechanism of HS-C is as follows:

There are three kinds of sites, X, Y and Z. X sites react only with CO<sub>2</sub>; Y and Z sites only with H<sub>2</sub>O, thus, as have been previously introduced:



Production of Y·H<sub>2</sub>O gives rise to another reaction:



For reactions 1, 2, 3, and 4, the forward and reverse reaction rate coefficients (k) have been noted. This mechanism explains the following experimental observations:

1. High capacity for CO<sub>2</sub> removal in the presence and absence of H<sub>2</sub>O(g) - demonstrated by reaction #1.
2. High capacity of H<sub>2</sub>O removal in the presence and absence of CO<sub>2</sub>(g) - demonstrated by reactions #1 and #3.
3. Enhancement of CO<sub>2</sub>(g) capacity by the presence of large amounts of H<sub>2</sub>O(g) - demonstrated by reaction #4.

#### Mathematical Formulation

The equations for the adsorption/desorption mechanism which have been implemented in the digital computer simulation are:

Rate Equations

$$\frac{-dX}{dt} = (K_X)(P_{\text{CO}_2})(X) - (K_{\text{XR}})(X \cdot \text{CO}_2)$$

$$\frac{-dY}{dt} = (K_Y)(P_{\text{H}_2\text{O}})(Y) - (K_{\text{YR}})(Y \cdot \text{H}_2\text{O})$$

Rate Equations

$$-\frac{dz}{dt} = (K_z)(P_{H_2O})(Z) - (K_{zr})(Z.H_2O)$$

$$-\frac{d(Y.H_2O)}{dt} = (K_{y.H_2O})(P_{CO_2})(Y.H_2O) - K_{y.H_2O}R(Y.H_2O.CO_2)$$

$$\frac{dM_{H_2O}}{dt} \text{ out} = + \frac{dM_{H_2O}}{dt} \text{ in} - \frac{dM_{H_2O}}{dt} \text{ ad}$$

$$\text{where: } \frac{dM_{H_2O}}{dt} = \left( \frac{dy}{dt} + \frac{dz}{dt} \right) w_{bed}$$

$$\frac{dM_{CO_2}}{dt} \text{ out} = - \frac{dM_{CO_2}}{dt} \text{ in} - \frac{dM_{CO_2}}{dt} \text{ ad}$$

$$\text{where: } \frac{dM_{CO_2}}{dt} \text{ ad} = \left( \frac{dx}{dt} + \frac{d(Y.H_2O)}{dt} \right) w_{bed}$$

Perfect Gas  
Law

$$PV = MRT$$

Arrhenius'  
Law

$$K = K_0 e^{-E/RT} \text{ expresses dependency of rate constants on temperature}$$

where:

$P_{CO_2}$  = Partial Pressure of  $CO_2$ , mm Hg

$P_{H_2O}$  = Partial Pressure of  $H_2O$ , mm Hg

(X) = Site concentrations available for  $CO_2$ ,  $\frac{\text{lb-mole}}{\text{lb}_{bed}}$

(X. $CO_2$ ) = Site concentrations not available for  $CO_2$ ,  $\frac{\text{lb-mole}}{\text{lb}_{bed}}$

(Y) = Site concentrations available for  $H_2O$ ,  $\frac{\text{lb-mole}}{\text{lb}_{bed}}$

- $(Y.H_2O) =$  Site concentrations not available for  $H_2O$ , but available for  $CO_2$ ,  $\frac{1b\text{-mole}}{1b_{bed}}$
- $(Y.H_2O.CO_2) =$  Site concentrations not available for  $CO_2$ ,  $\frac{1b\text{-mole}}{1b_{bed}}$
- $(Z) =$  Site concentrations available for  $H_2O$ ,  $\frac{1b\text{-mole}}{1b_{bed}}$
- $(Z.H_2O) =$  Site concentrations not available for  $H_2O$ ,  $\frac{1b\text{-mole}}{1b_{bed}}$
- $K_X =$  Forward rate coefficient for  $CO_2$  on X sites,  $\frac{1}{\text{min-mm Hg}}$
- $K_{Xr} =$  Reverse rate coefficient for  $CO_2$  on X sites,  $\frac{1}{\text{min}}$
- $K_Y =$  Forward rate coefficient for  $H_2O$  on y sites,  $\frac{1}{\text{min-mm Hg}}$
- $K_{Yr} =$  Reverse rate coefficient for  $H_2O$  on y sites,  $\frac{1}{\text{min}}$
- $K_Z =$  Forward rate coefficient for  $H_2O$  on z sites,  $\frac{1}{\text{min-mm Hg}}$
- $K_{Zr} =$  Reverse rate coefficient for  $H_2O$  on z sites,  $\frac{1}{\text{min}}$
- $K_{Y.H_2O} =$  Forward rate coefficient for  $CO_2$  on  $y.H_2O$  sites,  $\frac{1}{\text{min-mm Hg}}$
- $K_{Y.H_2OR} =$  Reverse rate coefficient for  $CO_2$  on  $y.H_2O$  sites,  $\frac{1}{\text{min}}$

$M_{H_2O}^{in}$	=	moles of $H_2O$ into node
$M_{CO_2}^{in}$	=	moles of $CO_2$ into node
$M_{H_2O}^{out}$	=	moles of $H_2O$ out of node
$M_{CO_2}^{out}$	=	moles of $CO_2$ out of node
$M_{H_2O}^{ad}$	=	moles of $H_2O$ adsorbed
$M_{CO_2}^{ad}$	=	moles of $CO_2$ adsorbed
$R$	=	gas constant - $555 \frac{ft^3-mm Hg}{lb-mole-^{\circ}R}$
$T$	=	carrier gas temperature, $^{\circ}R$
$K_o$	=	rate coefficient independent of temperature
$W_{bed}$	=	weight of bed material, lb.

#### Vacuum Desorption Pressure Distribution

Calculation of nodal pressures during vacuum desorption requires consideration of pressure gradients through the bed and the void volume of the bed.

The pressure at each end of the bed is specified either as an input or can be calculated within the computer program to allow for either single or double end vacuum desorption.

The mathematical model uses the polytropic process equation along with the equation of state to relate time rate of pressure change with mass flow rate of constituents through the bed

$$\frac{P}{\rho^{\gamma}} = \text{const}$$

$$PV = WRT$$



The equation relating rate of pressure to mass flow rate becomes

$$\dot{P} = \frac{\gamma RT}{V} \dot{W}$$

$\gamma = 1.0$  isothermal process

$\gamma = 1.4$  adiabatic process

It is assumed in the model that the flow through the bed is laminar and can be defined by

$$\dot{W} = \frac{A D^2 E^3 P_{tot}}{298,000 L (1-E)^2 T_G} (P_{Tin} - P_{Tout})$$

where:  $\dot{W}$  - lb moles/min

$P_{TOT}$  - average total pressure (mmHg)

$P_{Tin}$  - total inlet pressure (mmHg)

$P_{Tout}$  - total outlet pressure (mmHg)

$T_G$  - process gas temperature ( $^{\circ}R$ )

$\mu$  - viscosity (lb-sec/in<sup>2</sup>)

$D$  - bead diameter (inches)

$L$  - bed length (inches)

$A$  - bed cross sectional area (in<sup>2</sup>)

$E$  - bed void fraction

#### Mathematical Formulation

The equations for the vacuum desorption pressure calculation which have been implemented in the digital computer simulation are:

outlet flow from each node

$$D_{MOi} = D_W P_{T_{avg}} (P_{Ti} - P_{Ti+1})$$

where:  $P_{T_{avg}} = (P_{Ti} + P_{Ti+1})/2$

$$D_W = \frac{A D^2 E^3}{298,000 L (1-E)^2 T_G}$$

Inflow to 1st node

$$D_{MI} = D_W P_{T \text{ avg}} (P_{in} - P_{T1})$$

$$P_{T \text{ avg}} = (P_{in} + P_{T1})/2$$

Mole flow of constituents

$$D_{MH1} = \left( \frac{P_{H_2O1}}{P_{T1}} \right) D_{MI1}$$

$$D_{MC1} = D_{MT1} - D_{MH1}$$

$$D_{MCi} = D_{MCO_{i-1}}$$

$$D_{HCi} = D_{HCO_{i-1}} \quad (i = 2 \dots n)$$

$$D_{MHOi} = \left( \frac{P_{H_2O_k}}{P_{T_k}} \right) D_{MOi}$$

$$k = i \text{ for positive } D_{MOi}$$

$$k = i + 1 \text{ or negative } D_{MOi}$$

$$D_{MCOi} = D_{MOi} - D_{MHOi}$$

Average nodal partial pressures

$$P = \int_0^t \dot{W} \frac{RT}{V}$$

where:  $V$  - node void volume, (ft<sup>3</sup>)

$T$  - node process gas temperature, (°R)

$R$  - 555 ft<sup>3</sup>-mmHg/°R lb mole

$\dot{W}$  - net mole flow rate into or out of node void volume

$\gamma$  - ratio of specific heats (assumed  $\gamma = 1.$ )

$D_{MOi}$  - total mole flow rate out of node (lb mole/min)

$P_{T \text{ avg}}$  - average nodal total pressure (mmHg)

$P_{Ti}$  - node inlet total pressure (mmHg)

$P_{Ti+1}$  - node outlet total pressure (mmHg)

$D_{MI}$  - total mole flow rate into 1st node (lb mole/min)

$D_{MH1}$  - node inlet H<sub>2</sub>O mole flow rate (lb mole/min)

$\dot{M}_{C_i}$  - node inlet CO<sub>2</sub> mole flow rate (lb mole/min)


$\dot{M}_{H_2O_i}$  - node outlet H<sub>2</sub>O mole flow rate (lb mole/min)

$\dot{M}_{CO_2_i}$  - node outlet CO<sub>2</sub> mole flow rate (lb mole/min)

### Heat Transfer

To predict performance of a non isothermal bed a crossflow air-air heat exchanger was modeled. The heat transfer analysis is taken from "Computer Analysis Techniques for Spacecraft Adsorption Beds" by R. L. Blakely and B. N. Taylor, McDonnell Douglas, March 17, 1969.

The figure below shows the node structure of the heat transfer model.



The number of nodes in the process gas flow direction is equal to the number of nodes represented in the chemisorption kinetic model. Heat exchanger core temperature, bed temperature and the process gas temperature are calculated at each node. Average coolant gas outlet temperature is also calculated. Heat conduction in the axial direction of the process gas is included, and a log mean temperature difference is assumed between the heat exchanger temperature and coolant gas temperature, as well as between bed temperature and process gas temperature.

### Mathematical Formulation.-

#### Bed Node Heat Transfer

$$\left( \frac{T_{B_X} - T_{B_X \text{ past}}}{\tau} \right) M_B C_{PB} = (\dot{W}_{AIR_X} C_P + \dot{W}_{H_2O_X} C_{PH_2O} + \dot{W}_{CO_2_X} C_{PCO_2}) (1 - e^{-A}) (T_{G_{Xin}} - T_{B_X})$$

## METHOD OF SOLUTION

The transient processes involved in the adsorption and desorption modes are carried out using a finite difference technique employing multiple nodes. For each node the rates of adsorption of  $\text{CO}_2$  and  $\text{H}_2\text{O}$  are calculated based on past values of loading and partial pressure, and the heat transfer rates are calculated based on past values of temperatures, and the constituent flow rates through the bed. Simple rectangular integration is employed to integrate the rates to obtain the loadings of each constituent, temperatures of the bed and process gas, and nodal pressures during vacuum desorption.

$$+ U_{BHX} A_{BHX} (T_{HX_x} - T_{B_x}) + \sum Q_{R_x} + \frac{K_{B^*} A_B}{\Delta X} (T_{B_{x-1}} - T_{B_x})$$

$$+ \frac{K_B A_B}{\Delta X} (T_{B_{x+1}} - T_{B_x})$$

$$T_{GOUT_x} = T_{B_x} + (T_{Gin_x} - T_{B_x}) e^{-A}$$

where:

$$U_{BHX} = \frac{1}{\frac{1}{h_B} + \frac{1}{h_{HX}}}$$

$$h_B = f(\dot{W}_{REAC}) = f(\dot{W}_{AIR} + \dot{W}_{H_2O} + \dot{W}_{CO_2})$$

$$h_{HX} = f(\dot{W}_C)$$

$$A = \frac{h_B A_{BHX}}{\dot{W}_{REAC} C_p}$$

Heat exchanger node heat transfer

$$\begin{aligned} \frac{T_{HX_x} - T_{HX_{xpast}}}{\Delta t} M_{HX} C_p &= \dot{W}_C C_{p_c} (1 - e^{-B}) (T_{Cin} - T_{HX_x}) \\ &+ U_{BHX} A_{BHX} (T_{B_x} - T_{HX_x}) + U_{AMB} A_{AMB} (T_{AMB} - T_{HX_x}) \\ &+ \frac{K_{HX} A_{HX}}{(X-1) - X} (T_{HX_{x-1}} - T_{HX_x}) + \frac{K_{HX} A_{HX}}{X - (X+1)} (T_{HX_{x+1}} - T_{HX_x}) \end{aligned}$$

$$T_{\text{COUT}_X} = T_{\text{HX}_X} + (T_{\text{Cin}} - T_{\text{HX}_X}) e^{-B}$$

where:  $B = \frac{h_C A_{\text{CHX}}}{\dot{W}_C C_{\text{PC}}}$

$$h_C = F (\dot{W}_C)$$

### PROGRAM CAPABILITIES

The program predicts either the isothermal or nonisothermal performance of a single adsorption period (used for analyzing a breakthrough curve), a single vacuum or inert gas purge desorption period (knowing initial bed loadings at the beginning of the desorption run), and cyclic operation with either vacuum desorption or gas purge desorption. In addition the program predicts CO<sub>2</sub> adsorption in a dry atmosphere and H<sub>2</sub>O adsorption in a CO<sub>2</sub> free atmosphere.

### Program Options

- . Isothermal Operation
  - set ISOT (8) = 0.
  - set TCIN (35) = Isothermal Bed Temperature
- . Nonisothermal Operation
  - set ISOT (8) = 1.
  - set TCIN (35) = Coolant Inlet Temperature
- . Single Adsorption Period
  - set IND (6) = 0.
  - ADSORB (39) = TMAX (2)
  - PIH20 (15) = inlet H<sub>2</sub>O partial pressure
  - PICO2 (16) = inlet CO<sub>2</sub> partial pressure
- . Single Vacuum Desorption Period
  - set IND (6) = 1.
  - DESORB (40) = TMAX (2)
  - IDES (7) = 0.
  - PIH20 (15) = inlet H<sub>2</sub>O partial pressure at end of adsorption
  - PICO2 (16) = inlet CO<sub>2</sub> partial pressure at end of adsorption
  - PAIR (33) = initial total process gas pressure
  - Q (34) = process flow rate during adsorption needed to initialize the heat exchanger
  - XJ (9) = number of passes through vacuum pressure calculation each system pass

- . Single Gas Purge Desorption Period
  - set IND (6) = 1.
  - DESORB (40) = TMAX (2)
  - IDES (7) = 1.
  - PIH2O (15) = inlet H<sub>2</sub>O partial pressure at end of adsorption
  - PICO2 (16) = inlet CO<sub>2</sub> partial pressure at end of adsorption
  - PAIR (33) = initial total process gas pressure
  - Q (34) = purge gas flow rate
- . Cyclic Operation
  - set IND (6) = 0.
  - ADSORB (39) = desired adsorb period
  - DESORB (40) = desired desorb period
  - IDES (7) = 0 for vacuum desorption
  - 1 for inert gas purge desorption

#### PROGRAM RESTRICTIONS

- Only allows an inert gas purge (cannot use for gas purge with some P<sub>H2O</sub> or P<sub>CO2</sub> in the gas.
- Does not allow for desorption at pressures above the partial pressure of H<sub>2</sub>O and CO<sub>2</sub>.
- The pressures at each end of the bed during vacuum desorption must be specified as program inputs (does not include a simulation for a vacuum system).
- Inlet process gas temperature and inlet coolant temperature are constant (specified as program inputs) and can not be varied during the transient.

#### INPUT/OUTPUT PARAMETERS

Input/output parameters for the computer program are listed in Appendix D.

#### PROGRAM FLOW CHARTS

Program flow charts for the computer program are listed in Appendix D.

## PROGRAM SYMBOL DEFINITIONS

Program symbol definitions for the computer program are listed in Appendix D.

## PROGRAM SOURCE LISTINGS

Program source listings and a sample case output for the computer program are given in Appendix D.

## SAMPLE CASE

A sample case has been processed for cycle 16 of Run Series III (large scale tests) and included at the end of the computer output (Appendix D).

The CO<sub>2</sub> and water capacities predicted by the program well represent the observed data of cycle 16. This agreement was achieved by using kinetic constants obtained from work with an earlier HS-C material and modifying them to fit the data of cycle 16. Proper constants should be obtained for the material to be used on the next contract phase before the computer program is used to predict performance very far from test conditions.

### LABORATORY CONCEPT DEVELOPMENT

The two HS-C materials selected for test in "Material Variations" were tested in the laboratory in large (5 and 10 lb) and small (2 gm) scale tests.

The larger mesh size material was exhaustively tested in small scale tests, with twelve tests exploring performance variations due to changes in CO<sub>2</sub> feed concentration, inlet dew point, adsorption/desorption temperature, inlet flow rate, and cycle time. The smaller mesh material was run at nominal conditions only during the corresponding small scale tests.

For the large scale tests, 10 pounds of the larger mesh material were extensively, with fifteen parametric tests totaling 219 continuous hours (Run Series I) exploring the performance changes resulting from changes in inlet air temperature, inlet dew point, bed adsorb/desorb temperature, inlet CO<sub>2</sub> concentration, inlet air flow, cycle time, and desorption pressure.

To explore the effect of bed thickness, the bed was repacked with 5 pounds of the larger mesh size material and 22 additional hours of test accumulated (Run Series II).

Using the smaller mesh size material, a series of seven tests explored variations in cycle time, inlet dew point, inlet air flow, and inlet CO<sub>2</sub> concentration. 228 hours of continuous test were accumulated (Run Series III).

### SMALL SCALE DEVELOPMENT TESTS

The small scale apparatus previously described was used for the parametric tests of the HS-C material used in the Series I tests.

#### Test Objectives

The small scale test objectives were:

- To obtain parametric data prediction of large scale tests so as to minimize expensive large scale running time.
- To obtain parametric data over a wider range of variables than convenient with the large scale equipment.



### Test Accuracy

Data taken with with the small scale apparatus showed about 20% more capacity than was later confirmed with the large scale tests. This discrepancy was reduced by recalibration of the small scale apparatus with calibration gas used for the large scale tests. The trends in the parametric tests remain valid for they were confirmed in the large scale tests. The precision of the small scale tests is estimated as  $\pm 10\%$  or better. For accurate comparisons necessary during material development phases, the two beds are used in a comparative mode. In this manner comparative results are obtained that are precise to within  $\pm 5\%$ .

### Differences Between Large and Small Scale Tests

Except for test canister configuration and sample size, there were no important differences between conditions set for "nominal" small and large scale runs. Inlet gas flow rate was ratioed upward with sample size. Adsorption cycle time was cut to 30 minutes in the large scale tests because at this point  $\text{CO}_2$  adsorption was complete.

### Test Canisters

The canister for the small scale apparatus was a 1/2 inch stainless steel tube (0.035 in. wall) with screens on each end. The 5 ml test sample (about 2 grams) was 2 in. deep, and desorption was single end only. The 5 or 10 pound charge of HS-C in the large scale canister was 1-1/2 or 3 in. deep, normally desorbed from both ends. The flow passages were 14 in. x 0.15 in. The concentration of  $\text{CO}_2$  leaving the bed at the start of the adsorb cycle was zero for the small scale tests, but about 1/3 the feed composition in the large scale tests. This was interpreted as indicative of a large (33%) by-pass flow around the HS-C in the large scale canister, probably resulting from the numerous small (0.15 in.) air flow passages of the large scale canister.

### Parametric Data Description

Parametric data is presented on calculation sheets (Table IV). and graphs (Figures 4 through 8). There are two points each for the  $\text{CO}_2$  and  $\text{H}_2\text{O}$  adsorption of a given run, one calculated for 30 minutes adsorption time and one for the full 45 minutes.

SORBENT EVALUATOR CALCULATION SHEET

USE FLOW IN LITERS MIN WT IN KG VOL IN LITERS ML													
SAMPLE IDENTIFICATION		RAW FLOW RDG	CAL FLOW	FACTOR 1.3 FOR CFM 1.72 FOR CFH	FLOW LITERS MIN ML MIN	ADSORPTION			DESORPTION			ADSORPTION	
						PRESS. IN HG	AIR INLET T F	WATER TEMP F	WATER TEMP F	PRESS. IN HG OR IN	TIME MIN	TIME MIN	CALC TIME MIN
P7481 Bed 2 Mem.	1	9	510	1	510	28	75	75	75	30.25	45	45	30/45
Bed 1 Hi flow 1000	2	17	1000	1	1000								
Bed 1 Hi CO <sub>2</sub> 5mm	3	9	510	1	510								
Bed 1 Low CO <sub>2</sub> 2mm	4	9	510	1	510								
Bed 1 Low flow 250	5	6	250	1	250								
FEED CO <sub>2</sub> FEED H <sub>2</sub> O      MM      CYCLE      TEMPERATURE      COMPOSITION													
IN    OUT    DIFF    WT    IN    OUT    IN    OUT    DATE    ROLL    FT    ROLL    FT													
CO <sub>2</sub> IN (PCO <sub>2</sub> CAL)		1	17.2	2.72	2.79								
( F (HCO <sub>2</sub> CAL)			1	16.8		14.5	50	9.3	11-3-71		77		40
ATTENUATOR		2	16.1	2.72	280								
CALIB READ F			1	15.6		14.1	50	9.3	11-3-71		76		34
2		2	1										
2		1	2	3	27.0	2.72							
2		4	5	1	15.6		12.6	50	9.3	11-3-71		75	31
1		1	1										
1		2	5	4	10.6	2.72							
4		2	2	1	15.5		13.5	50	9.3	11-3-71		75	26
4		1	4										
		5	15.1	2.72	2.45		13.5	50	9.3	11-3-71		74	24
			1	15.5									
10													
MG													
CO <sub>2</sub> CO <sub>2</sub> CO <sub>2</sub> CO <sub>2</sub> CO <sub>2</sub> H <sub>2</sub> O    H <sub>2</sub> O    H <sub>2</sub> O    H <sub>2</sub> O    H <sub>2</sub> O													
X													
(1) TOTAL AREA													
(2) AREA BYPASS													
(3) AREA ADS													
(4) TOTAL CALC													
(5) X1000 REMOVAL EFF													
(6)													
NOTE: CALCULATIONS BELOW ARE BASED ON ANIMAL FLOW													
CO <sub>2</sub> CAPACITY													
RUN-ID		mm	10.5	1.65	1.65	FLOW ML MIN	TIME MIN	TIME VOL ML	GM	WT KG	WT	WT	WT
P7481 Bed 2 Mem.		1	10.5	1.65	2.79	32.7 31.8	310	45/30 5	9.63 7.61	5	1.88	2.43 1.72	WT
Hi Flow		2	10.5	1.65	2.80	17.6 13.3	1000	45/30 5	9.33 7.02	5	1.89	2.23 1.76	WT
Hi CO <sub>2</sub>		3	10.5	1.65	4.69	24.4 19.4	510	45/30 5	9.92 9.40	5	1.98	2.50 2.12	WT
Low CO <sub>2</sub>		4	10.5	1.65	1.86	41.5 32.6	510	45/30 5	6.58 5.59	5	1.88	1.67 1.41	WT
Low flow		5	10.5	1.65	2.45	41.7 33.0	250	45/30 5	4.66 3.93	5	1.88	1.17 .992	WT
H <sub>2</sub> O CAPACITY													
P7481 Bed 2 Mem.		1	10.5	1.65	9.3	63.0 52.9	310	45/30 5	21.7 17.3	5	1.98	5.47 4.37	WT
Hi Flow		2	10.5	1.65	9.3	30.1 22.1	1000	45/30 5	17.9 16.2	5	1.98	4.50 4.09	WT
Hi CO <sub>2</sub>		3	10.5	1.65	9.3	60.5 42.3	510	45/30 5	19.9 16.6	5	1.98	5.01 4.19	WT
Low CO <sub>2</sub>		4	10.5	1.65	9.3	61.5 49.1	510	45/30 5	20.2 16.9	5	1.98	5.10 4.24	WT
Low flow		5	10.5	1.65	9.3	66.0 74.5	250	45/30 5	15.0 11.6	5	1.98	3.78 2.82	WT

TABLE IV

SORBENT EVALUATOR CALCULATION SHEET

USE FLOW IN LITERS MIN OR ML MIN															WT IN KG GM		VOL IN LITERS ML					
SAMPLE IDENTIFICATION	RAW FLOW ROD	CAL FLOW	FACTOR 1.11 OR 1.12 FOR CFM	FLOW LITERS MIN ML MIN	ADSORPTION			DESORPTION			ADSORPTION											
					PRESS IN HG	AIR INLET T F	WATER TEMP F	WATER TEMP F	PRESS. IN HG OR K	TIME MIN	TIME MIN	CALC TIME MIN										
Low CO <sub>2</sub> Bed 1	6	9	510	1	510	28	75	75	75	30.4	45	45	45/30									
60° D.P. Bed 1	7	9	510	1	510						45	45	45/30									
40° DP Bed 1	8	9	510	1	510						45	45	45/30									
30 min 1/2 cycle	9	9	510	1	510						30	30	30									
Nominal Bed 1 P7481	10	9	510	1	510						45	45	45/30									
FEED CO <sub>2</sub>															FEED H <sub>2</sub> O		TEMPERATURE		COMPOSITION			
IN				OUT				IN		OUT		INLET		OUTLET		INLET		OUTLET				
CO <sub>2</sub> IN (PPCO <sub>2</sub> CAL)				CO <sub>2</sub> OUT (PPCO <sub>2</sub> CAL)				H <sub>2</sub> O IN (PPH <sub>2</sub> O CAL)		H <sub>2</sub> O OUT (PPH <sub>2</sub> O CAL)		TEMP		TEMP		H <sub>2</sub> O		H <sub>2</sub> O				
1				1				13.5		50		9.3		11.571		72		21				
ATTENUATOR															FEED H <sub>2</sub> O		TEMPERATURE		COMPOSITION			
CALIB		READ		F		FACTOR		IN		OUT		INLET		OUTLET		INLET		OUTLET				
2		1		1				19.0		60		12.8		11.571		70		14				
2		1		1				83		40		6.3		11.571		69		12				
2		4		.5				13.0		50		9.3		11.571				84				
1		1		1																		
1		2		.5																		
4		2		2																		
4		1		4																		
				10		17.5		2.72		3.05		14.0		50		9.3		11.571				
				1		15.6																
10															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
MG															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(1) TOTAL AREA															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(2) AREA BYPASS															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(3) AREA ADS															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(4) TOTAL CALC															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(5) X1000 % REMOVAL EFF															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
(6)															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
NOTE: CALCULATIONS BELOW ARE IN THE TGM															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
CO <sub>2</sub> CAPACITY															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
RUN		ID		CAN		FACTOR		INLET		OUTLET		INLET		OUTLET		INLET		OUTLET				
Low CO <sub>2</sub> Bed 1		6				2.42		814		75.0		510		4.10		3.42		5				
														5		2.48		1.92				
																		.865				
																		.626				
																		AT				
60° DP Bed 1		7				2.86		32.8		25.6		510		45/30		7.75		5				
														5		6.78		1.78				
																		2.01				
																		1.71				
																		AT				
40° DP Bed 1		8				3.91		30.0		83.0		510		45/30		7.26		5				
														5		6.31		1.98				
																		1.84				
																		1.57				
																		AT				
30 min 1/2 cycle		9				3.63		23.3		510		30		5		4.45		5				
														5		1.78		1.120				
																		AT				
Nominal Bed 1 P7481		10				3.05		35.1		27.7		510		45/30		9.16		5				
														5		7.15		1.98				
																		2.38				
																		1.95				
																		AT				
H <sub>2</sub> O CAPACITY															H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O		H <sub>2</sub> O	
RUN		ID		CAN		FACTOR		INLET		OUTLET		INLET		OUTLET		INLET		OUTLET				
Low CO <sub>2</sub>		6				9.3		65.5		50.7		510		45/30		20.9		5				
														5		17.1		1.92				
																		5.27				
																		4.32				
																		AT				
60° DP		7				12.8		66.5		55.0		510		45/30		31.1		5				
														5		25.1		1.98				
																		7.85				
																		6.34				
																		AT				
40° DP		8				6.3		64.6		50.3		510		45/30		14.0		5				
														5		12.0		1.92				
																		3.54				
																		2.04				
																		AT				
30 min 1/2 cy		9				9.3		63.9		510		30		5		17.5		5				
														5		1.92		4.41				
																		AT				
Nom Bed 1 P7481		10				9.3		65.5		53.7		510		45/30		22.1		5				
														5		18.0		1.92				
																		5.87				
																		4.55				
																		AT				

TABLE IV  
(CONTINUED)

SORBENT EVALUATOR CALCULATION SHEET

CR-115568  
SWISER-6040

SAMPLE IDENTIFICATION	RAW FLOW RDG	CAL FLOW	FACTOR	FLOW LITERS / MIN	ADSORPTION			DESORPTION			ADSORPTION		
					PRESS. IN HG	AIR INLET T F	WATER TEMP F	WATER TEMP F	PRESS. IN HG OR II	TIME MIN	TIME MIN	CALC TIME MIN	
High ads T <sub>780</sub>	11	9	510	1	510	28	75	78	78	30%	45	45	45/30
Low ads T <sub>670</sub>	12	9	510	1	510	28	75	67	67	30%	45	45	45/30
1 1/2 hr half cycle	13	9	510	1	510	28	75	75	75	30%	90	90	90
<p>FEED CO<sub>2</sub> MIN MG      FILL H<sub>2</sub>O IN WT    OUT OF HG      CYCLES      TEMPERATURE COMPOSITION</p> <p>DATE      ROLL      FT      ROLL      FT</p>													
0% CO <sub>2</sub> IN 10% CO <sub>2</sub> CAL	11	16.5	2.72	2.86		13.3	50	9.3					57
ATTENUATOR CALIB READ F	12	17.6	2.72	3.04		14.0	50	9.3					41
2 1 1	13	16.8	2.72	3.04		13.0	50	9.3					69
2 1 2													
2 1 3													
2 1 4													
2 1 5													
2 1 6													
2 1 7													
2 1 8													
2 1 9													
2 1 10													
2 1 11													
2 1 12													
2 1 13													
2 1 14													
2 1 15													
2 1 16													
2 1 17													
2 1 18													
2 1 19													
2 1 20													
2 1 21													
2 1 22													
2 1 23													
2 1 24													
2 1 25													
2 1 26													
2 1 27													
2 1 28													
2 1 29													
2 1 30													
2 1 31													
2 1 32													
2 1 33													
2 1 34													
2 1 35													
2 1 36													
2 1 37													
2 1 38													
2 1 39													
2 1 40													
2 1 41													
2 1 42													
2 1 43													
2 1 44													
2 1 45													
2 1 46													
2 1 47													
2 1 48													
2 1 49													
2 1 50													
2 1 51													
2 1 52													
2 1 53													
2 1 54													
2 1 55													
2 1 56													
2 1 57													
2 1 58													
2 1 59													
2 1 60													
2 1 61													
2 1 62													
2 1 63													
2 1 64													
2 1 65													
2 1 66													
2 1 67													
2 1 68													
2 1 69													
2 1 70													
2 1 71													
2 1 72													
2 1 73													
2 1 74													
2 1 75													
2 1 76													
2 1 77													
2 1 78													
2 1 79													
2 1 80													
2 1 81													
2 1 82													
2 1 83													
2 1 84													
2 1 85													
2 1 86													
2 1 87													
2 1 88													
2 1 89													
2 1 90													
2 1 91													
2 1 92													
2 1 93													
2 1 94													
2 1 95													
2 1 96													
2 1 97													
2 1 98													
2 1 99													
2 1 100													

TABLE IV  
(CONTINUED)

ORIGINAL PAGE 13  
OF POOR QUALITY

### CO<sub>2</sub> Feed Concentration

At high levels of  $P_{CO_2}$  (5 mm) the cyclic capacity for CO<sub>2</sub> was unaffected by the  $P_{CO_2}$  (Figure 4). From 3 mm downward the CO<sub>2</sub> cyclic capacity fell almost linearly with  $P_{CO_2}$ . This effect resulted from the existence of an equilibrium between the rate of adsorption and the rate of spontaneous desorption as the bed approaches saturation. The rate of adsorption was increased as  $P_{CO_2}$  increases but only in proportion to the adsorption sites which remained unoccupied. The rate of desorption increased with the number of occupied sites. As  $P_{CO_2}$  rises, most of the sites become filled and when spontaneous desorption did occur, a sufficiently high  $P_{CO_2}$  level (above 3 mm) caused rapid re-adsorption, keeping practically all the sites occupied.

The water capacity showed no clear dependence on CO<sub>2</sub> partial pressure, which is consistent with the proposed HS-C model.

Additional capacity was available for both water and CO<sub>2</sub> as the adsorption continued from 30 to 45 minutes. Later results (Figure 8) show there was little capacity to be gained after 45 minutes, even with correspondingly increasing desorption time.

### Dew Point

Dew point had a large effect on H<sub>2</sub>O capacity. When 45 minutes of adsorption was measured the capacity increased from 3.5% to 8% as dew point changed from 40°F to 60°F (Figure 5). This effect is important in maintaining cabin dew point as the water latent load increases.

CO<sub>2</sub> capacity is little affected with humidity, showing curious but repeatable slight maximum peaks at 50°F dew point.

### Adsorption/Desorption Temperature

CO<sub>2</sub> capacity depends little on temperature (Figure 6). Water capacity is significantly affected, with water capacity at 97°F down to 1/2 or 2/3 that of 67°F. This effect is not understood, but doubtless arises because of the net change with temperature of the overall rates of adsorption and desorption.

### Inlet Flow Rate

Inlet flow rate can affect capacity in two ways: (1) as flow increases a better mass transfer coefficient might improve mass transfer rate and thus capacity during a given time; (2) as flow increases more of the constituent to be adsorbed is passed through the bed and thus more may be available at the rear of the bed, again affecting the average rate of adsorption and thus capacity during a given time (Figure 7).

It is difficult to separate the two effects, but it seems clear that at gas flow rates over 500 ml/min., mass transfer is not limiting -- the data indicate a capacity decrease with increasing flow rate. A decrease seems impossible, and may perhaps be a result of unresolved test apparatus inaccuracy.

At low flow rates the second effect is clearly operative -- capacity falls linearly with flow for both water and CO<sub>2</sub>.

#### Cycle Time

Long cycle times allow generous contact with gases to be absorbed, and desorption from deep within the particles within the bulk of the bed. Shorter cycle times permit only incomplete desorption; in fact, casual observation has established that water apparently is desorbed before CO<sub>2</sub>. On this basis the CO<sub>2</sub> curve of Figure 8 has been shaped to show the low capacity for CO<sub>2</sub> at short cycle times. Alternately, water capacity is shown rising sharply with increasing cycle time.

At 45 minutes half-cycle time essentially all the CO<sub>2</sub> and water capacity available has been used, for a further increase in half-cycle time gave no important capacity increase. At 30 minutes the capacity for CO<sub>2</sub> was down by 50%. This effect was not nearly as strong in the large scale tests, probably due to the thinner half thickness of the bed (1-1/2 or 3/4 inch for large scale tests; 2 in. for small scale tests).

#### LARGE SCALE EQUIPMENT DESCRIPTION


Hamilton Standard's test rig #88 was used for the large scale test program. Figure 29 shows the exact configuration of the rig. Unused sections of the rig which were valved off are not shown. Figure 30 shows the rig in block form, from which its functioning may more easily be understood.

The test rig provided a stream of air humidified to a constant dew point with pressure, flow rate, CO<sub>2</sub> partial pressure, and temperature under closed control. Controlled temperature water was supplied to the test canister to provide cooling during adsorption and heating during desorption. Figures 31 and 32 are photographs of the large scale rig.

During adsorption (with valves as shown in Figures 29 and 30) CO<sub>2</sub> was automatically added to the system from a supply cylinder to maintain inlet


ORIGINAL PAGE IS  
OF POOR QUALITY

FIGURE 29




ORIGINAL PAGE IS  
OF POOR QUALITY

FIGURE 30



LARGE SCALE TESTS  
RIG 88 BLOCK DIAGRAM





LARGE SCALE TEST APPARATUS

FIGURE 31

LARGE SCALE TEST APPARATUS




FIGURE 32

CO<sub>2</sub> partial pressure constant even though the capacity of the bed was high at the start of the adsorption and low at the end. Total pressure was maintained automatically by adding CO<sub>2</sub> free air from a cylinder as necessary to make up for ullage losses.

Automatic cycling was controlled by a flexible timer actuating test canister inlet valves and the large desorption valves which connected each side of the test bed to a high (10-100 micron) vacuum source. The air flow was bypassed rather than stopped during desorption to minimize disturbances within the test rig.

### Large Scale Test Canister

The large scale test canister was constructed from a custom-sized commercial aluminum heat exchanger fitted with custom-made aluminum transition sections. The heat exchanger drawing is shown in Figure 33 and the transition sections as Figure 34.

HS-C was held loaded in the 0.1 inch sections between the 14 in. x 3 in. fins of the heat exchanger and retained by an 80 mesh screen on each side of the heat exchanger. Each screen was held in place with aluminum honeycomb material (1 in. thick with 3/8 in. hexagonal holes), in turn supported with two 1/2 in. rods across one dimension of the exchanger. Flow was downward through the exchanger. Photographs of the installed canister and the open canister ready for loading, are shown in Figures 10, 31, and 9. The assembly is shown mounted on the test rig, with the large desorption valves visible on the right and the motorized valves associated with the adsorption flow on the left. Screens and their supports are not visible. Note the ruler added to show the scale of the equipment in both Figures 9 and 10.

### Test Parameters

All test parameters were automatically recorded on a single strip chart except for CO<sub>2</sub> and air cylinder weights, which were recorded manually. Test parameters are listed in Table V.

### Flow Pattern

During the test program, there was a lingering doubt that all the HS-C material had sufficient contact with the air stream. Perhaps there were areas behind the coolant tubes which did not have enough air flow.

Reynolds number for the bed was calculated as 5, assuming a particle size of 26 mesh. Using electrically conductive paper as an analog of the air passage, the flow pattern was predicted by constructing perpendiculars to lines of constant voltage which were located experimentally. The resultant flow pattern about one tube is shown as Figure 35. Clearly, a satisfactory flow was obtained around the tubes.


Hamilton  
Standard

U  
A<sub>0</sub>



CR-115568  
SVHSR-6040

ORIGINAL PAGE IS  
OF POOR QUALITY

FIGURE 33



5/8 DIA TYP



TEST CANISTER DESIGN LAYOUT



### TEST CONFIGURATION HEADER LAYOUT

2. OBTAINABLE FROM AMERICAN STEEL & ALUM CORP. HTFD. CONV.  
 2 UNIT TO BE PRESSURE TIGHT. CHECK BY PRESSURIZING TO 5 P.S.I.G.  
 @ 2 P.S.I.G. AND IMMERSING IN WATER. NO VISIBLE LEAKAGE PERMISSIBLE.  
 1 WELD PER HS 191 CL III. LOCAL ANNEAL IN WELD AREA PER HS 1.3.2.E  
 NOTES

LARGE SCALE TESTS  
FLOW PATTERN WITHIN HEAT EXCHANGER USED AS HS-C  
CANISTER AS PREDICTED FROM ELECTRICAL ANALOG




FIGURE 35

## TEST PARAMETERS

Recorder Point No.	Signal Type	Logged Units	Description
1	Millivolt	in. H <sub>2</sub> O	Canister pressure drop (DP cell)
2	Millivolt	mmHg	CO <sub>2</sub> partial pressure (outlet) (LIRA infrared analyzer)
5	Thermocouple	°F	Canister coolant inlet
6	Thermocouple	°F	Air inlet temperature
9 or 15	Millivolt	mmHg	CO <sub>2</sub> partial pressure (inlet) (LIRA infrared analyzer)
10	Thermocouple	°F	Dew point condenser coolant inlet temperature
11	Thermocouple	°F	Canister coolant outlet
13	Millivolt	°F	Dew Point (Cambridge 880 Hygrometer)
14	Millivolt	Microns	Canister Vacuum (Stokes-Hastings gauge)
23	Millivolt	psia	Loop pressure (DP cell)
24	Millivolt	cfm	Loop flow rate (DP cell)
		hours or minutes	Clock time -- noted on chart manually each hour. Chart moved at 10 in/hr.
		cycle no.	Logged manually on chart each cycle.
		CO <sub>2</sub> Weight Air Weight	
		ft. left on roll	Printed on chart.

A Texas Instrument recorder was used with copper-constantan thermocouples and chart paper WTT20 (0-200°F). Millivolt signals from analyzers and pressure transducers were also recorded on this paper but require a special linear scale for interpretation, as discussed below under "calibration."

TABLE V

Calibrations


All calibrations were made directly on the recorder without reference to intermediate dials and gauges.

Recorder  
Point no.

- 1 Canister pressure drop was calibrated using a water manometer connected in parallel with the "DP" cell (delta pressure). The bypass valve was varied to produce a recorded pressure drop signal while water manometer readings were manually recorded. (See Figure 36). Accuracy was estimated as  $\pm 1$  in. H<sub>2</sub>O.
- 2 LIRA infrared analyzer. This unit was calibrated at least once every 8-12 hours with 1% and 0% span gas. Initial calibration included a midrange calibration gas, and resulted in Figure 37. Accuracy was estimated as  $\pm 0.1$  mm CO<sub>2</sub>.
- 5 Canister coolant inlet. Copper-constantan thermocouple, not calibrated, but there was agreement with #11 in no load condition,  $\pm 1^\circ\text{F}$ .
- 6 Air inlet temperature. Copper-constantan thermocouple calibrated with a thermometer in the thermowell  $\pm 0.5^\circ\text{F}$ .
- 9 Inlet LIRA. See point #2 above.
- 10 Dew point condenser coolant inlet. Copper-constantan thermocouples cross checked with thermowell in coolant outlet  $\pm 1/2^\circ\text{F}$ . (Flow was massive.)
- 11 Canister coolant outlet. Copper-constantan thermocouple, not calibrated but checked with #5 in no load condition  $\pm 1^\circ\text{F}$ .
- 13 Cambridge 880 Hygrometer. The direct readout dial was calibrated on the rig by running in the bypass mode, reducing the flow until dew point would not decrease further, i.e., until the temperature leaving the dew point condenser was presumably equal to the condenser coolant temperature. Adequate humidification prior to this condenser was assured by noting that the dew point leaving the humidifier was higher by at least a few degrees than that leaving the dew point condenser. From this single point calibration a dial correction was obtained ( $\pm 1^\circ\text{F}$ ) which was applied throughout the entire range. Final calibration was made by noting dial readings and recorded chart readings during a run, and plotting as in Figure 38.



LARGE SCALE TESTS  
CANISTER PRESSURE DROP CALIBRATION  
TRACE NO. 1 - BROWN



LARGE SCALE TESTS  
P<sub>CO2</sub> CALIBRATION

CR-115568  
SVHSER-6040





FIGURE 37

LARGE SCALE TESTS  
DEW POINT CALIBRATION  
TRACE NO. 13 - BROWN



Hamilton  
Standard

U  
A<sup>®</sup> DIVISION OF UNITED AIRCRAFT CORPORATION

LARGE SCALE TESTS  
HIGH VACUUM PRESSURE GAUGE CALIBRATION  
TRACE NO. 14 - RED

CR-115568  
SVHSER-6040




FIGURE 39

- 14 Canister vacuum (Microns). A Hastings thermocouple type vacuum sensor was wired into the recorder using the voltage applied to the local meter readout. A calibration curve (Figure 39) was made by noting recorded signals and meter readings. No direct calibration was made, but a general correspondence with similar gauges associated with the high vacuum system was noted.
- 23 Loop pressure. The zero pressure reference DP cell<sup>1</sup> recorded readout was calibrated by reference to a Wallace and Tiernan zero reference<sup>1</sup>  $\pm 0.1$  psia (Figure 40).
- 24 Loop flow. Pressure drop across a venturi type flowmeter was measured with a DP cell and recorded. A water manometer was connected in parallel and the flow varied over the range of interest, noting recorder readings and manometer readings. Manometer readings were converted to flow (cfm) using charts derived from manufacturer's data, and plotted as Figure 41, which was used to read flows from the recorder.

As a cross check a dry test meter (gas meter type) was connected to the outlet flow and the inlet opened to atmospheric air. Flows measured in this manner are also shown in Figure 41.

## LARGE SCALE TESTS

### Objectives

The objectives of the large scale tests were:

- To establish the capacity of the HS-C bed for water vapor and CO<sub>2</sub> at full scale (4-man system);
- To establish the degradation, if any, to be expected of the HS-C material after 7 days continuous operation. This is a rough simulation of the 7-day shuttle mission;
- To explore the effect of several operating parameters on HS-C performance;
- To provide data for the design development tasks and for verification of the mathematical model of HS-C performance.

<sup>1</sup>one side permanently evacuated

LARGE SCALE TESTS  
RIG PRESSURE CALIBRATION  
TRACE NO. 23 - BLUE

CR-115568  
SVHSER-6040




FIGURE 40

LARGE SCALE TESTS  
AIR FLOW CALIBRATION  
TRACE NO. 24 - BLACK

CR-115568  
SVISER-6040




FIGURE 41

### Experimental Method

Three separate series of tests were run according to the two test plans presented as Appendix E.

Series I used 8.84 pounds of 24-28 mesh HS-C and fulfilled the objectives of the large scale tests. Two hundred and nineteen hours of cyclic operation were accumulated without degradation including 7 continuous days (168 hours). Planned parametric test conditions were run, and complete data compiled. At nominal conditions (but with 5 mm CO<sub>2</sub> partial pressure, see below, page E-14) a CO<sub>2</sub> capacity of 2.0% by weight was indicated if a 90 minute desorption time was used.

Series II used a half bed (4.40 lbs.) of 24-28 mesh HS-C, thus decreasing the bed thickness from 3.0 to 1.5 inches to reduce the desorption time required for a 2.0% CO<sub>2</sub> adsorption capacity. Twenty-six hours of test were accumulated, and a CO<sub>2</sub> capacity of 1.9% by weight was achieved with a 40 minute desorption.

Series III also used a half bed of HS-C material, but smaller mesh size HS-C was used (30-40 mesh). A capacity of 2.0% CO<sub>2</sub> by weight was achieved with a 40 minute cycle, showing the enhancement of capacity made possible by the smaller particles of HS-C.

Water capacities for HS-C varied with the dew point, but better than 4.0% by weight was achieved with each HS-C material.

### Data Summary

Data summary sheets made during test Series I, II and III are reproduced in Appendix F.

### Calculations


The data recorded on the data sheets was complete except for water capacity. This was calculated by integration of the outlet dew point curve from the recorder chart. Figures 42 and 43 show the procedure.

First the recorder chart curve was transferred to graph paper with a point every 5 minutes. This curve was replotted as P<sub>H<sub>2</sub>O</sub> versus time (Figure 42) with the aid of the calibration curve (Figure 38) using dew point conversions from the steam tables. The feed P<sub>H<sub>2</sub>O</sub> was obtained from the trace just before adsorption and extended through the adsorption time. The removal efficiency for H<sub>2</sub>O was then obtained by graphical



LARGE SCALE PARAMETRIC TESTS  
HUMIDITY CALCULATIONS DATA CYCLE 70  
(RECORDER READING)

CR-115568  
SVHSER-6040



LARGE SCALE PARAMETRIC TESTS  
HUMIDITY CALCULATIONS - DATA - CYCLE 70




FIGURE 43

integration and the capacity for water vapor then calculated as shown in Figure 43.

### Parametric Data Discussion

Appendix F presents log sheets for Run Series I, II, and III. Figures 11 through 17 are plots developed from this parametric data. These plots are discussed below in detail.

#### Desorption Time, Temperature, and Vacuum

Figures 16 and 17 show the effect on capacity of varying desorption time at CO<sub>2</sub> partial pressures of 5 and 3 mmHg during run series I which employed a 3 in. thick bed of 24-28 mesh HS-C. At 5 mmHg, the shape of the curve is similar but the capacities are about 15% higher. But even the longer desorption times (90-160 min.) leave some of the bed incompletely desorbed, as is shown by the 2.55% CO<sub>2</sub> capacity available after an overnight desorption (1000 min.) at room temperature. Incomplete desorption results from inadequate desorption temperature, too short a desorption time, or too high a desorption pressure -- effects which interact in important ways not investigated in this study.

Desorption temperature.- This parameter is believed most important at the shorter desorption times, although the effect of adsorption temperature masks the effect when adsorption and desorption are at a single temperature (see Figure 12). At 1000 minutes, Figure 16 shows that a desorption temperature of 125°F resulted in only 10% additional capacity, indicating that desorption is reasonably complete after 1000 minutes at normal (80°F) desorption temperature.

Desorption time.- This parameter is very important, because time is required for the CO<sub>2</sub> and H<sub>2</sub>O to desorb and diffuse out of the HS-C particle and then for the desorbed gases to work their way through the bed to the simulated space vacuum at either side of the bed.

Desorption pressure.- Figure 17 shows 3 mm CO<sub>2</sub> data in detail including some runs with higher desorption pressures at 45 minutes desorption time. The 3 inch bed was normally desorbed through 3 inch gate valves on each side of the bed. When one was left shut, the desorption performance was decreased, simulating an equal weight of bed 6 inches thick when double end desorbed. Desorbing only through a 3/8 inch I.D. 1/2 inch plastic line (used normally for ullage dump) decreased the performance still further.

Decreasing the bed thickness to 1.5 inches with double-end desorption improved capacity about 5% (Run Series II). Decreasing the particle size from 24-28 mesh to 30-40 mesh in the 1.5 inch bed (Run Series III) further improved performance, giving a 15% increase over the base condition, with a 2% CO<sub>2</sub> capacity at 40 minutes desorption.

Even though powerful vacuum pumps were employed, desorption pressure was not instantaneously lowered to the 10-20 microns characteristic for termination of a normal desorption. Figure 44 shows a plot of the desorption pressure traces from a typical run. Performance in an actual spacecraft would be better, provided an adequately large line to space vacuum were provided.

### Design for Desorption

The optimal bed configuration will depend on packaging considerations. The best performing bed will be the thinnest bed but a 1-1/2 inch bed is probably heavier overall than a 3 inch bed due to structural requirements.

A thin bed gives a low pressure drop during adsorption, which is also important since the HS-C is a fine material relative to conventional sorbents such as molecular sieve, charcoal, or silica gel. The pressure drop during adsorption is shown in Figure 45 for the bed configurations of each run series. The pressure drop of a 3 inch bed is not prohibitively high, about the same as the usual molecular sieve plus silica gel bed and associated valving.

### Inlet CO<sub>2</sub> Concentration

Figure 14 shows the change in CO<sub>2</sub> and water capacity of the HS-C bed with changing CO<sub>2</sub> partial pressure. When the P<sub>CO<sub>2</sub></sub> is lowered from 3 to 1.5 mmHg the capacity drops about 20%. An increase to 5 mmHg causes a rise of about 10%. A further rise would have little effect because at this P<sub>CO<sub>2</sub></sub> the rate of adsorption is becoming very much greater than the rate of spontaneous desorption, allowing each reactive site to be occupied almost all the time. Capacity is then independent of adsorption P<sub>CO<sub>2</sub></sub>, depending only on the number of reaction sites available.

Bed temperature. - Figure 12 shows how little bed temperature affects cyclic performance for CO<sub>2</sub>. There is nonetheless an important effect due to temperature on both adsorption and desorption, with adsorption capacity increasing with decreasing temperature while desorption difficulty increases to compensate. Close examination of the performance data when the canister temperature was adjusted downward from 92°F to 67°F (cycle I-58 and 59) shows a capacity of 1.92% (0.17 lbs.), 20% above the normal cyclic capacity

because cycle 59 had a high temperature desorb followed by a low temperature adsorb. Water capacity shows a significant dependence on bed temperature similar to that of the small scale tests, with a reduction of 50% in water capacity when the temperature is increased from 66°F to 92°F.

Inlet Air Temperature.- Air inlet temperature had no effect on performance because the bed temperature is fixed by the coolant temperature which was held constant. (See Figure 11)

Inlet Air Flow.- Increased air flow raised the CO<sub>2</sub> cyclic capacity only slightly because the flow was great enough at each test condition to saturate the bed. Lower flows presumably would show a decreased capacity (dashed line on Figure 15). This effect also shows that gas phase mass transfer does not limit the mass transfer.

The water in the air flow through the bed was not sufficient to saturate the bed at all conditions. Therefore the more the flow, the greater the cyclic capacity.


Inlet Dew Point.- Figure 13 shows the effect of humidity on water and CO<sub>2</sub> adsorption capacity. The effects are similar to those of the small scale tests (Figure 5). CO<sub>2</sub> capacity is almost unaffected, decreasing slightly at the lower dew points. Water capacity increases rapidly with increasing dew points, and when the inlet flow is high it increases most rapidly.

The water capacity of the bed is limited by the water made available to the bed and by the adsorption time, for the bed is seldom "broken through." The level of the inlet partial pressure driving force is also very important.

Test Data Verification.- CO<sub>2</sub> Capacity: The capacity for CO<sub>2</sub> was determined by direct measurement of the CO<sub>2</sub> added by loss from a weighed gas bottle. The accuracy of the beam balance used was established by trial for small increments (< 2 pounds), using known weights, to be ±.0025 pounds, i.e., a weight could be measured repeatably to the nearest 0.005 lbs. Since operator judgment was involved, all operators were confirmed to be equally accurate with the balance.


Since the CO<sub>2</sub> capacity is measured by weight loss from the CO<sub>2</sub> supply cylinder, a leak from that system or even the test apparatus would have raised the apparent capacity. Such leaks were carefully eliminated prior to data acquisition. Had the problem occurred during operation it would have been quickly noted by the consumption of CO<sub>2</sub> during the desorption cycle when the test canister was by-passed. There was never such consumption and the CO<sub>2</sub> control system remained under closed loop composition control throughout the testing. For an important capacity measurement, as for instance cycles 190-194 of Run Series III, the weight loss was taken over several cycles, in this case 0.555 lbs over six cycles, giving a final capacity of 0.0925





HS-C LARGE SCALE PARAMETRIC TESTS  
DESORPTION PRESSURE VS. TIME

FIGURE 44



$\pm 0.0005$  lbs/cycle. The results on this series were confirmed by an analysis of the infrared analyzer inlet and outlet traces for cycle 190 using a technique analogous to that used for water capacity (Figures 42 and 43). For cycle 190 the removal efficiency was found to be 4.16%, giving a cyclic capacity of 0.085 lbs. This is within 10% of the 0.0925 lb capacity determined by direct weight, a very satisfactory agreement because the difference between the two infrared analyzers was small for all but the first few minutes of the adsorption cycle.

**Water Capacity:** Water capacity could not be determined by direct weight because the test apparatus had a large and variable holdup of liquid water. All measurements were therefore made by interpretation of the hygrometer traces as in Figures 42 and 43. Since only the outlet reading was taken (the dew point of the bypassed stream is automatically presented during a canister desorption and is taken as the inlet composition) accuracy requires a constant inlet dew point during the adsorption. The test apparatus provides this, and it was confirmed by recording the actual inlet dew point during a test run.



HS-C SYSTEM DESIGN CONCEPT DEVELOPMENT

The potential for growth in mission duration is evaluated for the regenerable desiccant system. The schematic used for this evaluation was selected on the basis of simplicity and ease of maintenance. It represents a minimum in terms of vehicle interface requirements. The objective of this phase was to develop and trade-off HS-C system design concepts applicable to the Space Shuttle. Experimental data from the large scale tests were combined with the latest shuttle specifications to define system constraints, and describe a realistic trade study.

## CONCEPT DESIGN

Figure 47 presents a schematic of that portion of the total Space Shuttle system affected by this study. The schematic shows dual cabin and radiator cooling loops connected by an interface heat exchanger. The heat rejection loop contains electronic equipment cold plates, fuel cell, circulating pumps, a radiator and auxiliary heat sinks. The cabin coolant loop contains electronic cold plates, circulating pumps and associated heat exchangers. Carbon dioxide, humidity and temperature control equipment are shown within the cabin area.

The design requirements and range of conditions considered in this evaluation are shown in Table VI. HS-C parametric data from Run Series I utilized the system sizing is summarized in Figure 46.

The procedures used to minimize the system weight for each candidate concept are shown in Table VII. Included in the optimization were the radiator, coolant pumps and interface heat exchanger, as well as the CO<sub>2</sub>, humidity and temperature control and ventilation portions of the subsystem.

At a constant radiator outlet temperature, there is an optimum flow rate. As the heat rejection loop flow is lowered, the radiator size and weight decreases as radiating temperature increases. The cabin heat exchanger weight increases as the heat rejection loop flow decreases because the "log-mean-temperature-difference" in the heat exchanger has decreased. As the radiator outlet temperature is lowered the radiator gets larger, but the cabin heat exchanger gets smaller.

The HS-C sorbent system schematic is shown in Figure 18. Figure 48 illustrates the best competitive system LiOH CO<sub>2</sub> condenser. Design trade

## DESIGN REQUIREMENTS

## CREW DATA

Crew Size (men)	2 - 14
Total Metabolic Heat Generation (per man)	540 Btu/hr peak
Sensible Metabolic Heat Generation (per man) (@ 65°F design point)	300 Btu/hr peak
Latent Metabolic Heat Generation (per man)	240 Btu/hr peak
Carbon Dioxide Production Rate average	2.2 lb/man-day
maximum	3.8 lb/man-day

## PRESSURIZED COMPARTMENT DATA

Total Pressure	14.7 psia
Oxygen Partial Pressure	3.1 psia
Atmosphere Diluent Gas	Nitrogen
Carbon Dioxide Partial Pressure Levels	
Nominal	5.0 mm Hg
Maximum normal	7.6 mm Hg
Maximum with single failure	10.0 mm Hg
Maximum emergency (2 hour duration)	15.0 mm Hg
Cabin Temperature (Design Point 65°F)	65° to 75°F
Cabin Humidity (dew point temp.)	40° to 57°F
Design point -65°F cabin temperature (12°F less than dry bulb temp.)	53°F maximum
Cabin Volume (4 men)	1000 ft <sup>3</sup>
Minimum Ventilation Flow Rate (see ventilation section)	400 cfm
Trace Contaminant Control Penalty (charcoal only)	0.167 lb/man-day

## VEHICLE DATA

Cabin Wall Heat Load (Except for reentry)	1700 Btu/hr
Air Cooled Electronics Heat Load (less EC/LSS load)	3400 Btu/hr
Cold Plate Cooled Electronics Heat Load (cabin)	8800 Btu/hr
Fuel Cell Heat Load	30,000 Btu/hr
Power Penalty	
Fixed Weight	286 lb/kW
Expendables	1.96 lb/kW-hr
Coolant	
Cabin cooling loop	Water
Radiator cooling loop	Freon-21

TABLE VI

### Radiator Weight Penalty (WT)

$$\begin{aligned}
 WT &= A \times W \times C_p \times (B-C) \sim \text{lbs.} \\
 A &= F \times T_s / K \sim \text{lbs-hr-}^\circ\text{R/Btu} \\
 T_s &= \text{Equilibrium surface temp } \sim ^\circ\text{R} \\
 K &= \text{Radiator Influx } \sim \text{Btu/hr-ft}^2 \\
 W &= \text{Radiator coolant flow rate } \sim \text{lbs/hr} \\
 C_p &\sim \text{Radiator coolant flow specific heat } \sim \text{Btu/lb-}^\circ\text{R} \\
 B &= \frac{1}{4} \ln \left[ \frac{\left( \frac{TRO}{T_s} + 1 \right) \left( \frac{TRI}{T_s} - 1 \right)}{\left( \frac{TRO}{T_s} - 1 \right) \left( \frac{TRI}{T_s} + 1 \right)} \right] \\
 C &= \frac{1}{2} \left[ \tan^{-1} \left( \frac{TRI}{T_s} \right) - \tan^{-1} \left( \frac{TRO}{T_s} \right) \right] \\
 TRI &\sim \text{Radiator Inlet Temp } \sim ^\circ\text{R} \\
 TRO &\sim \text{Radiator Outlet Temp } \sim ^\circ\text{R} \\
 F &= \text{lbs/ft}^2 / \text{Fin efficiency } \sim \text{lbs/ft}^2
 \end{aligned}$$

### For Nominal Conditions

$$\begin{aligned}
 A &= 7.05 \text{ lbs-hr-}^\circ\text{R/Btu} \\
 T_s &= 490^\circ\text{R}
 \end{aligned}$$

TABLE VI  
(CONTINUED)

## OPTIMIZATION PROCEDURE

1. Assume heat rejection loop flow rate. (freon)
2. Assume radiator outlet temperature.
3. Calculate interface heat exchanger heat rejection loop inlet temperature (size sublimator, if required).
4. Assume interface heat exchanger water outlet temperature.
5. Size/optimize CO<sub>2</sub> and water removal components.
6. Optimize cabin heat exchanger to find optimum air flow and outlet air temperature.
7. Calculate water loop temperatures and pump power and weight.
8. Size interface heat exchanger.
9. Calculate heat rejection loop temperatures and pump power and weight.
10. Size radiator (use cryogenics if area exceeds 900 ft<sup>2</sup>).
11. Calculate total system equivalent weight.
12. Repeat steps 4 through 11 until optimum temperature is found.
13. Repeat steps 3 through 12 until optimum radiator outlet temperature is found.
14. Repeat steps 1 through 13 until optimum flow rate is found.

TABLE VII






FIGURE 46



COOLANT LOOP SCHEMATIC

FIGURE 47

SCHEMATIC OF COMPETITIVE SYSTEM LiOH CONDENSER  
USED FOR TRADE STUDY



ORIGINAL PAGE IS  
OF POOR QUALITY

FIGURE 48

results are shown in Figure 19 and 20. System total equivalent weight, is plotted as functions of crew size and a two-day emergency period is included in addition to the mission length. Since the water and CO<sub>2</sub> removal capability depends on the size of the HS-C bed the CO<sub>2</sub> and water generation rates determine the bed size. If the latent (water) load in the cabin is high, the large HS-C bed needed to control water will easily handle the CO<sub>2</sub> requirement and the P<sub>CO2</sub> will fall below the nominal level. Conversely when CO<sub>2</sub> sizes the bed the cabin P<sub>H2O</sub> will fall below nominal and possibly out of specification. Fortunately this situation can be avoided by lowering air flow through the canister (See Figure 46).

For the current shuttle requirements, computer results show that water removal alone determines the HS-C system size. The LiOH condenser subsystem, however, is sized by CO<sub>2</sub> removal. For a six-man seven-day, two-day emergency mission, the total equivalent weight for the HS-C subsystem is 1890.7 pounds. The equivalent weight for a LiOH condenser subsystem is 2091.4 pounds. The HS-C subsystem maintains a lower dew point, requires less flow rate, and utilizes a smaller radiator heat sink.



Hamilton  
Standard

U  
DIVISION OF UNITED AIRCRAFT CORPORATION  
A®

CR-115568  
SVHSER-6040

APPENDIX A

PLAN OF TEST & TEST DATA

HS-C STRUCTURAL TESTS

PRECEDING PAGE BLANK NOT FILMED

TEST NO. \_\_\_\_\_

HAMILTON STANDARD

CR-115568  
SVHSER-6040PLAN OF TEST

JOB: \_\_\_\_\_

PLAN PREPARED BY: H. KolnsbergPROJECT & ORDER: HS-C Structural Tests

APPROVED BY: \_\_\_\_\_

INSTRUCTION: \_\_\_\_\_

TEST ENGINEER: \_\_\_\_\_

TIME PERIOD: \_\_\_\_\_ TO \_\_\_\_\_

1. WHAT IS ITEM BEING TESTED?
2. WHY IS TEST BEING RUN? WHAT WILL RESULTS SHOW OR BE USED FOR?
3. DESCRIBE TEST SET UP INCLUDING INSTRUMENTATION. ATTACH SKETCH OF INSTALLATION.
4. ITEMIZE RUNS TO BE MADE GIVING LENGTH OF EACH AND READINGS TO BE TAKEN.
5. SPECIAL INSTRUCTIONS: SAFETY PRECAUTIONS FOR OPERATORS AND HANDLING EQUIPMENT. OBSERVATIONS BY SIGHT, FEEL, OR HEARING. LIST POINTS OF OBSERVATION WHICH MIGHT CONTRIBUTE TO ANALYSIS OF (A) PERFORMANCE OF UNITS, (B) INCIPIENT TROUBLE BEFORE IT OCCURS, AND (C) CAUSE OF FAILURE.
6. HOW WILL DATA BE USED OR FINALLY PRESENTED? GIVE SAMPLE PLOT, CURVE, OR TABULATION AS IT WILL BE FINALLY PRESENTED.

NUMBER ENTRY AS LISTED ABOVE AND DESCRIBE BELOW1.0 Description of Test ItemThe test item is virgin HS-C CO<sub>2</sub> adsorbing desiccant.2.0 Test Objective

The objective of these tests is to demonstrate that the material will not be significantly structurally damaged or operationally degraded

under space flight conditions. The vibration levels used are those for lunar launch and boost used in testing IM hardware.

3.0 Description of Test Set-up3.1 Test Facility

The vibration test described here n will be conducted in the Hamilton Standard Vibration facility, Rig number 26 . All other tests will be conducted in the Hamilton Standard Advanced Engineering Laboratory.

3.2 Test Set-up

The adsorption test set up will be as shown in Figure 1.

The pressure drop test set-up will be as shown in Figure 2.

The vibration test set-up will be as shown in Figure 3.

### 3.3 Test Sequence

In order to minimize the amount of material required for testing, the following sequence of testing will be followed:

Configuration	- pre-vibration sample (1 ml)
Apparent density	- pre-vibration sample (100 ml)
*Adsorption	- pre-vibration sample (5 ml)
Pressure Drop	- pre-vibration canister (6 lb)
Vibration test	- canister
Pressure drop	- post-vibration canister
*Adsorption	- post-vibration sample (5 ml)
Configuration	- post-vibration sample (1 ml)
Apparent density	- post-vibration sample (100 ml)

\* Adsorption tests may be run simultaneously.

### 4.0 Test Procedures

#### 4.1 Configuration Test

Extract a 1 ml (or a minimum of 100 beads) sample at random from the test volume.

Spread sample to single bead thickness and examine under at least 10X magnification.

Record number and percent of beads with irregular surfaces. Note type (raised bumps, chips, cracks) of irregularities.

#### 4.2 Apparent Density - (per ASTM C136-46)

Extract a sample of approximately 50 gm from the test volume and weigh to the nearest 0.1 gm. Record weight. Transfer sample to a clean, dry 500 ml glass graduated cylinder. Incline and rotate the cylinder until the sample flows freely. Level the sample in the cylinder by tipping the vertically held cylinder back and forth without tapping or jarring. Determine and record sample volume in ml.

The apparent density is equal to the sample weight divided by the sample volume.

#### 4.3 Adsorption

Extract a sample of approximately 5 ml from the test volume and install in the laboratory test rig. Set the following test conditions:

$P_{CO_2}$  - 3 mm Hg  
Air flow - 500 ml/min  
 $P_{total}$  - 28 in Hg  
Air inlet dew point - 52°F  
Bed temperature - 75°F  
 $\frac{1}{P}$  Cycle time - 45 min  
 $P_{desorb}$  - 50 micron max.

#### 4.3 Adsorption (continued)

Run test for three adsorb-desorb cycles. Report capacity data on sorbent evaluator calculation sheet.

#### 4.4 Pressure drop

Install approximately 6 pounds of the sample volume in an SV742060 (IM 122) cartridge. Fill cartridge to within 1/8 inch of the cartridge cover cushion disc. Do not tap or jar cartridge during filling.

Install filled cartridge in SV748770 (IM 110) canister and install cartridge in test rig as shown in Figure 2.

Adjust flow of nitrogen to 25 cfm or to a pressure drop of 5 inches  $H_2O$  across the canister, whichever occurs first as the nitrogen flow is increased. Record nitrogen flow and canister P. Repeat fan 20 cfm (or 4 inches  $H_2O$   $\Delta P$ ) and 30 cfm (or 6 inches  $H_2O$   $\Delta P$ ).

#### 4.5 Vibration Test

Install the HS-C loaded cartridge (Paragraph 4.4) in the test structure as shown in Figure 3.

Vibrate the test item such that the vibration inputs at either control accelerometer location are at the following levels:

X-axis random vibration - 1 minute 0 12.4 g RMS

20	- 265 Hz	.005 $g^2/Hz$
265	- 750 Hz	+12 db/octave
750	- 850 Hz	.3 $g^2/Hz$
850	- 200 Hz	-12 db/octave

Sinusoidal vibration - 3 octave/min

5	- 14 Hz	.2 in D.A.
14	- 100 Hz	2G
100	- 14 Hz	2G
14	- 5 Hz	.2 in D.A.

Filter the control accelerometer during each test. Filter other accelerometer outputs during playback. Plot control and response data to slow filtered g's versus frequency for sine data and  $g^2/Hz$  versus frequency for random data.

#### 5.0 Special Instructions

Not Applicable

#### 6.0 Data Presentation

Tabulate the test results to show % of beads with irregular surfaces, apparent density in gm/ml,  $CO_2$  adsorption in % by weight and gms/liter, and pressure

6.0 Data Presentation (continued)

drop across the canister in in. H<sub>2</sub>O for each of three gas flow rates for samples taken before and after the vibration test.

Figure 1

Lab Rig Schematic (Adsorption Test)




Figure 2

Pressure Drop Test Set Up





Figure 3

Vibration Test Set Up



When location "A" is used as the control accelerometer, location "B" shall be used for response data and vice versa.

Cartridge Installation Procedure

1. Back off adjusting screws to clear canister.
2. Position .014 shim between screws and canister.
3. Adjust each screw until shim is snug between screw and canister.
4. Back off screws only enough to remove shims. Turn each screw clockwise  $180^\circ +0^\circ, -15^\circ$ .

**Hamilton Standard** DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT 06096

**U  
A**

SPACE & LIFE SYSTEMS LABORATORY

LOG OF TEST

TYPE OF TEST

HS-C CAN TET PRESSURE DROP

TEST ENGINEER

H. KOLNBERG

NAME OF RIG

88

PROJECT & ENG. ORDER NO.

SHEET

OF

DATE

11/22/71

TEST PLAN NO.

MODEL NO.

PART NO.

CR-115568

SERIAL NO.

SVHSER-6040

OPERATORS

DATE	TIME	VENTURI INLET	VENTURI ΔP	$\frac{\Delta P}{P}$	AIR FLOW	CAN ΔP														
—	—	PSIA	W.H <sub>2</sub> O	—	CFM	W.H <sub>2</sub> O														
11/22	1422	14.92	11.7	.028	30.5	1.45	}	BEFORE VIBRATION TEST												
	1455	14.82	8.2	.0195	25.5	1.05														
	1508	14.72	5.25	.0128	20.6	0.70														
	1600	14.94	11.4	.0273	30.1	1.40														
	1605	14.83	8.1	.0192	25.1	1.00														
	1610	14.74	5.4	.0129	20.7	0.7														
11/24	0825	15.14	4.8	.0119	20.0	0.65	}	AFTER VIBRATION TEST												
	0830	15.23	7.6	.0182	24.5	0.95														
	0835	15.36	11.4	.0273	30.1	1.40														
	0840	15.40	12.7	.030	31.5	1.52														
	0845	15.37	11.8	.0285	30.7	1.44														
	0850	15.20	6.2	.0149	22.1	0.80														
	0855	15.12	4.7	.0113	19.5	0.63														

REMARKS:

3387



Hamilito. Standard DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT 06096

U  
A

SPACE & LIFE SYSTEMS LABORATORY

LOG OF TEST

HS-C COUPLER ATION & DENSITY

TEST ENGINEER  
H. KOLNSBERG

NAME OF RIG

PROJECT & ENG. ORDER NO.

DATE 124111

TEST PLAN NO.

MODEL NO.

PART NO.

SERIAL NO.

OPERATORS

CR-115568  
SVHSFR-6040

CONFIGURATION - 20X MAGNIFICATION

BEADS  
IN

IRREG-  
ULAR

%

SAMPLE

BEADS

IRREG-  
ULAR

~370

5

1.35

- PRE-VIBRATION SAMPLE - ALL IRREGULAR BEADS HEMISPHERICAL

~380

4

1.05

- POST-VIBRATION SAMPLE - ALL IRREGULAR BEADS HEMISPHERICAL

APPARENT DENSITY

SAMPLE  
WEIGHT

SAMPLE  
VOLUME

A.D.

gms

ML

gm/ml

50.6

126

4.02

- PRE-VIBRATION SAMPLE

51.5

128

4.02

- POST-VIBRATION SAMPLE

REMARKS:

3386

Hamilton  
Standard

U  
A<sub>0</sub>

SVHSER-6040

Memo File Code SSD-CO2-1189

Memorandum to: H. KOLNSBERG

Page 1 of       

Program CO<sub>2</sub> DESICCANT

Test Item(s) HS-C CO<sub>2</sub> ABSORBING  
DESICCANT

Date of Test 11/23/71

Serial No.(s)       

Name of Test DVT VIBRATION

Specification TEST PLAN

Subject:

TYPE HS-C CO<sub>2</sub> ABSORBING DESICCANT WAS  
LOADED IN A LM 122 DVT CARTRIDGE AND  
VIBRATED ON FIXTURE SVSK 79541. ONLY -  
ONE AXIS, (X) VERTICAL, WAS TO BE TESTED WITH  
CONTROL ON THE SECONDARY FIXTURE'S TOP  
BRACKET.

THERE WAS NO UNUSUAL HAPPENING AND  
NO GROSS DUSTING.

INSTRUMENTATION INCLUDED ACCELEROMETERS  
AT CONTROL, CROSSAXES NEAR CONTROL (ON TOP  
BRACKET) AND PRIMARY DIRECTION ON THE  
BOTTOM FIXTURE CUP.

THIS REPORT INCLUDES CONTROL AND RESPONSE  
CURVES FROM ONE SINE AND ONE RANDOM TEST.

Test Engineer T. GEIER

Signature T. Geier

Date of Report 12/15/71

Approved Paul Malachuk

Date Dec 15, 1971

HAMILTON  
STANDARD



Memo File Code SSD-COZ-1189

Page No 2 of       

-----  
OPERATOR LOG # 1290, TAPE LOGS, AND  
DATA REDUCTION LOGS.

THE MAGNETIC TAPE DATA WILL BE ERASED  
IN 90 DAYS UNLESS A SPECIFIC REQUEST  
IS MADE TO THE UNDERSIGNED.

Hamilton  
Standard

U  
No. DIVISION OF UNITED AIRCRAFT CORPORATION

SVHSR-6040

Memo No. SSD-CO2-1189

Page No. 1 of 1

Memorandum to: Structures Group

Date of Test: 11/23/71

Date of Memo: 12/8/71

Program: CO<sub>2</sub> DESICCANT

Type of Test: DVT VIB.

Test Item(s): H.S.C CO<sub>2</sub>  
ABSORBING DESICCANT

S/N: \_\_\_\_\_

Remarks:

REDUCED DATA FROM (1) SINE & (1) RANDOM

— (4) CURVES EACH

OPERATOR LOG 1290

TAPE LOGS & D.R. LOGS

TESTED IN LM 122 CARTRIDGE ON SVSK 79541

Fixture IN X AXIS ONLY (VERTICAL)

Operational Test Engineer \_\_\_\_\_

Date \_\_\_\_\_

Received - Date \_\_\_\_\_

TER No. \_\_\_\_\_

Return ☒ to T. GEIB

Action Taken - Date \_\_\_\_\_

Hamilton  
Standard

U  
A®  
DIVISION OF UNITED AIRCRAFT CORPORATION

HSF-1633.1 2/69

SINE VIBRATION TEST

A-12


RIG #26	OPERATOR P. Jackson	WITNESS —	WITNESS —	TEST NO. 2
TEST ENGINEER T. Geib	CHECKED BY T.G.	PROJECT CO <sub>2</sub> DESICCANT		DATE 11-23-71
				TIME 1755

PS ACCELERATION

0

2.1

PAGE NO.



INPUT LEVEL ±1.0	EXCIT. AXIS X
ACCEL S/N PB34	SENSING AXIS X
ACCEL SENSITIVITY — MV RMS	
2.333 GP	
COL	
GP	
FILTER 10 100 200 HZ B.W.	
FILTER CROSSOVER @ 70 700 HZ	
SWEEP RATE 3.0 OCT/MIN	
TAPEREEL NO. 012255	<input checked="" type="checkbox"/> LIVE FROM TAPE
COMPR. SPEED Var DB/SEC.	
CHG. @ ~ HZ TO DB/SEC.	
CHG. @ ~ HZ TO DB/SEC.	
NON OPERATING	<input checked="" type="checkbox"/> CONTROL
TEMP. 74 °F	<input type="checkbox"/> RESPONSE
LOCATION "A"	
SPECIAL CONDITIONS	
REPORT NO. CR-115568 SWISER-6040	

FREQ. RANGE & DIRECTION 5-210 Hz	ITEM HS-C-000	CODE —	SERIAL NO. —	SPEC. Hand Test	PARA. —	AMEND. —
ACTION SHEET NO. —	ATA NO. —	TYPE OF TEST DVT		NAME OF TEST Sine Scan		




Hamilton  
Standard

U  
A  
DIVISION OF UNITED AIRCRAFT CORPORATION

HSF-1633.1 2/69

SINE VIBRATION TEST

RIG # 26	OPERATOR P. Joduin	WITNESS	WITNESS	TEST NO. 4
TEST ENGINEER T. Geib	CHECKED BY T.G.	PROJECT CO <sub>2</sub> DESICCANT		DATE 11-23-71 TIME 1440



INPUT LEVEL ±2.0	EXCIT. AXIS 2
ACCEL S/N PB34	SENSING AXIS 2
ACCEL SENSITIVITY	
MV RMS	
2.333	GP
	COL
	GP
FILTER 10, 100 HZ B.W.	
FILTER CROSSOVER @ 70 HZ	
SWEEP RATE 3.0 OCT/MIN	
TAPER REEL NO. 012255	<input checked="" type="checkbox"/> LIVE <input type="checkbox"/> FROM TAPE
COMPR. SPEED Var DB/SEC.	
CHG. @ - HZ TO DB/SEC.	
CHG. @ - HZ TO DB/SEC.	
NON OPERATING	<input type="checkbox"/> CONTROL
TEMP. 74 °F	<input type="checkbox"/> RESPONSE
LOCATION "A"	
SPECIAL CONDITIONS	
REPORT NO. CR-115568 SMHSR-6040	

FREQ. RANGE & DIRECTION S-100-5 HZ	ITEM HS-C CO <sub>2</sub> DESIC.	CODE -	SERIAL NO. -	SPEC. TEST PLAN	PARA. -	AMEND. -
ACTION SHEET NO. -	ATA NO. -	TYPE OF TEST DUT		NAME OF TEST Sine Run		

1.0

0.1

PAGE NO.  
A-13

# SINE VIBRATION TEST


Standard A

TRACE NO.	TEST NO.
DATE	TIME
11-23-71	1440

OPERATOR	TEST ENGINEER	CHECKED BY	PROJECT
P.J.	T.G.	T.G.	CO <sub>2</sub> DESICCANT

INPUT LEVEL	EXCIT. AXIS
+ 2.0	X
ACCEL S/N	SENSING AXIS
PB 34	X
ACCEL SENSITIVITY	MV RMS
2.333	GP
	COL
	GP
FILTER	HZ B.W.
10	
FILTER Crossover	HZ
2	
TAPER REEL NO.	SWEEP RATE
012255	3.0 OCT/MIN
COMPR. SPEED	DB/SEC
VAR	
CHG @	HZ TO - DB/SEC
CHG @	HZ TO - DB/SEC
NON-OPERATING	CONTROL
TEMP. 74 °F	RESPONSE
LOCATION	
A	
TOP BRACKET	
SPECIAL CONDITIONS	

REPORT NO.
CR-115568
SVHSIR-6040



FREQ. RANGE & DIRECTION	ITEM	CODE	SERIAL NO.	TYPE OF TEST
5-100-5/1/2	HS-C DESIC			BVT
SPECIFICATION	PARA.	AMEND.	PHASE	NAME OF TEST
TEST PLAN				




Hamilton  
Standard

U  
A<sup>®</sup>

SINE VIBRATION TEST

HSF 1633 A 2/69

RIG 26	OPERATOR P.J.	PLOTTED BY P.J.	TRACE NO. -	TEST NO. 4
TEST ENGINEER T.G.	CHECKED BY T.G.	PROJECT CO <sub>2</sub> DESICCANT	DATE 11-23-71	TIME 1440



INPUT LEVEL ± 2.0	EXCIT. AXIS X
ACCEL S/N PB36	SENSING AXIS X
ACCEL SENSITIVITY MV RMS 2489	
GP COL GP	
FILTER 10 HZ 3.W.	
FILTER CROSSOVER @ HZ	
TAPER REEL NO. 012263	SWEEP RATE 3.0 OCT/MIN
COMPR. SPEED VAR. DB/SEC	
CHG@ HZ TO DB/SEC	
CHG@ HZ TO DB/SEC	
NON-OPERATING TEMP. 74 °F	<input type="checkbox"/> CONTROL <input checked="" type="checkbox"/> RESPONSE
LOCATION "B"	
BOTTOM BRACKET	
SPECIAL CONDITIONS	

FREQ. RANGE & DIRECTION 5-100-5 Hz	ITEM HS-C DESIC	CODE -	SERIAL NO. -	TYPE OF TEST DVT
SPECIFICATION TEST PLAN	PARA. -	AMEND. -	PHASE -	NAME OF TEST -

REPORT NO.  
CR-115568  
SVHSR-6040




SINE VIBRATION TEST

Standard

DATE

FIG. 26	OPERATOR T.J.	TEST NO. 4
TEST ENGINEER T.G.	CHECKED BY T.G.	DATE 11-23-71
CO <sub>2</sub> DESICCANT		TIME 1440



INPUT LEVEL EXCIT. AXIS ± 20 g X		TRACE NO.	
ACCEL S/N NB82		TEST NO. 4	
ACCEL SENSITIVITY B		DATE 11-23-71	
MV RMS		TIME 1440	
2.848			
GP			
COL			
GP			
FILTER 10		HZ B.W.	
FILTER Crossover		HZ	
TAPEREEL NO. SWEEP RATE			
012253 3.0 OCT/MIN			
COMPR. SPEED VAR		DB/SEC	
CHG @ 1 HZ TO 1 DB/SEC			
CHG @ 1 HZ TO 1 DB/SEC			
NON-OPERATING		CONTROL	
TEMP. 74 °F		RESPONSE	
LOCATION B			
CROSSAXIS TOP BRACKET			
SPECIAL CONDITIONS			

REPORT NO.  
CR-115568  
SVHSER-6040

FREQ. RANGE & DIRECTION 5-100-5 HZ	ITEM 15-C DESICCANT	SERIAL NO.	TYPE OF TEST DVT
SPECIFICATION TEST PLAN	AMEND.	PHASE	NAME OF TEST

Hamilton  
Standard


DIVISION OF UNITED AIRCRAFT CORPORATION

U  
A<sup>®</sup>

## SINE VIBRATION TEST

RIG 26	OPERATOR P.J.	PLOTTED BY P.J.	TRACE NO. 4	TEST NO. 4
TEST ENGINEER T.G.	CHECKED BY T.G.	PROJECT CO <sub>2</sub> DESICCANT	DATE 11-23-71	TIME 1440

G'S ACCELERATION



INPUT LEVEL ± 2.0	EXCIT. AXIS X
ACCEL S/N NB 90	SENSING AXIS X
ACCEL SENSITIVITY MV RMS 2.637	
GP COL GP	
FILTER 10 HZ B.W.	
FILTER CROSSOVER @ — HZ	
TAPEREEL NO. SWEEP RATE 01225 3.0 OCT/MIN	
COMPR. SPEED VAR DB/SEC	
CHG@ — HZ TO — DB/SEC	
CHG@ — HZ TO — DB/SEC	
NON-OPERATING TEMP. 74°F	<input type="checkbox"/> CONTROL <input checked="" type="checkbox"/> RESPONSE
LOCATION (CROSSAXIS) TOP BRACKET	
SPECIAL CONDITIONS	

FREQ. RANGE & DIRECTION 5-100-5 HZ	ITEM HS-C DESIC.	CODE —	SERIAL NO. —	TYPE OF TEST DVT
SPECIFICATION TEST PLAN	PARA. —	AMEND. —	PHASE —	NAME OF TEST —

 REPORT NO.  
CR-115568  
SVHSR-6040


Hamilton  
Standard

U  
A

RANDOM VIBRATION TEST  
ANALYSIS METHOD A

PROJECT MICKET	CHECKED BY T.G.	TEST ENGINEER G.L.B.	RIG NO. 26	WITNESS
ITEM WS-2 (w/ Anderson design)	LOC.		SERIAL NO.	TYPE OF TEST D.V.T.
PARA.	PHASE	DATA NO.	DATE 11/23/71	TEST NO. 5
TEST PLAN				

EXCITATION ALONG X	AXIS
SRMS INPUT 12.4	
NON-OPERATING	
TEMP. 74	°F
PERIOD OF TEST <input checked="" type="checkbox"/> START <input type="checkbox"/> END	
DURATION OF TEST 10	MIN.
ACCEL. SERIAL NO. PB 34	
ACCEL. SENSITIVITY MV RMS GP	
2333	COL GP
ACCEL. SENSING X	AXIS
ACCEL. LOCATION A	
TAPER REEL NO. 010055	
SPECIAL CONDITIONS	
REPORT NO. CR-115568 SVHSER-6040	





Hamilton  
Standard


U  
A  
DIVISION OF UNITED AIRCRAFT CORPORATION

RANDOM VIBRATION TEST  
ANALYSIS METHOD B

HSF-1635 B

CR-115568  
SVHSER-6040

RIG 26	OPERATOR R. M.	PLOTTED BY T. G.	TRACE NO. 1	TEST NO. 5
TEST ENGINEER T. G.	CHECKED BY T. G.	DATE 11/23/71	TIME 1520	



INPUT LEVEL 12.4 GRMS	
EXCITATION AXIS X	
ACCEL SERIAL NUMBER PB 34	
ACCEL SENSING AXIS X	
ACCEL SENSITIVITY MV RMS GP 2.333 COL GP	
ANAL FILTER - HZ B.W. 6	
SWEEP SPEED OCT/MIN 10	
TIME CONSTANT - SEC 0.2	
ANAL. CALIBRATION 16.3 $\frac{g^2}{Hz}$ F.S.	
PERIOD OF TEST <input checked="" type="checkbox"/> START <input type="checkbox"/> END	
DURATION 1.0 MIN	
NON OPERATING	TEMP. 74 °F
TAPE REEL NO. 012255	
<input checked="" type="checkbox"/> CONTROL <input type="checkbox"/> RESPONSE	
PICKUP LOCATION A TOP BRACKET	
SPECIAL CONDITIONS	

PROJECT CO <sub>2</sub> DESICCANT	ITEM HS-C DESICCANT	CODE	SERIAL NUMBER	TYPE OF TEST DVT
SPEC. TEST PLAN	PARA.	AMEND.	PHASE	RANDOM
				PAGE NO. A-19



Hamilton  
Standard


U  
A  
DIVISION OF UNITED AIRCRAFT CORPORATION

RANDOM VIBRATION TEST  
ANALYSIS METHOD B

HSF-1635 B

CR-115568  
SVHSER-6040

RIG <b>26</b>	OPERATOR <b>R.M.</b>	PLOTTED BY <b>T.G.</b>	TRACE NO. <b>2</b>	TEST NO. <b>5</b>
TEST ENGINEER <b>T.G.</b>	CHECKED BY <b>T.G.</b>	DATE <b>11/23/71</b>	TIME <b>1520</b>	



INPUT LEVEL <b>12.4</b> GRMS	
EXCITATION AXIS <b>X</b>	
ACCEL SERIAL NUMBER <b>PB 36</b>	
ACCEL SENSING AXIS <b>X</b>	
ACCEL SENSITIVITY <b>2.489</b> MV RMS	
ANAL FILTER <b>6</b> HZ B.W.	
SWEEP SPEED <b>1</b> OCT/MIN	
TIME CONSTANT - SEC <b>1</b>	
ANAL. CALIBRATION <b>172.</b> $\frac{g^2}{Hz}$ F.S.	
PERIOD OF TEST <input checked="" type="checkbox"/> START <input type="checkbox"/> END	
DURATION <b>1.0</b> MIN	
NON OPERATING	TEMP. <b>74</b> °F
TAPE REEL NO. <b>012255</b>	
<input type="checkbox"/> CONTROL <input checked="" type="checkbox"/> RESPONSE	
PICKUP LOCATION <b>"B"</b>	
<b>BOTTOM BRACKET</b>	
SPECIAL CONDITIONS	

PROJECT <b>CO2 DESICCANT</b>	ITEM <b>HS-C DESIC.</b>	CODE <b>-</b>	SERIAL NUMBER <b>-</b>	TYPE OF TEST <b>DVT</b>
SPEC. <b>TEST PLAN</b>	PARA. <b>-</b>	AMEND. <b>-</b>	PHASE <b>-</b>	PAGE NO. <b>-</b>



**Hamilton  
Standard**


**U  
A**  
DIVISION OF UNITED AIRCRAFT CORPORATION

**RANDOM VIBRATION TEST  
ANALYSIS METHOD B**

HSF-1635 B

CR-115568  
SVHSER-6040

RIG <b>2.6</b>	OPERATOR <b>P.M</b>	PLOTTED BY <b>T.G.</b>	TRACE NO.	TEST NO. <b>5</b>
TEST ENGINEER <b>T.G.</b>	CHECKED BY <b>T.G.</b>	DATE <b>11/23/71</b>	TIME <b>1520</b>	



INPUT LEVEL <b>12.4</b> GRMS	
EXCITATION AXIS <b>X</b>	
ACCEL SERIAL NUMBER <b>NB82</b>	
ACCEL SENSING AXIS <b>B</b>	
ACCEL SENSITIVITY MV RMS <b>2.848</b> GP COL GP	
ANAL FILTER <b>6</b>	HZ B.W.
SWEEP SPEED <b>1</b>	OCT/MIN.
TIME CONSTANT <b>100</b>	SEC
ANAL. CALIBRATION <b>10.9</b> g <sup>2</sup> F.S. HZ	
PERIOD OF TEST <input checked="" type="checkbox"/> START <input type="checkbox"/> END	
DURATION <b>1.0</b> MIN	
NON OPERATING	TEMP. <b>74</b> °F
TAPE REEL NO. <b>012255</b>	
<input type="checkbox"/> CONTROL <input checked="" type="checkbox"/> RESPONSE	
PICKUP LOCATION <b>B</b> <b>(CROSS AXIS)</b> <b>TOP BRACKET</b>	
SPECIAL CONDITIONS	

PROJECT <b>Q2 DESICCANT</b>	ITEM <b>HS-C DESIC.</b>	CODE <b>-</b>	SERIAL NUMBER <b>-</b>	TYPE OF TEST <b>DVT</b>
SPEC. <b>TEST PLAN</b>	PARA. <b>-</b>	AMEND. <b>-</b>	PHASE <b>-</b>	RANDOM <b>-</b>
PAGE NO. <b>A-21</b>				



Hamilton  
Standard


U  
A  
DIVISION OF UNITED AIRCRAFT CORPORATION

RANDOM VIBRATION TEST  
ANALYSIS METHOD B

HSF-1635 B

CR-115568  
SVHSER-6040

RIG 26	OPERATOR R.M.	PLOTTED BY T.G.	TRACE NO. 4	TEST NO. 5
TEST ENGINEER T.G.		CHECKED BY T.G.	DATE 11/23/71	TIME 1520



INPUT LEVEL 12.4 GRMS	
EXCITATION AXIS X	
ACCEL SERIAL NUMBER NB90	
ACCEL SENSING AXIS X	
ACCEL SENSITIVITY MV RMS 2.637 GP COL GP	
ANAL FILTER 6	HZ B.W. 2
SWEEP SPEED OCT/MIN 10	
TIME CONSTANT - SEC 100	
ANAL. CALIBRATION 14.5 1/2 F.S. HZ	
PERIOD OF TEST <input checked="" type="checkbox"/> START <input type="checkbox"/> END	
DURATION 1.0 MIN	
NON OPERATING	TEMP. 74 °F
TAPE REEL NO. 012255	
<input type="checkbox"/> CONTROL <input checked="" type="checkbox"/> RESPONSE	
PICKUP LOCATION X CROSSAXIS TOP BRACKET	
SPECIAL CONDITIONS	

PROJECT CDL DESICCANT HS-C DESIC.	ITEM	CODE	SERIAL NUMBER	TYPE OF TEST DVT
SPEC. TEST PLAN	PARA.	AMEND.	PHASE	RANDOM
				PAGE NO.

**Hamilco Standard** DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT 06096

## SPACE &amp; LIFE SYSTEMS LABORATORY

## LOG OF TEST

### TYPE OF TEST

DVT Y 2-TEST

TEST ENGINEER

T. Gelb.

## NAME OF RIG

# 26

## PROJECT &amp; ENG. ORDER NO.

B77-400-100A

SHEET 1 OF

DATE 11-23-71

TEST PLAN NO. Per Plan of ST

MODEL NO. Virgin HS-C CO2 ad.

PART NO. Sorbing desiccant

SERIAL NO.

OPERATORS P. Judson R. Micket

Run #	Time Start	Axis	Mode	G's Peak	Scan Rate	G's Rms	Time in mins
2	1355	X	Sine	1.0	3.0	-	-
4	1440	X	Sine	2.0	3.0	-	-
5	1520	X	Rand	-	-	12.4	1.0

REMARKS:

CR-115568  
SVHSER-6040

1290



CODE

CR-115568  
- SVHSER-6040

MASTER PAGE NO 173

LOG PAGE NO. 1963

PROJECT

ITEM HS-C CO2

S/N

DATE \_\_\_\_\_

11/28/71

TEST TITLE DNT

Absorbing desiccant

ENGINEER T. G. b

OPERATOR R. Mickett / P Johnson

NO	RUN NO	TIME	TEST CODE	PREAMPLIFIER SETTINGS												VIB. AFS	INPUT LEVEL	SCAN RATE	COMP. SPEED	CONTROL FILTER	TAPE		VISA RECORD SPEED	RIS	REMARKS
				1	2	3	4	5	6	7	8	9	10	11	12						SPEED	TIME			
0	1		Cal	1000	1000									A	-	-	-	-	15			# 26	1 VOLT PK AT 200 HZ.		
1	2	1355	Run	10	10	-	-	-	-	-	-	-	-	C	X	1.0	3.0	4 Hz	10/100	1	3.0	-		5/10K ITEM/FIXTURE SCAN CONTROL @ "A"	
2	3	1430	Cal	1000	1000		1000	1000						C					1					1 VOLT PK AT 200 HZ.	
5	4	1440	Run	10	10	-	10	10	-	-	-	-	-	0	X	2.0	3.0	4 Hz	10/100	h	2.5	-		5/100 HZ/5 SINE CONTROL @ "A"	
	5	1520	Run	30	100		30	100						a	X	GRMS 12.4	-	-	-	e	m	1.0		1 min. Random Run	
																				e	d				
																					i				
																					a	T			
																					B	a			
																					1				
																					0				

U  
DIVISION OF UNITED AIRCRAFT CORPORATION  
19

CR-115568  
SVHSER-6040

CAL VOLTAGE ~~1000 MVpk~~ OR 1000 MV<sub>pk</sub> (AT 200 Hz)

## CALCULATION

$$\text{CALpt} = \frac{\text{RUN}}{\text{CAL}} \times \frac{\text{CAL VOLTAGE}}{\text{ACCEL SENS}}$$

$$\frac{MV_{rms}}{MV_{rms}/G_{pk}}$$

OR  $\frac{MV_{pk}}{Coul}$   
Gpk

CAL on RUN # 3

[illegible]

CAL on Row #3

A-26

DATE 11/25/71

PROJECT 23

TEST TITLE V F

ITEM

Absorbance

S/N

## MASTER VIBRATION LOG

CODE


WPI 11-44-100A RIG

OPERATOR P. Micket

MASTER PAGE NO. 233

LOG PAGE NO. 13

NO.	MEASUREMENT			TRANSDUCER				FIXED SCALE EQUIVALENT	VIBRATION		DIRECTION	REMARKS		REMARKS
	TYPE	LOC	LOC	TYPE	TL	CH	SN		INCH	MM		TYPE	IN	
1	Accel	CA	A"	2226	PD34		2323							
2	Accel	CA	B"	2226	PD35		2429							
3														
4	Accel	CB	B	2226	PD32		2848							
5	Accel	CB	C	2226	PD34		2637							
6														
7														
8														
9														
10														
11														
12														
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														

Hamilton  
ClarendonCR-115563  
SMSTR-6040

A-27

ORIGINAL PAGE  
OF POOR QUALITY

Hamilton  
Standard

U  
A.  
INDUSTRIAL AND AERIAL PHOTOGRAPHY

CR-115568  
SVHSER-6040

## APPENDIX B

### REPRODUCIBILITY

B-1

**PRECEDING PAGE BLANK NOT FILMED**

REPRODUCIBILITY

For preparation of HS-C for Test Series III, five batches were made. Capacity tests at standard conditions (p 53) showed excellent reproducibility ( $\pm 2.5\%$ ), as shown in Table B-I.

SERIES III LARGE SCALE PREPARATION SUMMARY

<u>Preparation Number*</u>	<u>CO<sub>2</sub> Capacity % by Wt.</u>	<u>H<sub>2</sub>O Capacity % by Wt.</u>	<u>Density g/ml</u>	<u>Date Prepared</u>	<u>Weight Prepared</u>
P-9130-II-A	1.96	4.60	.372	2/2/72	1.25 lb
P-9130-II-B	1.90	-	.374		
P-9130-III-A	1.88	-	.376	2/3/72	1.25 lb
P-9130-III-B	-	-	-		
P-9130-IV-A	1.87	-	.378	2/3/72	1.25 lb
P-9130-IV-B	-	-	-		
P-9130-V-A	1.88	-	.388	2/4/72	1.25 lb
P-9130-V-B	-	-	-		
P-9130-VI-A	1.89	-	.378	2/7/72	1.25 lb
P-9130-VI-B	1.86	-	.378		

\*NOTE: This Series was prepared in 1.25 pound batches which were given the designation, i.e., P-9130-II. Each batch was stored and subsequently tested in 0.50 liter containers labeled, i.e., P-9130-II-A or P-9130-II-B.

TABLE B-I

**Hamilton  
Standard**

**U**  
DIVISION OF UNITED AIRCRAFT CORPORATION  
**A**

**CR-115568  
SVHSER-6040**

## **APPENDIX C**

### **AMMONIA TESTING PER D-NA-002**

#### **TOXICANT TESTING**



HAMILTON  
Standard

A

CR-115568  
SVHSER-6040

REV I

10-11-71

AS 1-927 6/50

TEST NO. 2

HAMILTON STANDARD

PLAN OF TEST

JOB: Desiccant Humidity Control PLAN PREPARED BY: P. J. Lunde

PROJECT & ORDER: 1577-1000-100A APPROVED BY:

INSTRUCTION: Toxicant testing TEST ENGINEER: C. DeSimone

TIME PERIOD: 9-27-71 TO 10-31-71

1. WHAT IS ITEM BEING TESTED?
2. WHY IS TEST BEING RUN? WHAT WILL RESULTS SHOW OR BE USED FOR?
3. DESCRIBE TEST SET UP INCLUDING INSTRUMENTATION. ATTACH SKETCH OF INSTALLATION.
4. ITEMIZE RUNS TO BE MADE GIVING LENGTH OF EACH AND READINGS TO BE TAKEN.
5. SPECIAL INSTRUCTIONS: SAFETY PRECAUTIONS FOR OPERATORS AND HANDLING EQUIPMENT. OBSERVATIONS BY SIGHT, FEEL, OR HEARING. LIST POINTS OF OBSERVATION WHICH MIGHT CONTRIBUTE TO ANALYSIS OF (A) PERFORMANCE OF UNITS, (B) INCIPIENT TROUBLE BEFORE IT OCCURS, AND (C) CAUSE OF FAILURE.
6. HOW WILL DATA BE USED OR FINALLY PRESENTED? GIVE SAMPLE PLOT, CURVE, OR TABULATION AS IT WILL BE FINALLY PRESENTED.

NUMBER ENTRY AS LISTED ABOVE AND DESCRIBE BELOW

1. HS-C Preparation 1102

2. Purpose

It is conceivable that the HS-C bed may be heated as much as 100°F above normal operating temperature during undefined failure mode operation.

The work statement requires that HS-C not cause cabin contamination in such a failure mode and sets maximum for several toxicant levels 60 minutes and 168 hours after such a failure.

3. Test setup

The latest shuttle figures are

cabin volume 1800 ft<sup>3</sup>

CO<sub>2</sub> removal rate 0.53 lbs/hr.

Therefore,

$$\text{HS-C bed} = \frac{0.53 \text{ lb CO}_2 \times \text{hr}}{\text{hr}} \times \frac{1 \text{ lb HS-C}}{0.017 \text{ lbs CO}_2} \times \frac{154 \text{ gm}}{1 \text{ lb}} = 7070 \text{ gm}$$

(Prosuming an HS-C capacity of 1.7% CO<sub>2</sub> by wt).

Test bed weight is about 2 gm. Therefore

Equivalent

$$\text{cabin volume} = \frac{2 \text{ gm HSC} \times 1800 \text{ ft}^3 \text{ cabin}}{7070 \text{ gm HSC}} = 0.51 \text{ ft}^3$$

ORIGINAL PAGE IS  
OF POOR QUALITY

# AMMONIA TESTING

## Test Procedure

1. HS-C was tested for ammonia as follows. A 5.0 gram sample of resin was placed in a 1000cc stainless steel cylinder and evacuated to 38 mm pressure, back filled to 14.7 psia with bone dry air and stored at 155°F for 72 hours. The pressure was vented to 14.7 psia after an initial heating period of 2 hours. Following the heat soak, the container was removed from the oven and stored at room temperature for 24 hours. A sample of the gas over the resin was then transferred to a 10 cm. IR cell (10 psia pressure).
2. A NASA standard gas was used to calibrate HSD IR equipment at 500 ppm NH<sub>3</sub> in a 10 cm cell.
3. A newly purchased HSD gas was used to calibrate HSD IR equipment at 94 ppm. Agreement with NASA's 500 ppm sample was <±10% cm cell.

## Test Results

1. "Wet HS-C"\*\*, when tested to D-NA-002 gave 2120 ppm NH<sub>3</sub> above HSD sample containers.
2. "Dry HC-C"\*\*, when tested to D-NA-002 gave 1200 ppm test.
3. "Wet HS-C", after test, was evacuated for 30 minutes and let up to room air for 30 minutes equilibration. This gas then measured ≤ 10-20 ppm NH<sub>3</sub> when a 5x expansion was used with the 10 cm IR cell.
4. "Wet HS-C" gives  $\frac{267 \text{ microgram NH}_3}{\text{gm sample}}$   
"Dry HS-C" gives  $\frac{152 \text{ microgram NH}_3}{\text{gm sample}}$  when data from 4. and 5. above are reduced.

\*Equilibrated 24 hr. in N<sub>2</sub> with 50°F dewpoint H<sub>2</sub>O


\*\*Evacuated 24 hr. at room temp.

Hamilton  
Standard

U  
A<sup>®</sup>  
DIVISION OF UNITED AIRCRAFT CORPORATION

CR-115568  
SVHSER-6040

TOXICANT TEST APPARATUS



SS 10108-4

# Hamilton Standard

DIVISION OF UNITED AIRCRAFT CORPORATION

U  
A

CR-115568  
SVHSER-6040

**INTERNAL  
CORRESPONDENCE**

Please address answer to  
Mail Stop No. 1A-2-5

December 30, 1971  
SVME 623

Memorandum to: Dr. P. J. Lunde

cc: Messrs. W. A. Blecher  
R. L. Fischer  
F. Kester  
P. Perkins

Subject: Toxicant Testing on HSC and Rig 88

Four gas samples, one from rig 88 and three from an outgassing study on HSC Sample Prep 7489-92 (tested in rig 88) were sent to Analytical Research Laboratories, Inc., 160 Taylor Street, Monrovia, California for toxicant analysis. The results of the gas analysis are given in the attached report. The results of a blank analysis on the empty sample cylinders prior to the actual test are also included. The conditions under which the rig 88 sample was taken are available from Advanced Engineering; the procedure by which the HSC samples were obtained is as follows: three separate samples of 0.20 g of HSC were heated for periods of 1, 7 and 24 hours in a test rig of total volume of 0.05 cu. ft. at 180°F in air at 760 mm. The test rig consisted of a 400 cc stainless steel cylinder containing the sample and which was placed in an oven. This was connected to a 1000 cc stainless steel cylinder by a short length (8 in) of SS, 1/4" tubing which was outside of the oven.

In the case of the sample heated for 1 hr., a portion of the larger cylinder was immersed in liquid nitrogen for the duration of the test. The same procedure was followed during the last 2 hrs. of the 7 hr. test and the last 4 hrs. of the 24 hour test. This procedure was used to provide a driving force for the transfer of the offgassed products from the small cylinder through the tubing connecting it to the larger cylinder.

The presence of the brominated compounds in the HSC sample is explained on the basis that this sample had been tested in rig 88 where it adsorbed and held these contaminants. If the brominated compounds are neglected, the HSC samples still fail the test on the basis of the ammonia content, aromatics and total hydrocarbons.

Prepared by: A. Ruby

A. Ruby

Approved by: P. Perkins

P. Perkins

AR:han

TABLE No. 1

## Maximum allowable toxicant levels, HSC

Material	mg/M <sup>3</sup>
Carbon Monoxide	3.2
Total Hydrocarbons	14.7
Ethylene Glycol	2.5
Halocarbons	0.536
Inorganic Acids	0.0082
Aromatic Hydrocarbons	0.319
Ketones	5.88
Ammonia	1.73
Aldehydes	0.0123
Oxides of Nitrogen	0.094
Hydrazine	0.0655
Alcohols	1.31
2-butanone	29.4
Carbonyl Fluoride	6.75
2-methyl butanone	35.2
1,1,2-trichloroethane	153.
1,2,2-trifluoroethane	153.

Hamilton  
Standard



CR-115568  
SVHSER-6040

Lab/Shipper  
Log Number

# ANALYTICAL RESEARCH LABORATORIES, INC.

140 TAYLOR STREET, P.O. BOX 343, MONROVIA, CALIFORNIA 91016 • 213 387-3347

101022

Material/Sample Identity Hamilton Standard/4 gas cylinders		Date Received 10/21/71	
P.O. or R.P. Number SS008576NL		Requested By Armand Ruby	
Work Order 5098-01	Sample Disposition <input type="checkbox"/> Retain <input type="checkbox"/> Return <input type="checkbox"/> Destroy	Nature of Hazard	Due Date

Ship To:

Hamilton Standard, P. O. Box 343  
Windsor Locks, Connecticut 06096

Mark For:

## Nature of Work and Information Desired

Background Sampling of Gas Sample Cylinders

## SUMMARY OF LABORATORY REPORT

The four sample cylinders received from you were evacuated to approximately  $10^{-5}$  torr, flushed twice with helium, filled to 15 psig with helium, and transferred to an oven maintained at  $35^{\circ}\text{C}$  for 12 hours. Following this exposure, the bottles were placed on a gas chromatograph gas sample system and their contents cryogenically trapped for analysis. These analyses are shown on the attached tables. The values reported are the total micrograms of each component found in the one liter of gas transferred through the cryogenic trap.

This document and the attached data represents a certification of the trace analysis and cleanliness on the examined gas cylinders.

These sample cylinders were returned for sampling the outgassing of your sorbent bed. We are looking forward to an early receipt of the collected samples.

Analyst C. L. Deuel	Date 11/18/71	Approved By <i>Armand Ruby</i>	Invoice #
------------------------	------------------	-----------------------------------	-----------

CR-115568  
SVHSER-6040

COMPOUND	FW	UG
FREON 113	187.39	.00007
CHLOROFORM	119.39	.00028
TRICHLOROETHYLENE	131.40	.00011
DICHLOROBENZENE	147.01	TRACE
BUTANE	58.12	.0014
ISOPRENE	68.11	.0095
METHYLCYCLOPENTANE	64.11	.0043
METHYLCYCLOHEXANE	98.18	.0017
BENZENE	78.11	.021
TOLUENE	92.13	.025
CUMENE	120.20	.019
ETHYL ALCOHOL	46.07	.017
ISOPROPYL ALCOHOL	60.09	.010
ACETONE	58.08	.015
TOTAL		.12527

ORIGINAL PAGE 1  
OF POOR QUALITY

WILCOX, S. ADARL. SAMPLE BOTTLE NO. 2

PAGE

CR-115568  
SVHSER-6040

COMPOUND	FW	UG
FREON 113	167.39	.17
CHLOROFORM	119.39	.0029
TRICHLOROETHYLENE	131.40	.00006
BUTANE	58.12	.0084
TOLLENE	92.13	.0084
TOTAL		.19480



ILTCO STANDARD SAMPLE BOTTLE NO. 3

PAGE 1

COMPOUND	P.W	UG
FREON 113	167.39	.091
CHLOROFORM	119.39	.00014
TRICHLOROETHYLENE	131.40	.00011
TOLUENE	92.13	.0017
TOTAL		.09293

CR-115568  
SVHSER-6040

WILCOX S. DART, SAMPLE BOTTLE NO. 4

PAGE 1

CR-115568  
SVHSR-6040

COMPOUND	NW	UG
FREON 113	187.39	.00007
CHLOROFORM	119.39	.00014
TRICHLOROETHYLENE	131.40	.00011
TETRACHLOROETHYLENE	185.85	.00003
TOLUENE	92.13	.00032
TOTAL		.00067

**Hamilton  
Standard**

**U**  
DIVISION OF UNITED AIRCRAFT CORPORATION  
**A®**

CR-115568  
SVHSER-6040

**ANALYTICAL RESEARCH LABORATORIES, INC.**  
160 Taylor Street, P.O. Box 369  
Monrovia, Calif. 91016

**Laboratory/Shipper**  
**Log Number**  
101022A

<b>Material/Sample Identity</b> Hamilton Standard/4 gas samples			<b>Date Received</b> 12-3-71	
<b>P.O. or R.P. Number</b> SS008576NL		<b>Requested By</b> Ron Corriveau/cc: Armand Ruby		
<b>Work Order</b> 5098-01	<b>Sample Disposition</b> <input type="checkbox"/> Retain <input type="checkbox"/> Return <input type="checkbox"/> Destroy		<b>Nature of Hazard</b>	<b>Due Date</b>
<b>Ship To:</b> Hamilton Standard, P.O. Box 343, Windsor Locks, Connecticut 06096				

**Mark For:**

**Nature of Work and Information Desired**


Trace Gas Analysis of Supplied Samples

**Summary of Laboratory Report**

The four gas samples were divided on a vacuum rack to provide aliquots for at least two gas chromatographic examinations one for wet chemical and one for mass spectrometric analyses. The results of these studies are found in Tables 1-3.

The brominated compounds listed in Table 1 were identified by mass spectrometry. The dibromoethylene compounds were unequivocally identified, but the assignment of the proper isomers could not be made by mass spectrometry. The cis and trans isomers of 1,2 dibromoethylene were assigned primarily because the resolution of these two peaks by gas chromatography indicated a probable spread in boiling points. The 1,1 isomer's boiling point is quite close to that of the 1,2 isomer, while the cis-trans isomers offer a larger spread. It could, however, be considered equally significant that in samples 2,3 and 4 only one isomer was present. Since the cis-trans forms are generally mingled, a choice of the 1,1 and 1,2 isomers might be indicated.

The unknown listed in samples 1 and 2 is the same compound. It was not resolved by gas chromatograph from the tribromoethylene peak, and was not identified by mass spectrometry. There was some indication that it is probably a brominated acetylene type compound.

<b>Analyst</b> C. L. Deuel	<b>Date</b> 12-22-71	<b>Approved By</b> 	<b>Invoice No.</b>
-------------------------------	-------------------------	--	--------------------

## GC - MS TRACE ANALYSIS OF HAMILTON STANDARD

SAMPLES, mg/m<sup>3</sup>SAMPLE NUMBER

<u>Compound</u>	<u>1. R1G88 11-17</u>	<u>2. HSC 7 hrs. @ 180°</u>	<u>3. HSC 24 hrs. @ 180°</u>	<u>4. HSC 1 hr. @ 180°</u>
Methylene Chloride	-	3.8	0.039	-
Methyl Chloroform	0.0067	0.0015	0.026	0.0080
Tetrachloroethylene	0.00027	-	0.097	0.37
1,1 Dichloroethane	0.00057	-	0.0009	-
Trans dibromoethylene 770.	-	-	-	-
Cis dibromoethylene 820.	-	2.2	0.2	0.0022
Tribromoethylene 1350.	-	62.	100.	39.
Toluene	0.30	0.82	1.1	1.5
Methyl alcohol	0.026	-	0.51	0.73
Isopropyl alcohol	0.48	0.50	0.076	0.089
Acetone	0.67	0.92	0.65	0.80
Unknown	6.5	.13	-	-
Carbon Monoxide*	N. D.	N. D.	N. D.	N. D.

\*N. D. ■ None Detected, or less than 5 ppm with the analytical system used.

TABLE 1

Hamilton  
StandardU  
ACR-115568  
SVHSER-6040MASS SPECTROMETRIC ANALYSIS OF HAMILTON  
STANDARD SAMPLES, Vol %

<u>Compound</u>	<u>SAMPLE NUMBER</u>			
	<u>1. RIG88 11-17</u>	<u>2. HSC 7 hrs. @ 180°F</u>	<u>3. HSC 24 hrs. @ 180°F</u>	<u>4. HSC 1 hr. @ 180°F</u>
Hydrogen	0.14	N. D. *	N. D. *	N. D. *
Helium	N. D. *	0.05	0.45	0.05
Nitrogen	79.2	78.1	77.8	77.9
Oxygen	20.2	20.8	20.7	21.0
Argon	0.03	0.91	0.90	0.90
Carbon Dioxide	0.38	0.11	0.17	0.15
Water	0.04	0.01	0.04	0.03

---

\*N. D. ■ None Detected, <.005%

TABLE 2

## WET CHEMICAL ANALYSIS OF HAMILTON STANDARD

SAMPLES, ppm

SAMPLE NUMBER

<u>Compound</u>	<u>1. RIG88 11-17</u>	<u>2. HSC 7 hrs. @ 180°F</u>	<u>3. HSC 24 hrs. @ 180°F</u>	<u>4. HSC 1 hr. @ 180°F</u>
Ammonia	88	28	73	31
Oxides of Nitrogen (as NO <sub>2</sub> )	<1	2	<1	3
Aldehydes (as For- maldehyde)	<1	<1	<1	<1

TABLE 3

**Hamilton  
Standard**

DIVISION OF UNITED AIRCRAFT CORPORATION

**U  
A<sub>®</sub>**

**CR-115568  
SVHSER-6040**

## **APPENDIX D**

### **INPUT/OUTPUT PARAMETERS**

#### **FLOW CHARTS FOR COMPUTER PROGRAM**

## INPUT/OUTPUT PARAMETERS

Input ParametersProgram Control Constants.-

<u>Data Loc.</u>	<u>Symbol</u>	<u>Definition</u>	<u>Units</u>
1.	DT	Calculation time interval	min
2.	TMAX	Maximum time duration of transient	min
3.	PRINT	Input 1.0 to print system output variables each DT; input N to print system output variables each N(DT) minutes (N=any positive integer)	
4.	PLOT	Input 0. - No printer plots outputed Input 1. - Printer plots specified in section 1.2 outputed	
5.	FN	Number of nodes	
6.	IND	Input 0. - system initially adsorbs Input 1. - system initially desorbs	
7.	IDES	Input 0. - system vacuum desorbs Input 1. - system gas purge desorbs	
8.	ISOT	Input 0. - system performs isothermally Input 1. system performs nonisothermally	
9.	XJ	Number of passes through PVAC each system pass	
12.	PRILST	Same as print but for last full cycle.	

Initial Conditions. -

11.	ICXC	Initial loading of CO <sub>2</sub> on X sites	%
12.	ICYH	Initial loading of H <sub>2</sub> O on Y sites	%
13.	ICZC	Initial loading of H <sub>2</sub> O on Z sites	%



<u>Data Loc.</u>	<u>Symbol</u>	<u>Definition</u>	<u>Units</u>
14.	ICYHC	Initial loading of CO <sub>2</sub> on YH <sub>2</sub> O sites	%
15.	PIH <sub>2</sub> O	Inlet Partial pressure of H <sub>2</sub> O	mmHg
16.	PICO <sub>2</sub>	Inlet partial pressure of CO <sub>2</sub>	mmHg

Program Constants.-

21.	XOL	Ultimate loading capacity of CO <sub>2</sub> on X sites	%
22.	YOL	Ultimate loading capacity of H <sub>2</sub> O on Y sites	%
23.	ZOL	Ultimate loading capacity of H <sub>2</sub> O on Z sites	%
24.	KX	Forward rate coefficient for CO <sub>2</sub> on X sites	$\frac{1}{\text{mmHg}}$
25.	KXR	Reverse rate coefficient for CO <sub>2</sub> on X sites	$\frac{1}{\text{mmHg}}$
26.	KY	Forward rate coefficient for H <sub>2</sub> O on Y sites	$\frac{1}{\text{mmHg}}$
27.	KYR	Reverse rate coefficient for CO <sub>2</sub> on Y sites	$\frac{1}{\text{min}}$
28.	KYH	Forward rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	$\frac{1}{\text{min-mmHg}}$
29.	KYHR	Reverse rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	$\frac{1}{\text{min}}$
30.	KZ	Forward Rate coefficient for H <sub>2</sub> O on Z sites	$\frac{1}{\text{min-mmHg}}$
31.	KZR	Reverse rate coefficient for H <sub>2</sub> O on Z sites	$\frac{1}{\text{min}}$

<u>Data Loc.</u>	<u>Symbol</u>	<u>Definition</u>	<u>Units</u>
32.	MZT	Bed weight	lb
33.	PAIR	Process gas pressure at bed inlet	mmHg
34.	Q	Process gas flow	ft <sup>3</sup> /min
35.	TCIN	Coolant inlet temperature	°R
36.	TGI	Process gas inlet temperature	°R
37.	PIN	Bed inlet total pressure during vacuum desorption	mmHg
38.	POUT	Bed outlet total pressure during vacuum desorption	mmHg
39.	ADSORB	Adsorption cycle time	min
40.	DESORB	Desorption cycle time	min
41.	VB	Bed void volume	ft <sup>3</sup>
42.	XMU	Viscosity	lb-sec/in <sup>2</sup>
43.	DIA	Bead diameter	inches
44.	LB	Bed length	ft
45.	WeTOT	Coolant flow rate	lb/min
46.	CPC	Specific heat of coolant flow	BTU/lb-°F
47.	LB	Bed length	ft
48.	ABHXT	Heat transfer area between bed and heat exchanger	ft <sup>2</sup>
49.	AAMBT	Heat transfer area between heat exchanger and ambient	ft <sup>2</sup>
50.	WHX	Heat exchanger core weight	lb
51.	WBED	Bed weight	lb
52.	CPHX	Heat exchanger specific heat	BTU/lb-°F
53.	CPBED	Bed specific heat	BTU/lb-°F

<u>Data Loc.</u>	<u>Symbol</u>	<u>Definition</u>	<u>Units</u>
54.	AB	Bed cross sectional area	ft <sup>2</sup>
55.	AHX	Heat exchanger cross section area	ft <sup>2</sup>
56.	KB	Bed axial conductance	BTU/min-ft-°F
57.	KHX	Heat exchanger metal thermal conductivity	BTU/min-ft-°F
58.	TAMB	Ambient temperature	°R
59.	HAMB	Ambient heat transfer coefficient	BTU/min-ft <sup>2</sup> °F
60.	NPT1	No. of points in $h_B$ vs $W_T$ curve	
61.	NPT2	No. of points in $h_{HX}$ vs $W_c$ curve	
62.	PRLAST	Durling last cycle print every PRLAST (DT)	N.D.
63.	A	Cross sectional area of bed	in. <sup>2</sup>
64.	E	Void fraction	N.D.

Curve Inputs.-

1. Heat transfer coefficient,  $h_B$  vs flow rate

<u>Data Location</u>	<u>Input</u>
101 to 120	Values of flow through bed (lb/min)
121 to 140	Values of heat transfer coefficient corresponding to values of flow in data location 101 to 120.

2. Heat transfer coefficient,  $h_c$  vs coolant flow rate

<u>Data Location</u>	<u>Input</u>
141 to 160	Values of coolant flow (lb/min)
161 to 180	Values of heat transfer coefficient corresponding to values of flow in data location 141 to 160.

A description of the subroutine LOAD follows along with an example of the inputting of data. The example used is for the test case included in the source listings.

NAME: LOAD  
CATEGORY: Input/Output  
TITLE: Standard Load Routine  
PURPOSE: This routine loads a variable amount of floating point decimal input.  
METHOD: To load variables, 2 dimensional or 3 dimensional or arrays programmer must use qEQUIVALENCE statements to assign these parameters storage as part of the one dimensional array used as an argument to LOAD.

Program Information

The two items in this group specify the number (n) of pieces of data to be loaded per card or line, and where in the computer memory, location number, to put this input data. The location number is also used to terminate loading and start computing the results. See HS Form 1199A 9/63.

- A) "n" specifies the number of pieces of input data to be loaded on this card or line and is a number from 1 to 5 written without a decimal point. "n" is coded in card column 1.
- B) Location number, specified by the particular program, defines where the first piece of input data will be loaded in the computer memory. Successive pieces of input data will be loaded into successive locations in memory. The location number is coded in card columns 3 through 12. Other features and requirements are:
1. The location number must be written with a decimal point.
  2. If the location number is omitted, the input data on this card will be loaded consecutively in memory following the previously loaded input data.
  3. A minus sign before the location number terminates loading at the end of this card line, and the computer will proceed to calculate the results of the analysis.
  4. The input data is coded such that the first piece of data is in card columns 13 through 24, the second in card columns 25 through 36, etc.

USAGE: CALL LOAD (DATA)  
DATA - 1 dimensional array - floating point into which data is to be loaded.

Output Parameters

The following system variables are printed out each print interval (set up by PRINT (3)).

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
TIME	Transient elapsed time	min
PCTL	Total percent loading on bed	%
EFFH	H <sub>2</sub> O removal efficiency	%
EFFC	CO <sub>2</sub> removal efficiency	%
LTH2O	Total loading of H <sub>2</sub> O on bed	%
LTCO2	Total loading of CO <sub>2</sub> on bed	%
LYH2	Total loading of H <sub>2</sub> O on Y sites	%
LZH2	Total loading of H <sub>2</sub> O on Z sites	%
LXCO2	Total loading of CO <sub>2</sub> on X sites	%
LYHC	Total loading of CO <sub>2</sub> on YH <sub>2</sub> O sites	%
TCOUT	Average outlet coolant temperature	°R

The following variables are printed nodally or at nodal interfaces

## Weight percent adsorbed by nodes

LTCO2	-	Total CO <sub>2</sub>	%
LTH2O	-	Total H <sub>2</sub> O	%

## Flow rates between nodes

CO2	(lb-moles)/min
H2O	(lb-moles)/min
Total	(lb-moles)/min

## Rate of adsorption

CO2	(lb-moles)/min
H2O	(lb-moles)/min
Total	(lb-moles)/min

## Pressures at the nodes and at inlet and outlet

CO2	mm Hg
H2O	mm Hg
Total	mm Hg

## Temperatures

Gas	°F
Bed	°F

The following system variables vs time are also printer plotted at the end of each run:

PCTL	PHOUT	TG(out) - outlet process gas temperature
LTH2O	PCOUT	
LTCO2	TCOUT	

#### PROGRAM SOURCE LISTINGS


The source listings of each program module shown in the computer printout are included in this section, with the exception of subroutines BEGIN, LOAD, PLOT, and PACK which are listed in "Digital Computer Program for Desiccant Humidity Control System" date 21 July 1971.

#### PERFORMANCE MATCHING

A sample case has been processed to simulate cycle 16 of Run Series III of the large scale tests and is included on pages D-22 through D-57.

The computer program utilizes eleven constants to describe the reaction kinetics at a given temperature. Three of these are the basic capacities associated with each kind of adsorption site while the remaining eight are the forward and reverse reaction rate coefficients associated with each of the four kinetic reactions. These constants can be determined experimentally using thermogravimetric equipment. Alternatively, the eleven constants can be manipulated to match large scale test performance. In this case the basic rate data determined for an earlier material preparation was used as a point of departure and the individual rates then adjusted to match the large scale test results. The capacities associated with each of the basic adsorption sites were scaled on the basis of the quantity of coating used in the preparation. The forward and reverse rate coefficients were adjusted to fit the experimental breakthrough curves and to provide the observed interactions between water and CO<sub>2</sub> capacity. It was necessary to increase all of the forward rate coefficients to produce correlation with the test data. CO<sub>2</sub> breakthrough curve is quite fast and therefore simulation consists simply of achieving the correct cyclic capacity. The water adsorption curve does not completely breakthrough and requires curve fitting at the experimental valve of cyclic capacity. The water breakthrough curves for cycle 16 of Run Series III and the results of the sample printout of the computer simulation are shown in figure D-1. It is evident from figure D-1 that the revised rate coefficients permit a satisfactory fit of the test data.

HS-C LARGE SCALE TESTS  
H<sub>2</sub>O ADSORPTION CURVE  
CYCLE - 16 - SERIES III



The computer was then used to prepare graphs of performance similar to the experimentally derived figures 13, 14, and 15 of the main body of this report. These are presented as figures D-2, D-3 and D-4. Comparison with the experimental data shows similar trends, indicating a satisfactory computer program. In the case of capacity as a function of flow rate, it must be pointed out that the computer run is for a bed of half the size of the comparative test data. Therefore it is to be expected that the curve will be foreshortened along the flow axis.



HS-C LARGE SCALE PARAMETRIC TESTS  
EFFECT ON INLET HUMIDITY ON CYCLIC CAPACITY




FIGURE D-2

HS-C LARGE SCALE PARAMETRIC TESTS  
EFFECT OF PARTIAL PRESSURE OF CO<sub>2</sub>  
ON CYCLIC CAPACITY




FIGURE D-3

HS-C LARGE SCALE PARAMETRIC TESTS




FIGURE D-4

## PROGRAM FLOW CHARTS

Figure D-5 illustrates a general flow chart of the program.

A complete set of "Auto Flow" charts is included in this appendix following the sample case printout.

## PROGRAM SYMBOL DEFINITIONS

This section relates Fortran names to physical quantities in each of the subroutines.

Main Program

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
ADSORB	Adsorption cycle time	(min)
APCO2	Total loading of CO <sub>2</sub> /node	(%)
APH2O	Total loading of H <sub>2</sub> O/node	(%)
DCO2	CO <sub>2</sub> adsorption/desorption rate/node	(lb-mole/min)
DESORB	Desorption cycle time	(min)
DH2O	H <sub>2</sub> O adsorption/desorption rate/node	(lb-mole/min)
DIFF	Difference between present average coolant outlet temperature and past average coolant outlet temperature	(°F)
DMC	Nodal CO <sub>2</sub> inlet flow rate	(lb mole/min)
DMCO	CO <sub>2</sub> flow rate out of each node	(lb mole/min)
DMH	Nodal H <sub>2</sub> O inlet flow rate	(lb mole/min)
DMHO	H <sub>2</sub> O flow rate out of each node	(lb mole/min)
DT	Computing time interval	(min)
DTP	Computing time interval for subroutine PVAC	(min)
EFFC	CO <sub>2</sub> removal efficiency	(%)
EFFH	H <sub>2</sub> O removal efficiency	(%)

GENERAL FLOW CHART




FIGURE D-5

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
FN	Number of nodes	
I	nodal index	
ICXC	Initial loading of CO <sub>2</sub> on X sites	(%)
ICYH	Initial loading of H <sub>2</sub> O on Y sites	(%)
ICYHC	Initial loading of CO <sub>2</sub> on YH <sub>2</sub> O sites	(%)
ICZC	Initial loading of H <sub>2</sub> O on Z sites	(%)
IDES	Indicator used for system desorption	
ISOT	Indicator used to operate system isothermally or nonisothermally	
IND	Indicator used to specify whether system is adsorbing or desorbing	
JIND	Indicator from subroutine ALOGIC specifying whether the program is in its 1st pass, or whether on adsorb/desorb or desorb/adsorb switch has occurred	
KX	Forward rate coefficient for CO <sub>2</sub> on X sites	
KXR	Reverse rate coefficient for CO <sub>2</sub> on X sites	
KY	Forward rate coefficient for H <sub>2</sub> O on Y sites	
KYH	Forward rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	
KYHR	Reverse rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	
KYR	Reverse rate coefficient for H <sub>2</sub> O on Y sites	
KZ	Forward rate coefficient for H <sub>2</sub> O on Z sites	

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
KZR	Reverse rate coefficient for H <sub>2</sub> O on Z sites	
LTCO <sub>2</sub>	Percent loading of CO <sub>2</sub> on bed	(%)
LTH <sub>2</sub> O	Percent loading of H <sub>2</sub> O on bed	(%)
LXCO <sub>2</sub>	Loading of CO <sub>2</sub> on X sites	(lb/lb)
LYH <sub>2</sub> O	Loading of H <sub>2</sub> O on Y sites	(lb/lb)
LYHC	loading of CO <sub>2</sub> on YH <sub>2</sub> O sites	(lb/lb)
LZH <sub>2</sub>	Loading of H <sub>2</sub> O on Z sites	(lb/lb)
MCO <sub>2</sub>	Molecular weight of CO <sub>2</sub>	(lb/lb mole)
MH <sub>2</sub> O	Molecular weight of H <sub>2</sub> O	(lb/lb mole)
MTCO <sub>2</sub>	Total mass of CO <sub>2</sub> on bed	(lb)
MTH <sub>2</sub> O	Total mass of H <sub>2</sub> O on bed	(lb)
MZ	Bed weight/node	(lb)
MZT	Bed weight	(lb)
N	Number of nodes	
NPLOT	Indicator use to obtain printer plots	
NPRINT	Indicator used to print system output	
PAIR	Total pressure of process gas	(mmHg)
PCO	Bed outlet CO <sub>2</sub> partial pressure	(mmHg)
PCOUT	Nodal outlet partial pressure of CO <sub>2</sub>	(mmHg)
PCO <sub>2</sub>	Nodal inlet partial pressure of CO <sub>2</sub>	(mmHg)
PCTL	Total percent loading on bed	(%)
PHO	Bed outlet H <sub>2</sub> O partial pressure	(mmHg)
PHOUT	Nodal outlet partial pressure of H <sub>2</sub> O	(mmHg)

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
PH2O	Nodal inlet partial pressure of H <sub>2</sub> O	(mmHg)
PICO2	Bed inlet partial pressure of CO <sub>2</sub>	(mmHg)
PIH2O	Bed inlet partial pressure of H <sub>2</sub> O	(mmHg)
PIN	Bed inlet total pressure during vacuum desorption	(mmHg)
POUT	Bed outlet total pressure during vacuum desorption	(mmHg)
Q	Process volumetric flow rate	(ft <sup>3</sup> /min)
R	Gas constant	(555 ft <sup>3</sup> -mmHg/°R-lb mole)
TB	Bed nodal temperature	(°R)
TCIN	Heat exchanger coolant inlet temperature	(°R)
TCOUT	Average coolant outlet temperature	(°R)
TCOUTL	Past value of average coolant outlet temperature	(°R)
TG	Process gas nodal temperature	(°R)
TGI	Process gas inlet temperature	(°R)
TIME	Elapsed transient time	(min)
TMAX	Maximum time duration of transient	(min)
WAIR	Mass flow rate of process gas	(lb/min)
WCTOT	Coolant mass flow rate	(lb/min)
XCO2	Loading of CO <sub>2</sub> /node on X sites	(lb-mole/lb <sub>bed</sub> )
XOL	Ultimate loading capacity of CO <sub>2</sub> on X sites	(%)
YHOCO	Loading of CO <sub>2</sub> /node on YH <sub>2</sub> O sites	(lb mole/lb <sub>bed</sub> )
YH2O	YH <sub>2</sub> O sites available for CO <sub>2</sub> adsorption which have absorbed H <sub>2</sub> O	(lb mole/lb)



<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
YOL	Ultimate loading capacity of H <sub>2</sub> O on Y sites	(%)
ZOL	Ultimate loading capacity of H <sub>2</sub> O on Z sites	(%)

Subroutine TEMP

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
AAMB	Heat transfer area between heat exchanger and ambient/node	(ft <sup>2</sup> )
AAMBT	Total heat transfer area between heat exchanger and ambient	(ft <sup>2</sup> )
AB	Bed cross sectional area	(ft <sup>2</sup> )
ABHX	Heat transfer area between bed and heat exchanger node	(ft <sup>2</sup> )
ABHXT	Total heat transfer area between bed and heat exchanger	(ft <sup>2</sup> )
ACHX	Total heat exchanger heat transfer surface	(ft <sup>2</sup> )
AHX	Heat exchanger cross sectional area	(ft <sup>2</sup> )
CPBED	Bed specific heat	(BTU/lb-°F)
CPC	Specific heat of coolant flow	(BTU/lb-°F)
CPHX	Heat exchanger specific heat	(BTU/lb-°F)
DELL	Bed length of each node	(ft)
DMCO	CO <sub>2</sub> flow rate out of each node	(lb mole/min)
DMHO	H <sub>2</sub> O flow rate out each node	(lb mole/min)
DT	Subroutine computing time interval	(min)
HAMB	Heat transfer coefficient between heat exchanger external surface and ambient	(BTU/ft <sup>2</sup> -min-°F)

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
HB	Heat transfer coefficient between process gas and bed	(BTU/ft <sup>2</sup> -min-°F)
HXX	Heat transfer coefficient between coolant air and heat exchanger surface	(BTU/ft <sup>2</sup> -min-°F)
I	Nodal index	
JIND	Indicator specifying whether the program is in its 1st pass or not	
KB	Bed axial conductance	(BTU/min-ft-°F)
KHX	Heat exchanger metal thermal conductivity	(BTU/min-ft-°F)
K1	Total process gas (diluent + CO <sub>2</sub> + H <sub>2</sub> O) mass flow rate	(lb/min)
K11	Absolute value of total process gas mass flow rate	(lb/min)
K3	Effective heat transfer coefficient for bed axial conductance	(BTU/min-°F)
K4	Effective heat transfer coefficient for heat exchanger axial conductance	(BTU/min-°F)
LB	Bed length	(ft)
MCB	Heat capacity of bed/node	(BTU/°F)
MCHX	Heat capacity of heat exchanger/node	(BTU/°F)
N	Number of nodes	
QR	Heat of adsorption	(BTU/min)
Q1	Heat transfer rate between process gas and bed	(BTU/min)
Q2	Heat transfer rate between heat exchanger and bed	(BTU/min)
Q3	Axial heat transfer rate into bed node	(BTU/min)
Q4	Axial heat transfer rate out of bed node	(BTU/min)

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
Q5	Heat transfer rate between coolant and heat exchanger	(BTU/min)
Q6	Heat transfer rate between ambient and heat exchanger	(BTU/min)
Q7	Axial heat transfer rate into heat exchanger node	(BTU/min)
Q8	Axial heat transfer rate out of heat exchanger node	(BTU/min)
TAMB	Ambient temperature	(°R)
TB	Bed nodal temperature	(°R)
TCIN	Coolant inlet temperature	(°R)
TCOUT	Coolant nodal outlet temperature	(°R)
TGI	Process gas inlet temperature	(°R)
TG	Process gas nodal temperature	(°R)
THX	Heat exchanger nodal temperature	(°R)
TIME	Elapsed transient time	(min)
TOUT	Average coolant outlet temperature	(°R)
UAMB	Heat transfer coefficient between ambient and heat exchanger	(BTU/ft <sup>2</sup> -min-°F)
UBHX	Heat transfer coefficient between heat exchanger and bed	(BTU/ft <sup>2</sup> -min-°F)
WAIR	Process gas mass flow rate	(lb/min)
WBED	Bed weight	(lb)
WC	Coolant mass flow rate/node	(lb/min)
WCO2	CO <sub>2</sub> mass flow rate	(lb/min)
WCTOT	Coolant mass flow rate	(lb/min)

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
WHX	Heat exchanger core weight	(lb)
WH2O	H <sub>2</sub> O mass flow rate	(lb/min)

## Subroutine AMHSC

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
DCO2	CO <sub>2</sub> adsorption/desorption rate/node	(lb-mole/min)
DH2O	H <sub>2</sub> O adsorption/desorption rate/node	(lb-mole/min)
DMC	Nodal CO <sub>2</sub> inlet flow rate	(lb mole/min)
DMH	Nodal H <sub>2</sub> O inlet flow rate	(lb mole/min)
DT	Subroutine computing time interval	(min)
I	Nodal index	
IDES	Indicator used for system desorption	
IND	Indicator used to specify whether system is adsorbing or desorbing	
JIND	Indicator from subroutine ALOGIC defined under Main Program Symbol Definitions	
KX	Forward rate coefficient for CO <sub>2</sub> on X sites	
KXR	Reverse rate coefficient for CO <sub>2</sub> on X sites	
KY	Forward rate coefficient for H <sub>2</sub> O on Y sites	
KYH	Forward rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	
KYHR	Reverse rate coefficient for CO <sub>2</sub> on YH <sub>2</sub> O sites	
KYR	Reverse rate coefficient for H <sub>2</sub> O on Y sites	

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
KZ	Forward rate coefficient for H <sub>2</sub> O on Z sites	
MCO <sub>2</sub>	Molecular weight of CO <sub>2</sub>	(lb/lb mole)
MH <sub>2</sub> O	Molecular weight of H <sub>2</sub> O	(lb/lb mole)
MZT	Nodal bed weight	(lb)
MZ	Bed weight/node	(lb)
N	Number of nodes	
PCAVG	Average nodal CO <sub>2</sub> partial pressure	(mmHg)
PCOUT	Nodal outlet partial pressure of CO <sub>2</sub>	(mmHg)
PCO <sub>2</sub>	Nodal inlet partial pressure of CO <sub>2</sub>	(mmHg)
PHAVG	Average nodal H <sub>2</sub> O partial pressure	(mmHg)
PHOUT	Nodal outlet partial pressure of H <sub>2</sub> O	(mmHg)
PH <sub>2</sub> O	Nodal inlet partial pressure of H <sub>2</sub> O	(mmHg)
TYH <sub>2</sub> O	Total loading of H <sub>2</sub> O/node of Y sites	(lb mole/lb <sub>bed</sub> )
T	Bed nodal temperature	(°R)
XCO <sub>2</sub>	Loading of CO <sub>2</sub> /node on X sites	(lb mole/lb <sub>bed</sub> )
XO	Ultimate loading capacity of CO <sub>2</sub> on X sites	(lb mole/lb <sub>bed</sub> )
XOL	Ultimate loading capacity of CO <sub>2</sub> on X sites	(%)
XR	Adsorption rate of CO <sub>2</sub> /node on X sites	(lb mole/min/lb <sub>bed</sub> )
YHCR	Adsorption rate of CO <sub>2</sub> /node on YH <sub>2</sub> O sites	(lb mole/min/lb <sub>bed</sub> )
YHOCO	Loading of CO <sub>2</sub> /node on YH <sub>2</sub> O sites, also H <sub>2</sub> O/node on these sites	(lb mole/lb <sub>bed</sub> )
YH <sub>2</sub> O	Loading of H <sub>2</sub> O/node on Y sites with no CO <sub>2</sub> accepted	(lb mole/lb <sub>bed</sub> )

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
YO	Ultimate loading capacity of H <sub>2</sub> O Y sites	(lb mole/lb <sub>bed</sub> )
YOL	Ultimate loading capacity of H <sub>2</sub> O on Y sites	(%)
YR	Adsorption rate of H <sub>2</sub> O/node on Y sites	(lb mole/min/lb <sub>bed</sub> )
ZH2O	Loading of H <sub>2</sub> O/node on Z sites	(lb mole/lb <sub>bed</sub> )
ZO	Ultimate loading capacity of H <sub>2</sub> O on Z sites	(lb mole/lb <sub>bed</sub> )
ZOL	Ultimate loading capacity of H <sub>2</sub> O on Z sites	(%)
ZR	Adsorption rate of H <sub>2</sub> O/node on Z sites	(lb mole/min/lb <sub>bed</sub> )

Subroutine FOUT

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
AMTOT	Total constituent loading on bed	(lb)
DMH	Constituent inlet flow rate	(lb mole/min)
DT	Subroutine computing time interval	(min)
EFF	Removal efficiency of constituent	(%)
FCT2	Mass of constituent passed through bed during <u>one</u> computing time interval	(lb)
HCOTOT	Total mass of CO <sub>2</sub> passed through bed at any time	(lb)
H2OTOT	Total mass of H <sub>2</sub> O passed through bed at any time	(lb)
I	Nodal index	
IND	Indicator used to specify whether system is adsorbing or desorbing	

<u>SYMBOL</u>	<u>DESCRIPTION</u>	<u>UNITS</u>
LTOT	Total constituent loading for each node	(%)
MOLWT	Constituent molecular weight	(lb mole/lb)
MZ	Bed weight per node	(lb)
MZT	Total bed weight	(lb)
N	Number of nodes	
PCM1	Loading at site 1	(%)
PCM2	Loading at site 2	(%)
PCTL	Total constituent bed loading	(%)
TIME	Total elapsed time	(min)
X1	Constituent nodal loading at site 1	(lb mole/lb <sub>bed</sub> )
X2	Constituent nodal loading at site 2	(lb mole/lb <sub>bed</sub> )

## Subroutine PVAC

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
DCO2	CO <sub>2</sub> adsorption rate/node	(lb mole/min)
DELW	Apparent laminar flow resistance	
DH2O	H <sub>2</sub> O adsorption rate/node	(lb mole/min)
DIA	Apparent bed restriction diameter	(inches)
DMC	CO <sub>2</sub> flow rate out front end of bed	(lb mole/min)
DMCO	CO <sub>2</sub> flow rate out of each node	(lb mole/min)
DMH	H <sub>2</sub> O flow rate out front end of bed	(lb mole/min)
DMHO	H <sub>2</sub> O flow rate out of each node	(lb mole/min)
DMI	Total flow rate out of front end of bed	(lb mole/min)
DMO	Total nodal outlet flow rate	(lb mole/min)

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
DT	Subroutine computing time interval	(min)
I	Nodal index	
JIND	Indicator from subroutine ALOGIC defined under Main Program Symbol Definitions	
L	Node bed length	(inches)
N	Number of nodes	
PCOUT	CO <sub>2</sub> partial pressure out of bed	(mmHg)
PCO2	Nodal average CO <sub>2</sub> partial pressure	(mmHg)
PHOUT	H <sub>2</sub> O partial pressure out of bed	(mmHg)
PH2O	Nodal average H <sub>2</sub> O partial pressure	(mmHg)
PIN	Bed inlet pressure	(mmHg)
POUT	Bed outlet pressure	(mmHg)
Pt	Nodal total pressure	(mmHg)
PTA	Average total pressure	(mmHg)
R	Gas constant	(ft <sup>3</sup> -mmHg/°F-lb mole)
TG	Nodal process gas temperature	(°R)
VB	Bed void volume	(ft <sup>3</sup> )
VNODE	Nodal void volume	(ft <sup>3</sup> )
XLEN	Bed length	(ft)
XMU	Absolute viscosity	(lb-sec/in <sup>2</sup> )

Subroutine PCAL

<u>SYMBOL</u>	<u>DEFINITION</u>	<u>UNITS</u>
DAD	Constituent adsorption rate/node	(lb mole/min)



## CYCLE 16 SERIES III NOMINAL TEST CONDITIONS

CR-115568  
SVHSER-6040

BT	0.751250E-02	IPAX	146.000	PRINT	1024.00	PLBT	1.00000	FN	5.00000	IND	0.0
LES	0.0	ISDI	0.0	XJ	5.00000	ICXC	0.0	ICYM	0.0	IC7C	0.0
ICYHL	0.0	PIH2G	10.1000	PIC02	5.00000	XDL	2.45000	YOL	8.30000	ZDL	4.15000
KX	0.10000	KAY	0.100000E-00	KY	0.150000E-01	KYR	0.750000E-01	KYH	0.500000E-03	KYHR	0.128000
KZ	0.500000E-02	KZ-	0.200000E-01	MZT	4.00000	PAIR	755.000	Q	40.0000	TCIA	531.000
IGI	5.00000	PIN	0.100000E-01	PLUT	0.100000E-01	ADSORB	31.0000	DESORP	40.0000	V6	4.80000
XMO	0.250000E-08	LIA	0.250000E-01	WLTOY	1.00000	LPC	0.240000	LR	0.125000	AAHXT	1.00000
AAMBT	1.00000	KHX	5.00000	WED	4.00000	CPHX	0.202000	CPBED	0.160000	AP	1.00000
ANX	1.00000	KE	0.0	KHX	0.0	TAMB	70.0000	HAMB	0.100000E-01	NPII	3.70000
NPT2	3.00000	PREA5I	250.000	A	190.000	LPS	0.400000				

Hamilton  
StandardU  
A

OUTPUT

CR-115568  
SVHSER-6040

TIME	0.0	PCU	0.0	TCOUT	531.000	EFFH	100.000	EFFC	100.000
LIH2O	0.0	LICU2	0.0	LYH2O	0.0	LXCO2	0.0	LYHC	0.0

WT PLY ADSORBED BY NODES

LYCO2	0.0	0.0	0.0	0.0	0.0
LYH2O	0.0	0.0	0.0	0.0	0.0

FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67595E-03	0.0	0.0	0.0	0.0
H2O	0.14734E-02	0.0	0.0	0.0	0.0
TOTAL	0.20534E-02	0.0	0.0	0.0	0.0

RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.0	0.0	0.0	0.0	0.0
H2O	0.0	0.0	0.0	0.0	0.0
TOTAL	0.0	0.0	0.0	0.0	0.0

PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	0.0	0.0	0.0	0.0	0.0
H2O	10.100	0.0	0.0	0.0	0.0	0.0
TOTAL	15.100	0.0	0.0	0.0	0.0	0.0

TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
DEO	531.00	531.00	531.00	531.00	531.00

ORIGINAL PAGE IS  
OF POOR QUALITY

Harrison  
Standard

U  
A

TIME	8.00000	PCTL	6.00436	ICOUT	531.000	EFFH	43.6253	EFFC	36.0531
LTH20	3.84729	LICU2	2.15707	LYH20	3.07446	LZH2	0.752431	LXC02	2.09417
								LYHC	0.529330E-01

## WT PCT ADSORBED BY NODES

LXC02	2.2162	2.1877	2.1577	2.1272	2.0946
LYH20	5.5527	4.6686	3.7935	2.9799	2.2568

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67993E-03	0.67591E-03	0.67144E-03	0.66629E-03	0.66007E-03	0.65212E-03
H2O	0.13734E-02	0.12152E-02	0.10359E-02	0.84964E-03	0.67154E-03	0.51322E-03
TOTAL	0.20534E-02	0.18911E-02	0.17073E-02	0.15159E-02	0.13316E-02	0.11653E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.40166E-05	0.44697E-05	0.51450E-05	0.62252E-05	0.79526E-05
H2O	0.15671E-03	0.17937E-03	0.18623E-03	0.17810E-03	0.15832E-03
TOTAL	0.16223E-03	0.18384E-03	0.19137E-03	0.18433E-03	0.16627E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9852	4.9539	4.9185	4.8766	4.8242	4.7955
H2O	10.100	9.5176	8.2751	6.9249	5.5899	4.3529	3.7741
TOTAL	15.100	14.503	13.229	11.848	10.466	9.1771	8.5696

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
RED	531.00	531.00	531.00	531.00	531.00

TIME	16.0000	PCTL	8.45751	ICOUT	531.000	EFFH	23.0896	EFFC	19.0803
LTH20	5.17437	LICU2	2.28315	LYH20	4.67070	LZH2	1.50357	LXC02	2.12091
								LYHC	0.162240

## WT PCT ADSORBED BY NODES

LXC02	2.3314	2.3083	2.2838	2.2586	2.2336
LYH20	7.2414	6.7921	6.2560	5.6361	4.9463

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67993E-03	0.67819E-03	0.67623E-03	0.67413E-03	0.67197E-03	0.66983E-03
H2O	0.13734E-02	0.13195E-02	0.12473E-02	0.11556E-02	0.10451E-02	0.91908E-03
TOTAL	0.20534E-02	0.19977E-02	0.19236E-02	0.18298E-02	0.17170E-02	0.15889E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.17395E-05	0.19538E-05	0.20972E-05	0.21682E-05	0.21402E-05
H2O	0.53928E-04	0.72174E-04	0.91727E-04	0.11057E-03	0.12597E-03
TOTAL	0.55668E-04	0.74128E-04	0.93824E-04	0.11274E-03	0.12811E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9936	4.9800	4.9651	4.9494	4.9336	4.9257
H2O	10.100	9.9015	9.4374	8.8343	8.0900	7.2197	6.7587
TOTAL	15.100	14.895	14.417	13.799	13.039	12.153	11.684

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
RED	531.00	531.00	531.00	531.00	531.00

Hamilton  
StandardU  
A

TIME	24.0000	PLIL	9.68336	TCOUT	531.000	EFFH	15.9565	EFFC	13.1029
LTH20	7.33153	LTCU2	2.35183	LYH20	5.26690	LZH2	2.06463	LXC02	2.12262
								LYHC	2.229418

## WT PCT ADSORBED BY NODES

LXC02	2.3433	2.3699	2.3542	2.3360	2.3158
LYH20	7.8881	7.6653	7.3916	7.0577	6.5549

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67993E-03	0.67916E-03	0.67821E-03	0.67704E-03	0.67557E-03	0.67413E-03
H2O	0.13734E-02	0.13500E-02	0.13183E-02	0.12766E-02	0.12231E-02	0.11558E-02
TOTAL	0.20534E-02	0.20291E-02	0.19965E-02	0.19537E-02	0.18987E-02	0.18299E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.76591E-06	0.95373E-06	0.11240E-05	0.13692E-05	0.15453E-05
H2O	0.23456E-04	0.31654E-04	0.41659E-04	0.53585E-04	0.67241E-04
TOTAL	0.24252E-04	0.32607E-04	0.42823E-04	0.54954E-04	0.68788E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9972	4.9909	4.9831	4.9737	4.9630	4.9573
H2O	10.100	10.014	9.8107	9.5409	9.1905	8.7459	8.4996
TOTAL	15.100	15.011	14.802	14.524	14.164	13.709	13.457

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

TIME	31.0076	PLIL	10.2276	TCOUT	531.000	EFFH	12.4640	EFFC	10.2994
LTH20	7.84291	LTCU2	2.38471	LYH20	5.45065	LZH2	2.39226	LXC02	2.12260
								LYHC	0.262111

## WT PCT ADSORBED BY NODES

LXC02	2.4030	2.3957	2.3867	2.3757	2.3625
LYH20	8.1651	8.0361	7.8782	7.6853	7.4499

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.35317E-02	-0.18894E-02	-0.14185E-02	0.15953E-02	0.20825E-02	0.33535E-02
H2O	-0.71021E-02	-0.37503E-02	-0.27784E-02	0.31247E-02	0.40101E-02	0.63044E-02
TOTAL	-0.10000E-01	-0.56397E-02	-0.41968E-02	0.47200E-02	0.60926E-02	0.96579E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.35406E-06	0.46947E-06	0.60360E-06	0.75544E-06	0.94129E-06
H2O	0.13300E-04	0.17241E-04	0.22496E-04	0.28972E-04	0.36877E-04
TOTAL	0.13354E-04	0.17710E-04	0.23100E-04	0.29728E-04	0.37818E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.33212E-02	2.9517	3.9333	4.1677	3.9429	2.9409	0.34723E-02
H2O	0.68788E-02	5.9357	7.7891	8.1631	7.6012	5.5288	0.65277E-02
TOTAL	0.10000E-01	8.8874	11.722	12.331	11.544	8.4697	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

TIME	32.0000	PLIL	9.70052	TCOUT	531.000	EFFH	11.5199	EFFC	9.48045
------	---------	------	---------	-------	---------	------	---------	------	---------

ORIGINAL PAGE IS  
OF POOR QUALITYHamilton  
StandardU  
A

LYH20	7.51573	LXCO2	2.18479	LYH20	5.15303	LXCO2	2.36270	LXCO2	1.95013	LYHC	2.234557
-------	---------	-------	---------	-------	---------	-------	---------	-------	---------	------	----------

# WT PCT ADSORBED BY NODES

LXCO2	2.1958	2.1958	2.1912	2.1796	2.1606
LYH20	7.8079	7.7066	7.5627	7.3737	7.1277

# FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.87175E-04	-0.50980E-04	-0.16099E-04	0.18223E-04	0.52033E-04	0.87914E-04
H2O	-0.36382E-03	-0.20841E-03	-0.64637E-04	0.73184E-04	0.20936E-03	0.34980E-03
TOTAL	-0.45099E-03	-0.25939E-03	-0.80736E-04	0.91412E-04	0.26200E-03	0.43771E-03

# RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.36043E-04	-0.34678E-04	-0.34106E-04	-0.34198E-04	-0.35123E-04
H2O	-0.15516E-03	-0.14348E-03	-0.13751E-03	-0.13589E-03	-0.14021E-03
TOTAL	-0.19122E-03	-0.17815E-03	-0.17161E-03	-0.17009E-03	-0.17533E-03

# PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.19330E-02	0.39304	0.50156	0.53700	0.50830	0.40234	0.20084E-02
H2O	0.80070E-02	1.6405	2.0506	2.1563	2.0241	1.6010	0.79916E-02
TOTAL	0.10000E-01	2.0335	2.5521	2.6933	2.5329	2.0033	0.10000E-01

# TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
RED	531.00	531.00	531.00	531.00	531.00

CR-115568  
SVHSER-6040

HAMILTON  
Standard

U  
No

Multiple Pages Intentionally Left  
Blank

TIME	71.0078	PCTL	3.12057	TCOUT	531.000	EFFH	1.80293	EFFC	1.35293
LTH20	2.82224	LTCO2	0.298336	LYH20	1.45166	LZH2	1.42058	LXC02	0.294793
								LYHC	0.354279E-02

## WT PCT ADSORBED BY NODES

LXC02	0.25780	0.31510	0.33424	0.31991	0.26463
LYH20	2.7250	2.9716	3.5067	2.8772	2.5307

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.68161E-03	0.68440E-03	0.68631E-03	0.68818E-03	0.68987E-03
H2O	0.13734E-02	0.13942E-02	0.14241E-02	0.14442E-02	0.14636E-02	0.14823E-02
TOTAL	0.20534E-02	0.20758E-02	0.21085E-02	0.21305E-02	0.21518E-02	0.21722E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.16903E-05	-0.27808E-05	-0.19112E-05	-0.18687E-05	-0.16939E-05
H2O	-0.20730E-04	-0.29949E-04	-0.20024E-04	-0.19476E-04	-0.18716E-04
TOTAL	-0.22420E-04	-0.32730E-04	-0.21935E-04	-0.21344E-04	-0.20410E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	0.57741E-01	0.76295E-01	0.82948E-01	0.78112E-01	0.60228E-01	5.0731
H2O	10.100	0.65382	0.82173	0.86643	0.81316	0.64054	10.901
TOTAL	15.100	0.71157	0.89802	0.94938	0.89128	0.70076	15.974

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

TIME	72.0000	PCTL	4.15284	TCOUT	531.000	EFFH	5.06008	EFFC	3.82315
LTH20	3.28018	LTCO2	0.872661	LYH20	1.81631	LZH2	1.46387	LXC02	0.863784
								LYHC	0.867721E-02

## WT PCT ADSORBED BY NODES

LXC02	1.1594	1.0133	0.87279	0.73563	0.58219
LYH20	3.5530	3.5298	3.3981	3.1655	2.7544

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.55802E-03	0.44782E-03	0.35198E-03	0.27120E-03	0.20395E-03
H2O	0.13734E-02	0.10318E-02	0.79064E-03	0.61572E-03	0.48465E-03	0.37951E-03
TOTAL	0.20534E-02	0.15898E-02	0.12385E-02	0.96770E-03	0.75586E-03	0.58347E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.12190E-03	0.11020E-03	0.95838E-04	0.80781E-04	0.67246E-04
H2O	0.34167E-03	0.24114E-03	0.17492E-03	0.13106E-03	0.10515E-03
TOTAL	0.46357E-03	0.35134E-03	0.27076E-03	0.21184E-03	0.17240E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.5497	3.6930	2.9339	2.2843	1.7406	1.4998
H2O	10.100	8.8421	6.6971	5.1669	4.0421	3.1741	2.7908
TOTAL	15.100	13.392	10.390	8.1008	6.3264	4.9148	4.2907

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

TIME	74.0000	PCTI	5.79582	TCOUT	531.000	EFFH	9.06699	EFFC	5.86374
LTH20	4.12525	LTCO2	1.67058	LYH20	2.56551	LZH2	1.55974	LXCO2	1.64307
								LYHC	3.275744E-01

## WT PCT ADSORBED BY NODES

LXCO2	1.9215	1.8193	1.6956	1.5483	1.3681
LYH20	4.8623	4.5343	4.1786	3.7831	3.2680

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.64556E-03	0.60321E-03	0.55270E-03	0.49459E-03	0.42969E-03
H2O	0.13734E-02	0.11279E-02	0.92330E-03	0.75343E-03	0.61190E-03	0.49005E-03
TOTAL	0.20534E-02	0.17735E-02	0.15265E-02	0.13061E-02	0.11065E-02	0.91974E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.34365E-04	0.42354E-04	0.50508E-04	0.58108E-04	0.64902E-04
H2O	0.24555E-03	0.20459E-03	0.16988E-03	0.14153E-03	0.12104E-03
TOTAL	0.27992E-03	0.24695E-03	0.22039E-03	0.19964E-03	0.18675E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.8730	4.5896	4.2468	3.8462	3.3929	3.1598
H2O	10.100	9.1960	7.5391	6.1615	5.0164	4.0483	3.6037
TOTAL	15.100	14.069	12.129	10.408	8.8626	7.4411	6.7635

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
WED	531.00	531.00	531.00	531.00	531.00

TIME	76.0000	PCTI	6.89775	TCOUT	531.000	EFFH	10.3308	EFFC	7.86111
LTH20	4.86825	LTCO2	2.02950	LYH20	3.20385	LZH2	1.66440	LXCO2	1.97598
								LYHC	0.535170E-01

## WT PCT ADSORBED BY NODES

LXCO2	2.1396	2.0979	2.0450	1.9776	1.8874
LYH20	5.8007	5.3680	4.9110	4.4229	3.8387

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.66922E-03	0.65538E-03	0.63742E-03	0.61413E-03	0.58386E-03
H2O	0.13734E-02	0.11978E-02	0.10314E-02	0.87695E-03	0.73572E-03	0.60532E-03
TOTAL	0.20534E-02	0.18670E-02	0.16866E-02	0.15144E-02	0.13698E-02	0.11892E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.10708E-04	0.13837E-04	0.17563E-04	0.23292E-04	0.30266E-04
H2O	0.17568E-03	0.16639E-03	0.15443E-03	0.14123E-03	0.13040E-03
TOTAL	0.18639E-03	0.18023E-03	0.17239E-03	0.16452E-03	0.16067E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9605	4.8699	4.7525	4.6001	4.4025	4.2936
H2O	10.100	9.4532	8.1941	7.0136	5.9262	4.9275	4.4514
TOTAL	15.100	14.414	13.064	11.766	10.526	9.3299	8.7449

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
WED	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard



TIME	78.0000	PLTL	7.67097	TCOUT	531.000	EFFH	10.3627	EFFC	7.92371
LTH2U	5.50765	LTCU2	2.16333	LYH2U	3.73418	LZH2	1.77347	LXCQ2	2.09105
								LYHC	0.427914E-01

## WT PCT ADSORBED BY NODES

LXCL2	2.2175	2.1952	2.1640	2.1376	2.0974
LYH2U	6.4723	6.0362	5.5599	5.0410	4.4289

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	0.67992E-03	0.67511E-03	0.66946E-03	0.66261E-03	0.65404E-03	0.64294E-03
H2U	0.13734E-02	0.12475E-02	0.11159E-02	0.98232E-03	0.84993E-03	0.71930E-03
TOTAL	0.20534E-02	0.19226E-02	0.17854E-02	0.16449E-02	0.15040E-02	0.13622E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	0.40151E-05	0.56488E-05	0.66517E-05	0.85740E-05	0.11093E-04
H2U	0.12573E-03	0.13158E-03	0.13361E-03	0.13239E-03	0.13063E-03
TOTAL	0.13075E-03	0.13723E-03	0.14046E-03	0.14097E-03	0.14172E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	5.0000	4.9823	4.9437	4.8976	4.8407	4.7681	4.7290
H2U	10.100	9.6364	8.6864	7.7126	6.7340	5.7667	5.2895
TOTAL	15.100	14.619	13.632	12.610	11.575	10.535	10.018

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
WU	531.00	531.00	531.00	531.00	531.00

TIME	80.0000	PCTL	8.26807	TCOUT	531.000	EFFH	10.0445	EFFC	7.70939
LTH2U	6.04717	LTCU2	2.22090	LYH2U	4.15415	LZH2	1.88303	LXCQ2	2.11508
								LYHC	0.115814

## WT PCT ADSORBED BY NODES

LXCU2	2.2596	2.2421	2.2231	2.2022	2.1775
LYH2U	6.9552	6.5599	6.1112	5.6060	5.0036

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	0.67992E-03	0.67676E-03	0.67338E-03	0.66971E-03	0.66560E-03	0.66083E-03
H2U	0.13734E-02	0.12829E-02	0.11802E-02	0.10686E-02	0.95034E-03	0.82647E-03
TOTAL	0.20534E-02	0.19593E-02	0.18535E-02	0.17383E-02	0.16159E-02	0.14873E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	0.31665E-05	0.33742E-05	0.36720E-05	0.41089E-05	0.47769E-05
H2U	0.40937E-04	0.10235E-03	0.11158E-03	0.11824E-03	0.12387E-03
TOTAL	0.44103E-04	0.10572E-03	0.11529E-03	0.12235E-03	0.12865E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	5.0000	4.9883	4.9643	4.9096	4.8769	4.8595
H2U	10.100	9.7652	9.0537	8.2664	7.4209	6.5303
TOTAL	15.100	14.754	14.018	13.205	12.331	11.407

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
WU	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard

U  
P

TIME	82.0000	PCTL	8.75042	TCOUT	531.000		EFFH	9.66120	EFFC	7.44321	
LTH20	6.44490	LTCU2	2.25552	LYH20	4.51500	LZH2	1.98990	LXC02	2.11790	LYHC	0.137515

## AT PCT ADSORBED BY NODES

LXC02	2.2902	2.2741	2.2570	2.2386	2.2177
LYH20	7.3057	6.9655	6.5658	6.1013	5.5362

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	0.67992E-03	0.67743E-03	0.67485E-03	0.67218E-03	0.66939E-03	0.66644E-03
H2O	0.13734E-02	0.13070E-02	0.12280E-02	0.11370E-02	0.10352E-02	0.92280E-03
TOTAL	0.20534E-02	0.19844E-02	0.19029E-02	0.18092E-02	0.17044E-02	0.15892E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	0.24906E-05	0.25814E-05	0.26772E-05	0.27884E-05	0.29442E-05
H2O	0.60439E-04	0.79009E-04	0.90998E-04	0.10183E-03	0.11237E-03
TOTAL	0.68929E-04	0.81591E-04	0.93676E-04	0.10462E-03	0.11531E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	5.0000	4.9908	4.9722	4.9528	4.9327	4.9116	4.9009
H2O	10.100	9.8554	9.3200	8.6444	7.9848	7.1958	6.7861
TOTAL	15.100	14.846	14.292	13.647	12.918	12.108	11.687

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SLD	531.00	531.00	531.00	531.00	531.00

TIME	84.0000	PCTL	9.14384	TCOUT	531.000		EFFH	9.28372	EFFC	7.17684	
LTH20	6.46173	LTCU2	2.28212	LYH20	4.75999	LZH2	2.09174	LXC02	2.12015	LYHC	0.161968

## AT PCT ADSORBED BY NODES

LXC02	2.3149	2.2999	2.2836	2.2661	2.2462
LYH20	7.25835	7.2784	6.9338	6.5221	6.0109

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	0.67992E-03	0.67787E-03	0.67573E-03	0.67350E-03	0.67120E-03	0.66884E-03
H2O	0.13734E-02	0.13242E-02	0.12832E-02	0.11901E-02	0.11046E-02	0.10061E-02
TOTAL	0.20534E-02	0.20021E-02	0.19390E-02	0.18636E-02	0.17758E-02	0.16749E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	0.20515E-05	0.21454E-05	0.22294E-05	0.22966E-05	0.23596E-05
H2O	0.44271E-04	0.60953E-04	0.73162E-04	0.85471E-04	0.98485E-04
TOTAL	0.51322E-04	0.63099E-04	0.75341E-04	0.87768E-04	0.10085E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	5.0000	4.9925	4.9770	4.9609	4.9443	4.9271	4.9185
H2O	10.100	9.9186	9.5129	9.0193	8.4356	7.7588	7.3986
TOTAL	15.100	14.911	14.490	13.980	13.380	12.686	12.317

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SLD	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard

D-36

TIME	86.0000	PCTL	9.46422	TCOUT	531.000	EFFH	8.92682	EFFC	6.72181
LYH20	7.15569	LXCO2	2.30453	LYH20	4.97270	LXCO2	2.12095	LYHC	0.143574

## WT PCT ADSORBED BY NODES

LXCO2	2.3353	2.3214	2.3061	2.2895	2.2704
LYH20	7.7562	7.5201	7.2205	6.8722	6.4215

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.67823E-03	0.67642E-03	0.67451E-03	0.67250E-03	0.67042E-03
H2O	0.13734E-02	0.13636E-02	0.12890E-02	0.12306E-02	0.11601E-02	0.10759E-02
TOTAL	0.20534E-02	0.20145E-02	0.19655E-02	0.19051E-02	0.18376E-02	0.17463E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.16707E-05	0.18119E-05	0.19162E-05	0.20043E-05	0.20820E-05
H2O	0.37167E-04	0.47233E-04	0.58422E-04	0.70539E-04	0.84158E-04
TOTAL	0.36855E-04	0.49044E-04	0.60338E-04	0.72543E-04	0.86240E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9936	4.9809	4.9672	4.9527	4.9377	4.9301
H2O	10.100	9.9632	9.6525	9.2637	8.7891	8.2199	7.9121
TOTAL	15.100	14.957	14.633	14.231	13.742	13.158	12.842

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	88.0000	PCTL	9.72439	TCOUT	531.000	EFFH	8.59107	EFFC	6.67357
LYH20	7.40043	LXCO2	2.32376	LYH20	5.12585	LXCO2	2.12137	LYHC	0.202395

## WT PCT ADSORBED BY NODES

LXCO2	2.3520	2.3395	2.3255	2.3100	2.2919
LYH20	7.9028	7.7081	7.4635	7.1596	6.7691

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.67854E-03	0.67702E-03	0.67538E-03	0.67362E-03	0.67175E-03
H2O	0.13734E-02	0.13449E-02	0.13080E-02	0.12614E-02	0.12038E-02	0.11331E-02
TOTAL	0.20534E-02	0.20234E-02	0.19850E-02	0.19368E-02	0.18774E-02	0.18048E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.13883E-05	0.15172E-05	0.16432E-05	0.17584E-05	0.18674E-05
H2O	0.26548E-04	0.36893E-04	0.46597E-04	0.57651E-04	0.70668E-04
TOTAL	0.29936E-04	0.38411E-04	0.48240E-04	0.59409E-04	0.72535E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9949	4.9842	4.9726	4.9601	4.9467	4.9399
H2O	10.100	9.9449	9.7541	9.4468	9.0632	8.5910	8.3325
TOTAL	15.100	14.940	14.738	14.419	14.023	13.538	13.272

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

ORIGINAL PAGE IS  
OF POOR QUALITYHamilton  
StandardU  
P

TIME	90.0000	PLTL	9.93549	TCOUT	531.000		EFFH	8.27475	EFFC	6.44763	
LTH20	7.59528	LTCO2	2.34021	LYH20	5.24057	LZH2	2.35477	LXCO2	2.12168	LYHC	0.218535

## WT PCT ADSORBED BY NODES

LXCO2	2.3056	2.3546	2.3420	2.3279	2.3111
LYH20	8.0164	7.8556	7.5512	7.3939	7.0594

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.67880E-03	0.67754E-03	0.67614E-03	0.67462E-03	0.67296E-03
H2O	0.13734E-02	0.13511E-02	0.13220E-02	0.12847E-02	0.12378E-02	0.11791E-02
TOTAL	0.20534E-02	0.20299E-02	0.19996E-02	0.19609E-02	0.19124E-02	0.18521E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.11291E-05	0.12522E-05	0.14002E-05	0.15228E-05	0.16641E-05
H2O	0.22325E-04	0.29114E-04	0.37274E-04	0.46923E-04	0.58697E-04
TOTAL	0.23455E-04	0.30366E-04	0.38275E-04	0.48448E-04	0.60381E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9958	4.9871	4.9773	4.9666	4.9548	4.9417
H2O	10.100	10.318	9.8285	9.5042	9.2744	8.8857	8.6709
TOTAL	15.100	15.314	14.816	14.562	14.241	13.841	13.620

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SOL	531.00	531.00	531.00	531.00	531.00

TIME	92.0000	PLTL	10.1070	TCOUT	531.000		EFFH	7.97630	EFFC	6.23121	
LTH20	7.75288	LTCO2	2.35414	LYH20	5.32589	LZH2	2.42698	LXCO2	2.12194	LYHC	0.232205

## WT PCT ADSORBED BY NODES

LXCO2	2.3765	2.3670	2.3559	2.3432	2.3282
LYH20	8.1059	7.9726	7.8017	7.5845	7.2996

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67991E-03	0.67901E-03	0.67798E-03	0.67680E-03	0.67549E-03	0.67404E-03
H2O	0.13734E-02	0.13557E-02	0.13324E-02	0.13025E-02	0.12643E-02	0.12158E-02
TOTAL	0.20534E-02	0.20347E-02	0.20104E-02	0.19793E-02	0.19398E-02	0.18898E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.91209E-06	0.10316E-05	0.11765E-05	0.13107E-05	0.14512E-05
H2O	0.17761E-04	0.23237E-04	0.29489E-04	0.36194E-04	0.43481E-04
TOTAL	0.18673E-04	0.24269E-04	0.31165E-04	0.39605E-04	0.49932E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9966	4.9895	4.9814	4.9722	4.9620	4.9507
H2O	10.100	10.335	9.8838	9.6879	9.4370	9.1190	8.9406
TOTAL	15.100	15.331	14.873	14.669	14.409	14.080	13.897

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SOL	531.00	531.00	531.00	531.00	531.00

TIME	102.000	PCTL	10.5990	TCOUT	531.000	EFFH	6.71402	FFFC	5.29325
LYH20	8.20355	LTCO2	2.39546	LYH20	5.51729	LXCO2	2.12274	LYHC	5.272719

## WT PCT ADSORBED BY NODES

LXCO2	2.4057	2.4015	2.3966	2.3905	2.3830
LYH20	8.3578	8.3006	8.2262	8.1304	8.0027

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.67962E-03	0.67926E-03	0.67882E-03	0.67829E-03	0.67764E-03
H2O	0.13734E-02	0.13666E-02	0.13577E-02	0.13463E-02	0.13316E-02	0.13125E-02
TOTAL	0.20534E-02	0.20462E-02	0.20370E-02	0.20251E-02	0.20099E-02	0.19902E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.30128E-06	0.30634E-06	0.44181E-06	0.52943E-06	0.64196E-06
H2O	0.60051E-05	0.88536E-05	0.11408E-04	0.14697E-04	0.19070E-04
TOTAL	0.71904E-05	0.92199E-05	0.11650E-04	0.15226E-04	0.19712E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.9999	4.9964	4.9935	4.9899	4.9856	4.9832
H2O	10.100	10.075	10.017	9.9422	9.8461	9.7219	9.6520
TOTAL	15.100	15.074	15.013	14.936	14.836	14.707	14.635

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SLU	531.00	531.00	531.00	531.00	531.00

TIME	102.000	PCTL	10.5992	TCOUT	531.000	EFFH	6.71880	FFFC	5.29665
LYH20	8.20377	LTCO2	2.39548	LYH20	5.51736	LXCO2	2.12274	LYHC	5.272738

## WT PCT ADSORBED BY NODES

LXCO2	2.4057	2.4016	2.3966	2.3906	2.3830
LYH20	8.3580	8.3007	8.2264	8.1307	8.0030

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.35372E-02	-0.19882E-02	-0.15376E-02	0.16165E-02	0.21001E-02	0.34422E-02
H2O	-0.71286E-02	-0.39808E-02	-0.30584E-02	0.32152E-02	0.41446E-02	0.67124E-02
TOTAL	-0.10664E-01	-0.59690E-02	-0.45960E-02	0.48317E-02	0.62448E-02	0.10155E-01

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.30104E-06	0.36606E-06	0.44151E-06	0.52899E-06	0.64149E-06
H2O	0.60046E-05	0.88476E-05	0.11400E-04	0.14687E-04	0.19057E-04
TOTAL	0.71858E-05	0.92137E-05	0.11842E-04	0.15216E-04	0.19698E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.33163E-02	2.4518	3.9616	4.2013	3.9605	2.9439	0.33898E-02
H2O	0.66637E-02	5.9490	7.9221	8.3565	7.8199	5.7408	0.66102E-02
TOTAL	0.10000E-01	8.4008	11.884	12.558	11.780	8.6848	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SLU	531.00	531.00	531.00	531.00	531.00

TIME	104.000	PCTL	9.55774	TCOUT	531.000	EFFH	6.70862	FFFC	4.47440
------	---------	------	---------	-------	---------	------	---------	------	---------

PRECEDING PAGE BLANK NOT FILLED

MARTIN  
StandardU  
No

D-4

LTW20	7.4415	LTC22	2.01364	LYH20	4.93378	LZH2	2.61036	LXC22	1.79525	LYHC	2.217561
-------	--------	-------	---------	-------	---------	------	---------	-------	---------	------	----------

CR-115568  
SWIR-6840

AT PCT ADSORBED BY NODES

LXCU	2.0121	2.0230	2.0234	2.0148	1.9949
LYH20	7.6500	7.6461	7.5411	7.4929	7.3346

FLOW RATE (LB-MILES/HRI) BETWEEN NODES

CO2	-0.76982E-04	-0.45150E-04	-0.14598E-04	0.15505E-04	0.45828E-04	0.77210E-04
H2O	-0.34503E-03	-0.19953E-03	-0.63865E-04	0.67833E-04	0.20007E-03	0.33871E-03
TOTAL	-0.42202E-03	-0.24468E-03	-0.78463E-04	0.83338E-04	0.24590E-03	0.41592E-03

RATE OF ADSORPTION (LB-MILES/HRI) BY NODES

CO2	-0.31701E-04	-0.30381E-04	-0.29918E-04	-0.30150E-04	-0.31250E-04
H2O	-0.14528E-03	-0.13537E-03	-0.13135E-03	-0.13145E-03	-0.13842E-03
TOTAL	-0.17449E-03	-0.18575E-03	-0.16131E-03	-0.16210E-03	-0.16967E-03

PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.18241E-02	0.35801	0.45621	0.46028	0.45907	0.36250	0.18552E-02
H2O	0.81756E-02	1.6083	2.0162	2.1276	2.0043	1.5904	0.81437E-02
TOTAL	0.10000E-01	1.9671	2.4724	2.6136	2.4634	1.9528	0.10000E-01

TEMPERATURES (DEG F)

WAS	530.00	530.00	530.00	530.00	530.00
SED	531.00	531.00	531.00	531.00	531.00

PREPARED BY  
J. J. J. J.

PC

TIME	106.000	PLTL	8.69049	TCOUT	531.000	EFFH	4.90273	EFFC	3.82447
LTH2U	6.97525	LTCD2	1.71525	LYH2U	4.43441	LZH2	2.53594	LXC02	1.54248
								LYHC	5.172748

## WT PCT ADSORBED BY NODES

LXC02	1.7029	1.7279	1.7332	1.7220	1.6903
LYH2U	7.0497	7.0823	7.0441	6.9432	6.7569

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.50141E-04	-0.35155E-04	-0.11349E-04	0.12060E-04	0.35684E-04	0.60311E-04
H2U	-0.29603E-03	-0.17090E-03	-0.54665E-04	0.58087E-04	0.17143E-03	0.29067E-03
TOTAL	-0.35617E-03	-0.20606E-03	-0.66014E-04	0.70147E-04	0.20711E-03	0.35098E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.24888E-04	-0.23677E-04	-0.23270E-04	-0.23494E-04	-0.24528E-04
H2U	-0.12492E-03	-0.11597E-03	-0.11247E-03	-0.11308E-03	-0.11905E-03
TOTAL	-0.14981E-03	-0.13965E-03	-0.13574E-03	-0.13657E-03	-0.14357E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.16885E-02	0.30513	0.36735	0.41260	0.38973	0.30825	0.17183E-02
H2U	0.83115E-02	1.5020	1.6831	1.9875	1.8724	1.4857	0.82817E-02
TOTAL	0.10000E-01	1.5672	2.2705	2.4001	2.2621	1.7940	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BEU	531.00	531.00	531.00	531.00	531.00

TIME	108.000	PLTL	7.96423	TCOUT	531.000	EFFH	4.25887	EFFC	3.30750
LTH2U	6.46484	LTCD2	1.47939	LYH2U	4.02119	LZH2	2.46365	LXC02	1.34227
								LYHC	5.137117

## WT PCT ADSORBED BY NODES

LXC02	1.4578	1.4950	1.5044	1.4910	1.4487
LYH2U	6.5263	6.5968	6.5733	6.4698	6.2580

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.48061E-04	-0.28066E-04	-0.90573E-05	0.96254E-05	0.28490E-04	0.48204E-04
H2U	-0.25638E-03	-0.14791E-03	-0.47302E-04	0.50269E-04	0.14839E-03	0.25179E-03
TOTAL	-0.30444E-03	-0.17597E-03	-0.56359E-04	0.59894E-04	0.17688E-03	0.29999E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.19917E-04	-0.18908E-04	-0.18575E-04	-0.18763E-04	-0.19634E-04
H2U	-0.10629E-03	-0.10037E-03	-0.97318E-04	-0.97890E-04	-0.10322E-03
TOTAL	-0.12621E-03	-0.11928E-03	-0.11589E-03	-0.11665E-03	-0.12285E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.15767E-02	0.26375	0.33473	0.35651	0.33679	0.26649	0.16067E-02
H2U	0.84213E-02	1.4070	1.7641	1.8620	1.7543	1.3921	0.83933E-02
TOTAL	0.10000E-01	1.6708	2.0988	2.2185	2.0911	1.6585	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BEU	531.00	531.00	531.00	531.00	531.00

Hamilton  
StandardU  
A

CR-115568  
SWISS-6040

TIME	110.000	PCTL	7.34746	TCOUT	531.000	EFFH	3.73456	EFFC	2.8835
LTH20	6.05830	LTCU2	1.28916	LYH20	3.66460	LZH2	2.39371	LXC02	1.18734
								LYHC	0.109917

# WT PCT ADSORBED BY NODES

LXC02	1.2602	1.3073	1.3199	1.3046	1.2538
LYH20	6.0708	6.1747	6.1640	6.0581	5.8239

# FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.3904E-04	-0.22844E-04	-0.73750E-05	0.78368E-05	0.23193E-04	0.39221E-04
H20	-0.22393E-03	-0.12919E-03	-0.41326E-04	0.43914E-04	0.12964E-03	0.21996E-03
TOTAL	-0.26302E-03	-0.15204E-03	-0.48701E-04	0.51751E-04	0.15283E-03	0.25918E-03

# RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.16180E-04	-0.15388E-04	-0.15125E-04	-0.15274E-04	-0.15964E-04
H20	-0.94269E-04	-0.87654E-04	-0.85015E-04	-0.85514E-04	-0.90153E-04
TOTAL	-0.11076E-03	-0.10304E-03	-0.10014E-03	-0.10079E-03	-0.10612E-03

# PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.14863E-02	0.23082	0.29311	0.31226	0.29495	0.23328	0.15132E-02
H20	0.85137E-02	1.5222	1.6577	1.7449	1.6487	1.3083	0.84868E-02
TOTAL	0.10000E-01	1.5530	1.9509	2.0621	1.9437	1.5416	0.10000E-01

# TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BEU	531.00	531.00	531.00	531.00	531.00

TIME	112.000	PCTL	6.61758	TCOUT	531.000	EFFH	3.30120	EFFC	2.54385
LTH20	5.68431	LTCU2	1.13327	LYH20	3.35836	LZH2	2.32594	LXC02	1.04688
								LYHC	0.863919E-01

# WT PCT ADSORBED BY NODES

LXC02	1.0985	1.1533	1.1685	1.1518	1.0943
LYH20	5.6717	5.8046	5.8049	5.6969	5.4434

# FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.32263E-04	-0.18887E-04	-0.61033E-05	0.64839E-05	0.19179E-04	0.32381E-04
H20	-0.19709E-03	-0.11379E-03	-0.36420E-04	0.38691E-04	0.11420E-03	0.19363E-03
TOTAL	-0.22936E-03	-0.13268E-03	-0.42523E-04	0.45175E-04	0.13338E-03	0.22601E-03

# RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.13324E-04	-0.12717E-04	-0.12516E-04	-0.12628E-04	-0.13149E-04
H20	-0.83154E-04	-0.77181E-04	-0.74907E-04	-0.75317E-04	-0.79281E-04
TOTAL	-0.96478E-04	-0.89898E-04	-0.87423E-04	-0.87944E-04	-0.92431E-04

# PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.14067E-02	0.20399	0.25935	0.27643	0.26102	0.20624	0.14327E-02
H20	0.85933E-02	1.2462	1.5626	1.6496	1.5543	1.2333	0.85673E-02
TOTAL	0.10000E-01	1.4502	1.8220	1.9260	1.8153	1.4396	0.10000E-01

# TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BEU	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard



TIME	114.000	PCIL	6.35782	TCOUT	531.000	EFFH	2.93368	EFFC	2.25680
LYH20	5.35395	LICU2	1.00387	LYH20	3.09366	LZH2	2.26029	LXCJ2	3.935232
								LYHC	3.686199E-01

## WT PCT ADSORBED BY NODES

LXCJ2	0.96478	1.0253	1.0424	1.0246	0.96227
LYH20	5.3147	5.4775	5.4872	5.3776	5.1077

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.26953E-04	-0.15821E-04	-0.51195E-05	0.54371E-05	0.16070E-04	0.27065E-04
H2O	-0.17470E-03	-0.10098E-03	-0.32345E-04	0.34352E-04	0.10135E-03	0.17165E-03
TOTAL	-0.20165E-03	-0.11681E-03	-0.37465E-04	0.39789E-04	0.11742E-03	0.19871E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.11148E-04	-0.10646E-04	-0.10497E-04	-0.10576E-04	-0.10951E-04
H2O	-0.73580E-04	-0.68467E-04	-0.66513E-04	-0.66829E-04	-0.70160E-04
TOTAL	-0.84608E-04	-0.79113E-04	-0.77010E-04	-0.77406E-04	-0.81111E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.13360E-02	0.18175	0.23145	0.24686	0.23300	0.18385	0.13620E-02
H2O	0.86634E-02	1.1781	1.4774	1.5597	1.4696	1.1660	0.86380E-02
TOTAL	0.10010E-01	1.3598	1.7088	1.8065	1.7026	1.3499	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SED	531.00	531.00	531.00	531.00	531.00

TIME	116.000	PCIL	5.95535	TCOUT	531.000	EFFH	2.63208	EFFC	2.01505
LYH20	5.06018	LICU2	0.895177	LYH20	2.86348	LZH2	2.19669	LXCJ2	3.840578
								LYHC	0.545996E-01

## WT PCT ADSORBED BY NODES

LXCJ2	0.85296	0.91756	0.93602	0.91756	0.85178
LYH20	5.0073	5.1863	5.2042	5.0934	4.8098

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.22755E-04	-0.13402E-04	-0.43436E-05	0.46114E-05	0.13616E-04	0.22862E-04
H2O	-0.15585E-03	-0.90232E-04	-0.28928E-04	0.30711E-04	0.90566E-04	0.15314E-03
TOTAL	-0.17860E-03	-0.10363E-03	-0.33271E-04	0.35323E-04	0.10418E-03	0.17600E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.93154E-05	-0.90110E-05	-0.89046E-05	-0.89566E-05	-0.92083E-05
H2O	-0.63492E-04	-0.61148E-04	-0.59473E-04	-0.59699E-04	-0.62452E-04
TOTAL	-0.74807E-04	-0.70159E-04	-0.68378E-04	-0.68656E-04	-0.71660E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.12741E-02	0.16304	0.20803	0.22205	0.20947	0.16501	0.12989E-02
H2O	0.87259E-02	1.1167	1.4007	1.4738	1.3934	1.1054	0.87011E-02
TOTAL	0.10000E-01	1.2797	1.6087	1.7009	1.6029	1.2704	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SED	531.00	531.00	531.00	531.00	531.00

ORIGINAL PAGE IN  
OF POOR QUALITYHamilton  
StandardU  
A

D-46

TIME	118.000	PCTL	5.60028	TCOUT	531.000	EFFH	2.37033	EFFC	1.80948
LTH20	4.79732	LTCU2	0.802968	LYH20	2.66222	LZH2	2.13539	LXCO2	0.759475
								LYHC	0.434938E-01

WT PCT ADSORBED BY NODES

LXCO2	0.75862	0.82593	0.84536	0.82646	0.75848
LYH20	4.7284	4.9254	4.9503	4.8386	4.5439

FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.19388E-04	-0.11463E-04	-0.37217E-05	0.39498E-05	0.11649E-04	0.19490E-04
H2O	-0.13985E-03	-0.81127E-04	-0.26035E-04	0.27631E-04	0.81430E-04	0.13743E-03
TOTAL	-0.15924E-03	-0.92590E-04	-0.29757E-04	0.31581E-04	0.93079E-04	0.15692E-03

RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.78927E-05	-0.77004E-05	-0.76283E-05	-0.76580E-05	-0.78090E-05
H2O	-0.54613E-04	-0.54949E-04	-0.54516E-04	-0.53658E-04	-0.55895E-04
TOTAL	-0.66505E-04	-0.62650E-04	-0.61144E-04	-0.61316E-04	-0.63704E-04

PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.12175E-02	0.14712	0.18812	0.20096	0.18948	0.14898	0.12420E-02
H2O	0.87825E-02	1.0614	1.3315	1.4059	1.3246	1.0506	0.87580E-02
TOTAL	0.10000E-01	1.2084	1.5196	1.6069	1.5141	1.1996	0.10000E-01

TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
S&D	531.00	531.00	531.00	531.00	531.00

TIME	120.000	PCTL	5.28484	TCOUT	531.000	EFFH	2.14509	EFFC	1.63322
LTH20	4.56078	LTCU2	0.724062	LYH20	2.48534	LZH2	2.07544	LXCO2	0.689354
								LYHC	0.347577E-01

WT PCT ADSORBED BY NODES

LXCO2	0.67838	0.74729	0.76735	0.74823	0.67906
LYH20	4.4782	4.6903	4.7211	4.6090	4.3053

FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.16654E-04	-0.98879E-05	-0.32166E-05	0.34124E-05	0.10051E-04	0.16752E-04
H2O	-0.12618E-03	-0.73355E-04	-0.23568E-04	0.25032E-04	0.73632E-04	0.12401E-03
TOTAL	-0.14284E-03	-0.83243E-04	-0.26785E-04	0.28415E-04	0.83683E-04	0.14077E-03

RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.67364E-05	-0.66362E-05	-0.65915E-05	-0.66032E-05	-0.66732E-05
H2O	-0.52726E-04	-0.49658E-04	-0.48433E-04	-0.48501E-04	-0.50282E-04
TOTAL	-0.59464E-04	-0.56294E-04	-0.55025E-04	-0.55104E-04	-0.56955E-04

PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.11659E-02	0.13344	0.17102	0.18286	0.17230	0.13520	0.11900E-02
H2O	0.88340E-02	1.0110	1.2688	1.3399	1.2623	1.0009	0.88100E-02
TOTAL	0.10000E-01	1.1445	1.4398	1.5227	1.4346	1.1361	0.10000E-01

TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
S&D	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard

PC

TIME	122.000	PTIL	5.00282	TCOUT	531.000	EFFH	1.94987	EFFC	1.48796
LTH20	4.34661	LTCO2	0.656014	LYH20	2.32914	LZH2	2.01767	LXCO2	0.628260
								LYHC	0.277541E-01

## WT PCT ADSORBED BY NODES

LXCO2	0.60964	0.67926	0.69469	0.68052	0.61095
LYH20	4.2525	4.4773	4.5132	4.4009	4.0901

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.14411E-04	-0.85939E-05	-0.28012E-05	0.29706E-05	0.87380E-05	0.14505E-04
H2O	-0.11443E-03	-0.66673E-04	-0.21446E-04	0.22743E-04	0.66926E-04	0.11247E-03
TOTAL	-0.12884E-03	-0.75267E-04	-0.24247E-04	0.25713E-04	0.75664E-04	0.12697E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.57428E-05	-0.57621E-05	-0.57392E-05	-0.57366E-05	-0.57422E-05
H2O	-0.47659E-04	-0.45109E-04	-0.44064E-04	-0.44066E-04	-0.45449E-04
TOTAL	-0.53452E-04	-0.50871E-04	-0.49803E-04	-0.49802E-04	-0.51192E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.11185E-02	0.12158	0.15620	0.16717	0.15742	0.12326	0.11423E-02
H2O	0.88815E-02	0.90537	1.2119	1.2799	1.2057	0.95579	0.88577E-02
TOTAL	0.10000E-01	1.0869	1.3681	1.4470	1.3631	1.0791	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

TIME	124.000	PTIL	4.74922	TCOUT	531.000	EFFH	1.77953	EFFC	1.34851
LTH20	4.15230	LTCO2	0.596920	LYH20	2.19057	LZH2	1.96174	LXCO2	0.574673
								LYHC	0.222474E-01

## WT PCT ADSORBED BY NODES

LXCO2	0.55036	0.62000	0.64058	0.62150	0.55216
LYH20	4.0481	4.2833	4.3236	4.2114	3.8951

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.12553E-04	-0.75200E-05	-0.24561E-05	0.26038E-05	0.76482E-05	0.12642E-04
H2O	-0.10425E-03	-0.60889E-04	-0.19608E-04	0.20787E-04	0.61121E-04	0.10247E-03
TOTAL	-0.11680E-03	-0.68409E-04	-0.22064E-04	0.23391E-04	0.68769E-04	0.11511E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.50115E-05	-0.50370E-05	-0.50313E-05	-0.50174E-05	-0.49726E-05
H2O	-0.43274E-04	-0.41173E-04	-0.40281E-04	-0.40227E-04	-0.41267E-04
TOTAL	-0.48286E-04	-0.46210E-04	-0.45313E-04	-0.45244E-04	-0.46239E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.10747E-02	0.11122	0.14325	0.15346	0.14441	0.11283	0.10982E-02
H2O	0.89253E-02	0.92371	1.1600	1.2252	1.1541	0.91461	0.89018E-02
TOTAL	0.10000E-01	1.0349	1.3032	1.3786	1.2985	1.0274	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BLD	531.00	531.00	531.00	531.00	531.00

ORIGINAL PAGE IN  
OF POOR QUALITYHamilton  
StandardU  
P

TIME	126.000	PCTL	4.51998	TCOUT	531.000	EFFH	1.63306	EFFC	1.23266
LTH20	3.97471	LTCU2	0.545276	LYH20	2.06711	LZH2	1.90759	LXC02	0.527393
								LYHC	0.178328E-01

## WT PCT ADSORBED BY NODES

LXC02	0.49094	0.56803	0.58860	0.56973	0.50110
LYH20	3.8621	4.1058	4.1498	4.0380	3.7178

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.11000E-04	-0.66205E-05	-0.21668E-05	0.22962E-05	0.67353E-05	0.11086E-04
H20	-0.95385E-04	-0.55851E-04	-0.18007E-04	0.19083E-04	0.56055E-04	0.93770E-04
TOTAL	-0.10635E-04	-0.62471E-04	-0.20174E-04	0.21380E-04	0.62800E-04	0.10486E-03

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.43610E-05	-0.44300E-05	-0.44378E-05	-0.44152E-05	-0.43313E-05
H20	-0.39460E-04	-0.37744E-04	-0.35986E-04	-0.36883E-04	-0.37628E-04
TOTAL	-0.43821E-04	-0.42174E-04	-0.41423E-04	-0.41298E-04	-0.41959E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.10340E-02	0.10213	0.13187	0.14140	0.13298	0.10367	0.10572E-02
H20	0.89660E-02	0.88561	1.1125	1.1752	1.1069	0.87693	0.89478E-02
TOTAL	0.10000E-01	0.98774	1.2444	1.3166	1.2399	0.98059	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
RED	531.00	531.00	531.00	531.00	531.00

TIME	128.000	PCTL	4.31174	TCOUT	531.000	EFFH	1.49812	EFFC	1.13766
LTH20	3.81186	LTCU2	0.499882	LYH20	1.95667	LZH2	1.85519	LXC02	0.485462
								LYHC	0.144197E-01

## WT PCT ADSORBED BY NODES

LXC02	0.45404	0.52220	0.54262	0.52404	0.45650
LYH20	3.6921	3.9428	3.9900	3.8787	3.5557

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CU2	-0.96930E-05	-0.58609E-05	-0.19221E-05	0.20363E-05	0.59642E-05	0.97741E-05
H20	-0.87634E-04	-0.51437E-04	-0.16603E-04	0.17590E-04	0.51634E-04	0.86152E-04
TOTAL	-0.97327E-04	-0.57297E-04	-0.18525E-04	0.19626E-04	0.57598E-04	0.95926E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CU2	-0.38155E-05	-0.39177E-05	-0.39359E-05	-0.39067E-05	-0.37931E-05
H20	-0.36125E-04	-0.34742E-04	-0.34197E-04	-0.33954E-04	-0.34448E-04
TOTAL	-0.39441E-04	-0.38660E-04	-0.38033E-04	-0.37860E-04	-0.38240E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CU2	0.99592E-03	0.94086E-01	0.12180	0.13073	0.12286	0.95563E-01	0.10189E-02
H20	0.90041E-02	0.85066	1.0690	1.1293	1.0637	0.84235	0.89811E-02
TOTAL	0.10000E-01	0.94474	1.1908	1.2601	1.1865	0.93792	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
RED	531.00	531.00	531.00	531.00	531.00

TIME	130.000	PCTL	4.12172	TCOUT	531.000	EFFH	1.38113	EFFC	1.04751
LTH20	3.66196	LTCU2	0.459769	LYH20	1.85750	LZH2	1.80446	LXCO2	3.448101
								LYHC	0.115583E-01

## WT PCT ADSORBED BY NODES

LXCO2	0.41468	0.48157	0.50174	0.48351	0.41735
LYH20	3.5362	3.7925	3.8423	3.7318	3.4070

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.85644E-05	-0.52146E-05	-0.17136E-05	0.18149E-05	0.53080E-05	0.86615E-05
H2O	-0.60812E-04	-0.47548E-04	-0.15366E-04	0.16274E-04	0.47731E-04	0.79449E-04
TOTAL	-0.89396E-04	-0.52762E-04	-0.17079E-04	0.18089E-04	0.53039E-04	0.88111E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.33549E-05	-0.34822E-05	-0.35084E-05	-0.34742E-05	-0.33385E-05
H2O	-0.33197E-04	-0.32098E-04	-0.31551E-04	-0.31374E-04	-0.31652E-04
TOTAL	-0.36552E-04	-0.35581E-04	-0.35059E-04	-0.34848E-04	-0.34991E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.96026E-03	0.86943E-01	0.11284	0.12124	0.11386	0.88362E-01	0.98299E-03
H2O	0.90397E-02	0.81649	1.0289	1.0872	1.0238	0.81054	0.90170E-02
TOTAL	0.10000E-01	0.90544	1.1418	1.2064	1.1377	0.89890	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	132.000	PCTL	3.94763	TCOUT	531.000	EFFH	1.27692	EFFC	0.960312
LTH20	3.52346	LTCU2	0.424151	LYH20	1.76811	LZH2	1.75537	LXCO2	3.414572
								LYHC	0.947395E-02

## WT PCT ADSORBED BY NODES

LXCO2	0.37498	0.44537	0.46522	0.44738	0.38281
LYH20	3.3927	3.6533	3.7054	3.5958	3.2702

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.76381E-05	-0.46609E-05	-0.15347E-05	0.16249E-05	0.47457E-05	0.77113E-05
H2O	-0.74781E-04	-0.44105E-04	-0.14269E-04	0.15107E-04	0.44275E-04	0.73524E-04
TOTAL	-0.82419E-04	-0.48766E-04	-0.15803E-04	0.16732E-04	0.49021E-04	0.81235E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.29638E-05	-0.31094E-05	-0.31416E-05	-0.31038E-05	-0.29521E-05
H2O	-0.30614E-04	-0.29758E-04	-0.29294E-04	-0.29089E-04	-0.29187E-04
TOTAL	-0.33577E-04	-0.32867E-04	-0.32430E-04	-0.32193E-04	-0.32140E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.92674E-03	0.80568E-01	0.10483	0.11274	0.10580	0.81930E-01	0.94922E-03
H2O	0.90733E-02	0.78882	0.99199	1.0483	0.98712	0.78120	0.90508E-02
TOTAL	0.10000E-01	0.86939	1.0968	1.1610	1.0929	0.86313	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

ORIGINAL PAGE IS  
OF POOR QUALITYHamilton  
Standard

U

CR-115568  
SVHSR-6040

TIME	134.000	PLIL	3.78749	TCOUT	531.000	EFFH	1.18366	EFFC	0.888754
LTH20	3.39511	LTCO2	0.392383	LYH20	1.68725	LZH2	1.70797	LXCO2	0.386649
								LYHC	0.773375E-02

## WT PCT ADSORBED BY NODES

LXCO2	0.34926	0.41297	0.43244	0.41504	0.35220
LYH20	3.2601	3.5241	3.5781	3.4695	3.1438

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.68255E-05	-0.41837E-05	-0.13803E-05	0.14610E-05	0.42609E-05	0.68948E-05
H2O	-0.69425E-04	-0.41042E-04	-0.13292E-04	0.14069E-04	0.41200E-04	0.68261E-04
TOTAL	-0.76250E-04	-0.45225E-04	-0.14672E-04	0.15530E-04	0.45461E-04	0.75156E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.26298E-05	-0.27882E-05	-0.25250E-05	-0.27846E-05	-0.26218E-05
H2O	-0.28325E-04	-0.27677E-04	-0.27235E-04	-0.27058E-04	-0.27004E-04
TOTAL	-0.33955E-04	-0.30465E-04	-0.30110E-04	-0.29843E-04	-0.29626E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.89514E-03	0.74852E-01	0.97635E-01	0.10511	0.98572E-01	0.76161E-01	0.91737E-03
H2O	0.91049E-02	0.76137	0.95781	1.0123	0.95314	0.75405	0.90826E-02
TOTAL	0.10000E-01	0.83623	1.0554	1.1174	1.0517	0.83021	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	136.000	PLIL	3.63968	TCOUT	531.000	EFFH	1.09989	EFFC	0.824649
LTH20	3.27575	LTCO2	0.363929	LYH20	1.61385	LZH2	1.66190	LXCO2	0.357590
								LYHC	0.633972E-02

## WT PCT ADSORBED BY NODES

LXCO2	0.32195	0.38387	0.40291	0.39596	0.32496
LYH20	3.1373	3.4037	3.4594	3.3518	3.0266

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.61237E-05	-0.37700E-05	-0.12461E-05	0.13187E-05	0.38405E-05	0.61894E-05
H2O	-0.64647E-04	-0.38304E-04	-0.12418E-04	0.13141E-04	0.38452E-04	0.63567E-04
TOTAL	-0.70771E-04	-0.42074E-04	-0.13664E-04	0.14460E-04	0.42293E-04	0.69757E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.23429E-05	-0.25101E-05	-0.25501E-05	-0.25080E-05	-0.23380E-05
H2O	-0.26290E-04	-0.25818E-04	-0.25488E-04	-0.25243E-04	-0.25062E-04
TOTAL	-0.28533E-04	-0.28328E-04	-0.26038E-04	-0.27751E-04	-0.27400E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.86528E-03	0.69707E-01	0.91148E-01	0.98223E-01	0.92049E-01	0.70966E-01	0.88726E-03
H2O	0.91347E-02	0.73592	0.92612	0.97887	0.92163	0.72887	0.91127E-02
TOTAL	0.10000E-01	0.80563	1.0173	1.0771	1.0137	0.79983	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard

U

TIME	138.000	PCTL	3.50278	TCOUT	531.000	EFFH	1.02441	EFFC	0.766362
LYH20	3.16444	LXC02	0.338347	LYH20	1.54701	LZHZ	1.61742	LXC02	0.333124
		LYHC							0.522362E-02

## WT PCT ADSORBED BY NODES

LXC02	0.29757	0.35761	0.37621	0.35972	0.30062
LYH20	0.0230	0.2913	0.3443	0.2418	0.29177

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.55145E-05	-0.34093E-05	-0.11290E-05	0.11944E-05	0.34740E-05	0.55767E-05
H2O	-0.60368E-04	-0.35848E-04	-0.11633E-04	0.12307E-04	0.35985E-04	0.59363E-04
TOTAL	-0.65884E-04	-0.39254E-04	-0.12742E-04	0.13502E-04	0.39459E-04	0.64940E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.20953E-05	-0.22678E-05	-0.23101E-05	-0.22670E-05	-0.20928E-05
H2O	-0.24472E-04	-0.24150E-04	-0.23874E-04	-0.23615E-04	-0.23328E-04
TOTAL	-0.26567E-04	-0.26418E-04	-0.26134E-04	-0.25882E-04	-0.25421E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.83701E-03	0.65060E-01	0.85276E-01	0.91985E-01	0.86142E-01	0.66271E-01	0.85873E-03
H2O	0.91630E-02	0.71225	0.89665	0.94742	0.89232	0.70545	0.91413E-02
TOTAL	0.10000E-01	0.77731	0.98192	1.0398	0.97846	0.77173	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	140.000	PCTL	3.37561	TCOUT	531.000	EFFH	0.956102	EFFC	0.714836
LYH20	3.06035	LXC02	0.315265	LYH20	1.48595	LZHZ	1.57440	LXC02	0.310937
		LYHC							0.432777E-02

## WT PCT ADSORBED BY NODES

LXC02	0.27573	0.33386	0.35197	0.33597	0.27879
LYH20	2.9166	3.1860	3.2441	3.1388	2.8162

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.49830E-05	-0.30934E-05	-0.10262E-05	0.10855E-05	0.31529E-05	0.50420E-05
H2O	-0.56521E-04	-0.33632E-04	-0.10925E-04	0.11555E-04	0.33762E-04	0.55583E-04
TOTAL	-0.61504E-04	-0.36725E-04	-0.11951E-04	0.12641E-04	0.36915E-04	0.60625E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.18807E-05	-0.20558E-05	-0.20996E-05	-0.20560E-05	-0.18801E-05
H2O	-0.22843E-04	-0.22648E-04	-0.22418E-04	-0.22148E-04	-0.21774E-04
TOTAL	-0.24724E-04	-0.24704E-04	-0.24517E-04	-0.24204E-04	-0.23654E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.81019E-03	0.60847E-01	0.79942E-01	0.86315E-01	0.80776E-01	0.62013E-01	0.83156E-03
H2O	0.91898E-02	0.64020	0.86917	0.91838	0.86500	0.68364	0.91683E-02
TOTAL	0.10000E-01	0.75104	0.94912	1.0052	0.94578	0.74566	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

CR-115568  
SVHSER-6040

TIME	142.000	PCIL	3.25712	TCOUT	531.000	EFFH	0.894130	EFFC	0.667539
LTH20	2.96276	LTCO2	0.294368	LYH20	1.42999	LZH2	1.53277	LXCO2	0.290761
								LYHC	0.360571E-02

## WT PCT ADSORBED BY NODES

LXCO2	0.25609	0.31229	0.32992	0.31439	0.25915
LYH20	2.8170	3.0871	3.1462	3.0421	2.7214

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	-0.45173E-05	-0.28154E-05	-0.93566E-06	0.98942E-06	0.28702E-05	0.45732E-05
H2O	-0.53050E-04	-0.31628E-04	-0.10283E-04	0.10874E-04	0.31751E-04	0.52171E-04
TOTAL	-0.57567E-04	-0.34444E-04	-0.11219E-04	0.11864E-04	0.34622E-04	0.56744E-04

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.16936E-05	-0.18693E-05	-0.19140E-05	-0.18704E-05	-0.16947E-05
H2O	-0.21377E-04	-0.21290E-04	-0.21094E-04	-0.20822E-04	-0.20376E-04
TOTAL	-0.23071E-04	-0.23159E-04	-0.23013E-04	-0.22693E-04	-0.22071E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	0.76471E-03	0.57016E-01	0.75082E-01	0.81143E-01	0.75885E-01	0.58139E-01	0.80591E-03
H2O	0.92153E-02	0.66959	0.84350	0.89183	0.83948	0.66326	0.91941E-02
TOTAL	0.10000E-01	0.72661	0.91859	0.97297	0.91536	0.72140	0.10000E-01

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	142.008	PCIL	3.25663	TCOUT	531.000	EFFH	0.893763	EFFC	0.667356
LTH20	2.96235	LTCO2	0.294282	LYH20	1.42976	LZH2	1.53259	LXCO2	0.290679
								LYHC	0.360392E-02

## WT PCT ADSORBED BY NODES

LXCO2	0.25602	0.31217	0.32984	0.31431	0.25908
LYH20	2.8167	3.0865	3.1458	3.0418	2.7210

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67592E-03	0.68162E-03	0.68443E-03	0.68635E-03	0.68822E-03	0.68991E-03
H2O	0.13734E-02	0.13948E-02	0.14264E-02	0.14475E-02	0.14684E-02	0.14887E-02
TOTAL	0.20534E-02	0.20764E-02	0.21109E-02	0.21339E-02	0.21566E-02	0.21786E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	-0.16931E-05	-0.28154E-05	-0.19133E-05	-0.18697E-05	-0.16940E-05
H2O	-0.21372E-04	-0.31628E-04	-0.21094E-04	-0.20817E-04	-0.20371E-04
TOTAL	-0.23065E-04	-0.34444E-04	-0.23007E-04	-0.22687E-04	-0.22065E-04

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	0.57016E-01	0.75082E-01	0.81143E-01	0.75885E-01	0.58139E-01	5.0734
H2O	10.100	0.66959	0.84350	0.89183	0.83948	0.66326	10.948
TOTAL	15.100	0.72661	0.91859	0.97297	0.91536	0.72140	16.021

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00

TIME	144.000	PCIL	5.17910	TCOUT	531.000	EFFH	3.89125	EFFC	2.22310
------	---------	------	---------	-------	---------	------	---------	------	---------

Hamilton  
Standard  
No.



LTH20	3.84658	LYC02	1.33253	LYH20	2.23273	LZH2	1.61385	LXC02	1.31533	LYHC	0.171970E-C1
-------	---------	-------	---------	-------	---------	------	---------	-------	---------	------	--------------

# HI PCT ADSORBED BY NODES

LXC02	1.6573	1.5103	1.3479	1.1724	0.97476
LYH20	4.3400	4.1567	3.9217	3.6265	3.1880

CR-115568  
SWISER-6040

# FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.61469E-03	0.54268E-03	0.46676E-03	0.39028E-03	0.31584E-03
H2O	0.13734E-02	0.10863E-02	0.86529E-03	0.69341E-03	0.55738E-03	0.44407E-03
TOTAL	0.20534E-02	0.17010E-02	0.14080E-02	0.11602E-02	0.94767E-03	0.75991E-03

# RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.65232E-04	0.72009E-04	0.75921E-04	0.76478E-04	0.74448E-04
H2O	0.28718E-03	0.22098E-03	0.17187E-03	0.13603E-03	0.11331E-03
TOTAL	0.35242E-03	0.29299E-03	0.24779E-03	0.21251E-03	0.18776E-03

# PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.7584	4.2521	3.7065	3.1450	2.5895	2.3226
H2O	10.100	9.0427	7.1723	5.7273	4.5952	3.6788	3.2656
TOTAL	15.100	13.802	11.424	9.4337	7.7402	6.2684	5.5882

# TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
SEA	531.00	531.00	531.00	531.00	531.00

Hamilton  
Standard  
No. 11

TIME	146.000	PLIL	6.52321	TCOUT	531.000			EFFH	5.34057	EFFC	4.01804
LTH20	4.63146	LTC02	1.89176	LYH20	2.92543	LZH2	1.70603	LXC02	1.85143	LYHC	0.403343E-01

## WT PLT ADSORBED BY NODES

LXC02	2.0620	1.9969	1.9145	1.8104	1.6750
LYH20	5.4376	5.0651	4.6735	4.2526	3.7285

## FLOW RATE (LB-MOLES/MIN) BETWEEN NODES

CO2	0.67992E-03	0.66132E-03	0.63723E-03	0.60650E-03	0.56806E-03	0.52074E-03
H2O	0.13734E-02	0.11681E-02	0.98533E-03	0.82467E-03	0.68422E-03	0.55869E-03
TOTAL	0.20544E-02	0.18294E-02	0.16226E-02	0.14317E-02	0.12523E-02	0.10794E-02

## RATE OF ADSORPTION (LB-MOLES/MIN) BY NODES

CO2	0.18606E-04	0.24692E-04	0.30727E-04	0.34434E-04	0.47321E-04
H2O	0.20537E-03	0.18275E-03	0.15066E-03	0.14045E-03	0.12553E-03
TOTAL	0.22398E-03	0.20684E-03	0.19139E-03	0.17888E-03	0.17285E-03

## PRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)

CO2	5.0000	4.5313	4.7736	4.5711	4.3159	3.9995	3.8294
H2O	10.100	9.3439	7.9153	6.6518	5.5444	4.5665	4.1085
TOTAL	15.100	14.275	12.689	11.223	9.8603	8.5661	7.9379

## TEMPERATURES (DEG F)

GAS	530.00	530.00	530.00	530.00	530.00
BED	531.00	531.00	531.00	531.00	531.00


Hamilton  
StandardU  
No

TOTAL BED LOADING

CR-115568  
SWISER-604

MINIMUM X= 0.0 Y= 0.0  
SCALE/INCH X= 1.2257022E 01 Y= 1.1734705E 00

MAXIMUM X= 1.4463281E 02 Y= 1.0561470E 01  
+OR- TOLERANCE/POINT X= 6.1284067E-01 Y= 9.7791374E-32



Hamilton  
Standard

TOTAL H2O LOADING

MINIMUM X= 0.0

Y= 0.0

MAXIMUM

X= 1.4463281E 02

Y= 8.1620941E 01

SCALE/INCH


X= 1.2257022E 01

Y= 9.0765721E-01

+OR- TOLERANCE/POINT

X= 6.1285067E-01

Y= 7.5639721E-02


Hamilton  
StandardU  
A

TOTAL CO2 LOADING

CR-115568  
SWISER-60

MINIMUM X= 0.0 Y= 0.0  
SCALE/INCH X= 1.2257022E 01 Y= 2.6581454E-01


MAXIMUM X= 1.4463281E 02 Y= 2.3923936E 01  
+OR- TOLERANCE/POINT X= 6.1285667E-01 Y= 2.2151697E-02



ORIGINAL PAGE IS  
OF POOR QUALITY

Maximum  
Standard Dev.

OUTLET PARTIAL PRESSURE OF H<sub>2</sub>OCR-115568  
SWISER-604
 MINIMUM X= 0.0 Y= 0.0  
 SCALE/INCH X= 1.2257022E 01 Y= 1.0669365E 00

 MAXIMUM X= 1.4463281E 02 Y= 9.6526411E 00  
 +OR- TOLERANCE/POINT X= 6.128567E-01 Y= 8.8913321E-01
Hamilton  
Standard


DC

OUTLET PARTIAL PRESSURE OF CO2

CR-115568  
SVHSR-604

MINIMUM X= 0.0 Y= 0.0  
SCALE/INCH X= 1.2257022E-01 Y= 5.5344242E-01

MAXIMUM X= 1.4463281E-02 Y= 4.7017715E-02  
TOLERANCE/POINT X= 6.1285067E-01 Y= 4.512127E-02



09-U

OUTLET COLLANT TEMPERATURE

CR-115568  
SVHSER-6040

MINIMUM A= C.C Y=-5.3100000E 02  
SCALE/INCH X= 1.2257022E 01 Y= 1.7699611E 02

MAXIMUM X= 1.4463281E 02 Y= 1.0473000E 03  
+OR- TOLERANCE/POINT X= 6.1285067E-01 Y= 1.4750000E 01

1.06E 03 +

9.44E 02 +

7.97E 02 +

6.49E 02 +

5.02E 02 +

3.54E 02 +

2.07E 02 +

5.90E 01 +

-8.85E 01 +

-2.36E 02 +

-3.84E 02 +

-5.31E 02 +

1.77E 01

3.43E 01

5.15E 01

6.86E 01

8.58E 01

1.03E 02

1.25E 02

1.37E 02

Hammikon  
Standard  
A



CR-115568  
SVHSR-6040

OUTLET PROCESS GAS TEMPERATURE

MINIMUM	X= 0.0	Y=-5.300000E 02	MAXIMUM	X= 1.4463281E 02	Y= 1.060000E 03
SCALE/INCH	X= 1.2257022E 01	Y= 1.7666278E 02	FOR TOLERANCE/POINT	X= 6.1285067E-01	Y= 1.4722271E 01

1.06E 03 +

9.42E 02 +

7.95E 02 +

6.48E 02 +

5.01E 02 +

3.53E 02 +

2.06E 02 +

5.69E 01 +

-8.83E 01 +

-2.36E 02 +

-3.83E 02 +

ORIGINAL PAGE IN  
OF POOR QUALITY

Hamilton  
Standard  
U  
No.

```

C HSC DISTRIBUTIVE MODEL - PHASE 3 00000010
C UPDATED AUGUST 1971 TO INCLUDE: 00000020
C 1. VACUUM DESORPTION CAPABILITIES 00000030
C 2. NONISOTHERMAL PERFORMANCE CAPABILITIES 00000040
0001 REAL KY, KXR, KY, KYH, KYHR, X7 00000050
X KZR, ICXC, ICYH, ICZC, ICYHC, MZT, MH2O, MC02, 00000060
X MH2O2, IC02, LYH2O, LZHZ, LTH2O, LTC02, LYHC, 00000070
X MZ, MTI2O, ISGT, IDES 00000080
0002 DIMENSION C(200), HOL( 23), PC02(100), PH2O(100), 00000090
X DM(100), DMH(100), XCU2(100), VH2O(100), YH2O(100), 00000100
X ZH2O(100), 00000110
X XR(100), YR(100), YHCR(100), ZR(100), 00000120
X DH2O(100), PHOUT(100), 00000130
X DMH0(100), DCU2(100), PCOUT(100), DMCO(100) 00000140
0003 DIMENSION 00000150
X PLTIME(500), PLPCT(1500), PLPHNT(500), PLPCDT(500) 00000160
0004 DIMENSION PLMXC(500), PLMYC(500), PLMYH(500), PLW/H2(500) 00000170
0005 DIMENSION APH2O(100), APC02(100), CON(17), C(4) 00000180
0006 DIMENSION WAIR(100), QR(100), TR(100), TG(100), CNI(16), 00000190
X TK(120), THB(20), TWC(20), HX(20) 00000200
C PROGRAM CONTROL CONSTANTS 00000210
0007 EQUIVALENCE (DI1),DT ), (DI2),TMAX ), 00000220
X (DI3),PRINT ), (DI4),PICT ), (DI5),EX ), 00000230
X (DI6),AIND ), (DI7),IDES ), (DI8),ISOT ), 00000240
X (DI9),XJ ) 00000250
C INITIAL CONDITIONS 00000260
0008 EQUIVALENCE (DI11),ICXC ), (DI12),ICYH ), 00000270
X (DI13),ICZC ), (DI14),ICYHC ), (DI15),PIH2O ), 00000280
X (DI16),PIC02 ) 00000290
C PROGRAM CONSTANTS 00000300
0009 EQUIVALENCE (DI21),XOI ), (DI22),YHI ), 00000310
X (DI23),ZUL ), (DI24),KX ), (DI25),KXR ), 00000320
X (DI26),KY ), (DI27),KYP ), (DI28),KYH ), 00000330
X (DI29),KYHR ), (DI30),KZ ), (DI31),KZR ), 00000340
X (DI32),MZT ), (DI33),PAIR ), (DI34),O ), 00000350
X (DI35),TCIN ), (DI36),TGI ), (DI37),PIN ), 00000360
X (DI38),PDUT ), (DI39),ADSORB ), (DI40),DESORB ), 00000370
X (DI41),C(1) ), (DI45),WCTOT ), (DI46),CNI(1) ) 00000380
0010 EQUIVALENCE (DI101),TK(111), (DI121),THB(11), 00000390
X (DI141),TWC(11), (DI161),HX(11), (DI62),PRLAST) 00000400
X, (DI64),A), (DI66),EPS) 00000401
0011 DIMENSION PCAVG(100), PHAVG(100) 00000402
0012 DIMENSION GMD(100), GMDH(100), PI(100), IFAC(100) 00000403
0013 COMMON/BLOCK3 /PCAVG,PHAVG 00000404
0014 COMMON/OUTPUT/PI, FACTH, FACTC 00000405
0015 COMMON/BLOCK1/XR,YR,YHCR,ZR 00000410
0016 COMMON/BLOCK2/CON 00000420
C SET DATA ARRAY TO ZERO 00000430
0017 DO 1 I=1,200 00000440
0018 1 D(I) = 0. 00000450
0019 10 CALL BEGIN(HOL) 00000460
0020 WRITE(6,1020) HOL 00000470
0021 1020 FORMAT(1H1, 2CA4) 00000480
0022 CALL LOAD(D) 00000490
C SET PROGRAM CONSTANTS 00000500
0023 NJ = XJ 00000510

```

```

0024      DTP = DT/NJ          00000522
0025      INC = AIND          00000530
0026      R = 555.            00000542
0027      MCO2 = 44.          00000550
0028      MH2O = 18.          00000560
0029      TIME=0.             00000570
0030      K=C                  00000580
0031      NPRINT=PRINT         00000590
0032      NPLUT = (TMAX/DT + 1.1)/100 + 1 00000600
0033      K=G                  00000610
0034      KK = 0               00000620
0035      N=FN                 00000630
0036      MZ = MZI/FN          00000640
C      PRINT INPUT           00000650
0037      WRITE(6,1000) DT , TMAX , PRINT , PLUT , FN , AIND ,
X IDCS , ISOT , XJ , ICXC , ICYH , ICZC , ICYHC , PIH2O ,
X PIC02 , XOL , YOL , ZOL , KY , KXR , KY , KYP ,
X KYH , KYHR , KZ , KZR , MZT , PAIR , Q , TCIN 00000660
0038      WRITE(6,1016)
X TGI , PIN , POUT , ADSORB , DESORB , D(41) , D(42) , D(43) ,
X WCTOT , D(44) , D(47) , D(48) , D(49) , D(50) , D(51) ,
X D(52) , D(53) , D(54) , D(55) , D(56) , D(57) , D(58) , D(59) ,
X D(60) , D(61) , D(62) 00000670
X , A , EPS 00000680
0039      1000 FORMAT(10INPUT, 72X,
X 8H DT ,G12.6,8H TMAX ,G12.6,8H PRINT ,G12.6,
X 8H PLUT ,G12.6,8H FN ,G12.6,8H INC ,G12.6/2X,
X 8H IDCS ,G12.6,8H ISOT ,G12.6,8H XJ ,G12.6,
X 8H ICXC ,G12.6,8H ICYH ,G12.6,8H ICZC ,G12.6/2X,
X 8H ICYHC ,G12.6,8H PIH2O ,G12.6,
X 8H XOL ,G12.6,8H YOL ,G12.6,8H ZOL ,G12.6/2X,
X 8H KY ,G12.6,8H KXR ,G12.6,8H KY ,G12.6,
X 8H KYP ,G12.6,8H KYH ,G12.6,8H KYHR ,G12.6/2X,
X 8H KZ ,G12.6,8H KZR ,G12.6,8H MZT ,G12.6,
X 8H PAIR ,G12.6,8H Q ,G12.6,8H TCIN ,G12.6/1) 00000690
0040      1016 FORMAT (2X,
X 8H TGI ,G12.6,8H PIN ,G12.6,8H POUT ,G12.6,
X 8H ADSORB ,G12.6,8H DESORB ,G12.6,8H VB ,G12.6/2X,
X 8H WCTOT ,G12.6,8H D(44) ,G12.6,
X 8H D(47) ,G12.6,8H D(48) ,G12.6/2X,
X 8H D(49) ,G12.6,8H D(50) ,G12.6,
X 8H D(51) ,G12.6,8H D(52) ,G12.6,8H D(53) ,G12.6,
X 8H D(54) ,G12.6,8H D(55) ,G12.6,8H D(56) ,G12.6/2X,
X 8H D(57) ,G12.6,8H D(58) ,G12.6,8H D(59) ,G12.6/2X,
X 8H D(60) ,G12.6,8H D(61) ,G12.6,8H D(62) ,G12.6/2X,
X ,G12.6/1) 00000700
C      SET DATA ARRAY FOR AMHSC 00000710
0041      DO 12 I=1,12 00000720
0042      CON(I) = D(20+I) 00000730
0043      12 CONTINUE 00000740
C      SET INITIAL CONDITIONS 00000750
0044      IF(IIND)15,15,13 00000760
0045      13 DO 14 J=1,100 00000770
C      INITIAL CONDITION FOR DESORPTION 00000780
0046      WAIR(1) = (PAIR*Q/(R*TGI))*2R. 00000790
0047      XR(1) = 0. 00000800

```

```

0048      YR(1) = 0.                                00001060
0049      YHCR(1) = 0.                              00001070
0050      ZR(1) = 0.                                00001080
0051      DMH0(1) = 0.                              00001090
0052      DCO2(1) = 0.                              00001100
0053      DMC0(1) = 0.                              00001110
0054      DH20(1) = 0.                              00001120
0055      PCO2(1) = PICO2                            00001130
0056      PH20(1) = PIH20                            00001140
0057      PHOUT(1) = PIH20                           00001150
0058      PCOUT(1) = PICO2                           00001160
0059      DMC(1) = 0.                                00001170
0060      DMH(1) = 0.                                00001180
0061      TG(1) = TGI                                 00001190
0062      TB(1) = TCIN                               00001200
0063      14 CONTINUE                                00001210
0064      TCCUT = TCIN                                00001220
0065      TCCUTL = TCIN                               00001230
0066      IF(ISHUT)17,17,22                          00001240
0067      22 DO 18 I=1,N                             00001250
0068      18 CALL TEMPL(I,DT,TIME,N,KK,CN1,TX1,T4B,TWC,HX,JCYOT,TCIN,WAIR,DMC3, 00001260
           X      DMH0,TG,TB,TCCUT)                  00001270
0069      DIFC = ABS(TCCUT-TCCUTL)                   00001280
0070      TCCUTL = TCCUT                              00001290
0071      IF(DIFC-1,121,21,19)                       00001300
0072      19 KK = KK + 1                              00001310
0073      IF(KK .LT. 100) GO TO 22                   00001320
0074      WRITE(6,1013)                               00001330
0075      21 WAIR(1) = 0.                             00001340
0076      GO TO 17                                    00001350
0077      15 DO 16 I=1,100                           00001360
           C INITIAL CONDITION FOR ADSORPTION      00001370
0078      RCAVG(1)=0.                                00001371
0079      RHAVG(1)=0.                                00001372
0080      WAIR(1) = (PAIR*Q/(R+TG(1))*28.            00001380
0081      XR(1) = 0.                                  00001390
0082      YR(1) = 0.                                  00001400
0083      YHCR(1) = 0.                               00001410
0084      ZR(1) = 0.                                  00001420
0085      DMH0(1) = 0.                               00001430
0086      DCO2(1) = 0.                               00001440
0087      DMC0(1) = 0.                               00001450
0088      DH20(1) = 0.                               00001460
0089      PHOUT(1) = 0.                               00001470
0090      PCOUT(1) = 0.                               00001480
0091      PCO2(1) = 0.                               00001490
0092      DMC(1) = 0.                                00001500
0093      DMH(1) = 0.                                00001510
0094      TG(1) = TGI                                 00001520
0095      TB(1) = TCIN                               00001530
0096      16 PH20(1) = 0.                             00001540
0097      PIAC=POUT*(PICO2/(PICO2+PIH20))            00001541
0098      PIAT=POUT-PIAC                              00001542
0099      PCO2(1)=PICO2                              00001550
0100      PH20(1)=PIH20                              00001560
0101      DMC(1)=Q * PCO2(1) / (R * TG(1))          00001570

```

```

0102      DMH(1)=0.*PH20(1)/(R.*TC(1))          00001583
0103      TCOUT = TCIN                          00001590
0104      TCOUTL = TCIN                         00001603
0105      IF(IISOT)17,17,28                     00001610
0106      DO 35 I=1,N                          00001620
0107      25  CALL TEMP(I,DT,TIME,N,KK,CN1,TK1,THD,TWC,HX,WCTUT,TCIN,WATR,DMCQ,
          X      DMH,TC,TB,TCOUT)                00001630
0108      DIFF = ABS(TCOUT-TCOUTL)               00001650
0109      TCOUTL = TCOUT                         00001660
0110      IF(DIFF-1.026,26,27)                   00001670
0111      27  KK = KK + 1                        00001680
0112      1013 FORMAT('OHX SUBROUTINE WILL NOT REACH SSQ/') 00001690
0113      IF(KK.LT.100) GO TO 28                 00001700
0114      WRITE(6,1013)                          00001710
0115      26  CONTINUE                          00001720
          C  INITIAL CONDITIONS SET FOR EACH CASE 00001730
0116      17  MTH20 = 0.                        00001740
0117      MTCO2 = 0.                             00001750
0118      DO 20 I=1,N                          00001760
0119      XCO2(I) = ICXC/(100.*MCO2)             00001770
0120      YH20(I) = ICYH/(100.*MH20)            00001780
0121      YHCO(I) = ICYHC/(100.*MCO2)           00001790
0122      ZH20(I) = ICZC/(100.*MH20)           00001800
0123      20  CONTINUE                          00001810
0124      WRITE (6,1005)                        00001820
0125      1005 FORMAT (1H1, 'OUTPUT@,/')         00001830
0126      IF(TIME) 125,125,30                   00001840
          C  CALCULATIONS FOR N NODES EACH COMPUTING TIME INTERVAL 00001850
0127      30  DO 122 I=1,N                     00001860
0128      CALL AMHSC(I,IND,JIND,IDES,DT,TG,N,PH20,PHOUT,PCO2,PCOJT,DH20,
          X  DCU2,DMH,DMC,XCO2,YH20,YHCO,ZH20) 00001880
0129      122  CONTINUE                          00001890
          C  IS SYSTEM ADSORBING OR DESORBING 00001900
0130      IF(IND)2000,2000,2001                00001900
          C  IS SYSTEM VACUUM DESORBING OR GAS PURGE DESORBING 00001910
0131      2001 IF(IDES)2002,2002,34             00001920
0132      2002 DO 35 J=1,NJ                     00001920
0133      DO 35 I=1,N                          00001922
          C  SUBROUTINE USED FOR VACUUM DESORPTION 00001940
0134      35  CALL PVAC(I,DTP,N,JIND,C,DH20,DCO2,PIN,POJT,DMH,DMCO,PHO,PCO,
          X  TG,DMH,DMC,A,EPS)                  00001960
0135      PHOUT(N) = PHO                         00001970
0136      PCOUT(N) = PCO                         00001980
0137      WATR(I) = 0.                          00001990
0138      GO TO 120                             00002000
0139      34  PCU2(I) = 0.                       00002010
0140      PH20(I) = 0.                          00002020
0141      DO 2003 I=1,N                         00002021
0142      PHOUT(I) = ABS(TG(I)*DH20(I)*R/Q)      00002030
0143      PCOUT(I) = ABS(TG(I)*DCO2(I)*R/Q)      00002040
0144      2003 CONTINUE                          00002060
0145      DMC(1) = 0.                           00002050
0146      DMH(1) = 0.                           00002060
0147      2000 DO 2004 I=1,N                     00002061
0148      32  CALL PCAL (1,DMC,XCO2,PCO2,PCOUT,DMCO,
0149      CALL PCAL (1,DMH,DH20,PH20,PHOUT,DMHCO) 00002070

```

```

0150      2006 CONTINUE                                00002081
C      IS SYSTEM PERFORMANCE ISOTHERMAL OR NONISOTHERMAL 00002090
0151      120      IE(IISOT12010,2010,2005)            00002100
0152      2005 DO 2006 I=1,N                          00002101
0153      121      CALL TEMP(I,DT,TIME,N,KK,CN1,TX1,YH2,TWC,HX,WCIDT,TCIX,WAIX,DMC1, 00002110
X      DMHD,TG,TB,TCOUT)                                00002120
0154      2006 CONTINUE                                00002130
0155      2010 CONTINUE                                00002131
C      CALCULATION OF OUTPUT PARAMETERS                00002140
0156      125      CALL FOUT (TIME,DT,N,MH2O,MZT,DM1,YH2O,ZH2O,APH2O,LTH2O,LYH2O, 00002150
X      L7H2,EFFH)                                       00002160
0157      CALL FOUT (TIME,DT,N,MCO2,MZT,DMC,XCO2,YHCO,APCO2,LTCO2,LXCO2, 00002170
X      LYHC,EFFC)                                       00002180
0158      MTH2O = 0.                                    00002190
0159      MTCO2 = 0.                                    00002200
0160      DO 135 I = 1,N                                00002210
C      CALCULATION OF H2O MASS ON BED1BS1              00002220
0161      MTH2O = MTH2O + APH2O(I)*MZ/100.              00002230
C      CALCULATION OF CO2 MASS ON BED1BS1              00002240
0162      MTCO2 = MTCO2 + APCO2(I)*MZ/100.              00002250
0163      135 CONTINUE                                00002260
C      CALCULATION OF TOTAL BED LOADING (H2O AND CO2) 00002270
0164      PC1=(MTH2O + MTCO2) / 100. / MZT              00002280
C      SET UP PRINTER PLOT ARRAYS                      00002290
0165      IF(PLOT .EQ. 0.) GO TO 140                    00002300
0166      IF(MOD(M,NPLOT) .NE. 0) GO TO 140             00002310
0167      K=K+1                                          00002320
0168      PLTIME(K)=TIME                                00002330
0169      PLECT1(K)=PC1                                  00002340
0170      PLPHOT(K)=PHOUT(N)                            00002350
0171      PLPCOT(K)=PCOUT(N)                            00002360
0172      PLMXC(K) = LTH2O                              00002370
0173      PLMYC(K) = LTCO2                              00002380
0174      PLMYH(K) = TCOUT                              00002390
0175      PLMZH2(K) = TG(N)                             00002400
0176      140      IF(MOD(M,NPRINT) .NE. 0 .AND. JIND .NE. 1) GO TO 150 00002410
C      PRINT OUTPUT VARIABLES                          00002420
0177      IF(JIND .EQ. 1) WRITE(6,1033)                00002430
0178      WRITE(6,1001) TIME, PCT1, TCOUT,              00002440
X      EFFH, EFFC, LTH2O, LTCO2, LYH2O, L7H2,          00002450
X      XCO2, LYHC                                       00002451
0179      1001 FORMAT(///2X,                             00002470
X      8H TIME G12.6,8H PCT1 G12.6,8H TCOUT G12.6,20X, 00002471
X      8H EFFH G12.6,8H EFFC G12.6/2X,                00002472
X      8H LTH2O G12.6,8H LTCO2 G12.6,8H LYH2O G12.6,8H L7H2 00002473
X      G12.6,8H LXCO2 G12.6,8H LYHC G12.6)              00002520
0180      WRITE(6,1002)                                  00002521
0181      1002 FORMAT('OWT PCT ADSORBED BY NODES')      00002522
0182      WRITE(6,1003) (APCO2(I),I=1,N)               00002523
0183      1003 FORMAT(' LTCO2 ',13X,8G13.5)             00002524
0184      WRITE(6,1004) (APH2O(I),I=1,N)               00002525
0185      1004 FORMAT(' LTH2O ',13X,8G13.5)             00002526
0186      WRITE(6,1015)                                  00002527
0187      1015 FORMAT('OFLW RATE (LB-MOLES/MIN) BETWEEN NODES') 00002528
0188      WRITE(6,1006) (DMC(I),I=1,N), (DMC(I))        00002529
0189      1006 FORMAT(' CO2 ', 6X,8G13.5)

```

```

0190      WRITE(6,1007) (DMH(I),I=1,N), DM40(N)
0191      1007 FORMAT(' H2O      ', 6X,8G13.5)
0192      DO 1008 I=1,N
0193      1008 DMU(I)=DMC(I)+DMH(I)
0194      DMCL=DMCU(N)+DMH(N)
0195      WRITE(6,1009) (DMO(I),I=1,N), DMOL
0196      1009 FORMAT(' TOTAL      ', 6X,8G13.5)
0197      WRITE(6,1010)
0198      1010 FORMAT('ORATE OF ADSORPTION (LB-MOLES/MIN) BY NODES')
0199      WRITE(6,1011) (DCO2(I),I=1,N)
0200      1011 FORMAT(' CO2      ', 13X,8G13.5)
0201      WRITE(6,1012) (DH2O(I),I=1,N)
0202      1012 FORMAT(' H2O      ', 13X,8G13.5)
0203      DO 1026 I=1,N
0204      1026 DTOT(I)=DCO2(I) + DH2O(I)
0205      WRITE(6,1014) (DTOT(I),I=1,N)
0206      1014 FORMAT(' TOTAL      ', 13X,8G13.5)
0207      WRITE(6,1018)
0208      1018 FORMAT('OPPRESSURES BY NODE, INCLUDING BOTH ENDS (MM HG)')
0209      IF(IND .EQ. 1) GO TO 1027
0210      WRITE(6,1017) PICU2, (PCAVG(I),I=1,N), PCOUT(N)
0211      WRITE(6,1019) PIH2O, (PHAVG(I),I=1,N), PHOUT(N)
0212      PTIN=PICU2 + PIH2O
0213      PTOUT=PCOUT(N) + PHOUT(N)
0214      DO 1028 I=1,N
0215      1028 PT(I)=PCAVG(I) + PHAVG(I)
0216      WRITE(6,1022) PTIN, (PT(I),I=1,N), PTOUT
0217      GO TO 1030
0218      1027 CONTINUE
0219      PTAC=(      POUT * (PHAVG(N)/ (PHAVG(N)+ PCAVG(N)))
0220      PTAC=(      POUT * (PCAVG(N)/ (PHAVG(N)+ PCAVG(N)))
0221      WRITE(6,1017) FACTC, (PCAVG(I),I=1,N), PTAC
0222      WRITE(6,1019) FACTH, (PHAVG(I),I=1,N), PTAC
0223      WRITE(6,1022) PIN, (PT(I),I=1,N), POUT
0224      1017 FORMAT(' CO2      ', 9G13.5)
0225      1019 FORMAT(' H2O      ', 9G13.5)
0226      1022 FORMAT(' TOTAL      ', 9G13.5)
0227      1030 WRITE(6,1023)
0228      1023 FORMAT('TEMPERATURES (DEG F)')
0229      WRITE(6,1024) (TG(I),I=1,N)
0230      1024 FORMAT(' GAS      ', 13X,8G13.5)
0231      WRITE(6,1025) (TB(I),I=1,N)
0232      1025 FORMAT(' BED      ', 13X,8G13.5)
0233      IF(MOD(M,2*NPRINT) .EQ. 0) WRITE(6,1033)
0234      1033 FORMAT('1')
0235      150 CONTINUE
0236      M=M+1
C      SET UP INDICATORS FOR ADSORB AND DESORB CYCLES
0237      160 IE(TIME)161,161,162
0238      161 CALL ALOGICTIME ,ADSORB,DESORB,IND,JIND,TMAX,PRLAST,NPRINT)
0239      GO TO 163
0240      162 CALL ALOGICTIME+DT,ADSORB,DESORB,IND,JIND,TMAX,PRLAST,NPRINT)
0241      163 CONTINUE
C      RESET TIME
0242      TIME=TIME+DT
0243      IF(IND .NE. 0 .OR. JIND .NE. 1) GO TO 210

```

00002530  
00002531  
00002532  
00002533  
00002534  
00002535  
00002536  
00002537  
00002538  
00002539  
00002540  
00002541  
00002542  
00002543  
00002544  
00002545  
00002546  
00002547  
00002548  
00002549  
00002550  
00002551  
00002552  
00002553  
00002554  
00002555  
00002556  
00002557  
00002558  
00002559  
00002560  
00002561  
00002562  
00002563  
00002564  
00002565  
00002566  
00002567  
00002568  
00002569  
00002570  
00002571  
00002572  
00002573  
00002574  
00002830  
00002840  
00002850  
00002860  
00002861  
00002862  
00002863  
00002864  
00002870  
00002880  
00002881

D-68

FORTRAN IV C LEVEL 2C-1

MAIN

DATE = 72140

13/18/09

0175 0007

CR-115568

SVHSER-6040

0244		DMC(1)=PICD2/(R*TGI)*Q	00002882
0245		DMH(1)=PIH20/(R*TGI)*Q	00002883
0246	210	CONTINUE	00002884
0247		IF (TIME-TMAX) 30,30,220	00002890
0248	220	CONTINUE	00002900
	C	PRINTER PLOT OUTPUT	00002910
0249		IF (PLOT) 10,10,230	00002920
0250	230	CALL PPL0T(PLTIME,PLPCTL,K,'*',1,7,0,1,0.,'TOTAL BFD LOADING	00002930
	X	*,500)	00002940
0251		CALL PPL0T(PLTIME,PLMXC,K,'*',1,7,0,1,0.,'TOTAL H2O LOADING	00002950
	Y	*,500)	00002960
0252		CALL PPL0T(PLTIME,PLMYC,K,'*',1,7,0,1,0.,'TOTAL CO2 LOADING	00002970
	X	*,500)	00002980
0253		CALL PPL0T(PLTIME,PLPHOT,K,'*',1,7,0,1,0.,'OUTLET PARTIAL PRESSURE	00002990
	X OF H2O	*,500)	00003000
0254		CALL PPL0T(PLTIME,PLPCOT,K,'*',1,7,0,1,0.,'OUTLET PARTIAL PRESSURE	00003010
	X OF CO2	*,500)	00003020
0255		CALL PPL0T(PLTIME,PLMTYH,K,'*',1,7,0,1,0.,'OUTLET COOLANT TEMPERATURE	00003030
	XURE	*,500)	00003040
0256		CALL PPL0T(PLTIME,PLMZH2,K,'*',1,7,0,1,0.,'OUTLET PROCESS GAS TEMPERATURE	00003050
	XERATURE	*,500)	00003060
0257		GO TO 10	00003070
0258		END	00003080

Hamilton  
StandardU  
A.



COMMON BLOCK /BLOK3 / MAP SIZE 320			
SYMBOL	LOCATION	SYMBOL	LOCATION
PCAVG	0	PHAVG	190

COMMON BLOCK /OUTPUT / MAP SIZE 190			
SYMBOL	LOCATION	SYMBOL	LOCATION
PT	0	EACTH	190

COMMON BLOCK /BLOK1 / MAP SIZE 640			
SYMBOL	LOCATION	SYMBOL	LOCATION
XR	0	YR	190
		YHCR	320
		ZR	480

COMMON BLOCK /BLOK2 / MAP SIZE 30			
SYMBOL	LOCATION	SYMBOL	LOCATION
CUN	0		

SUBPROGRAMS CALLED							
SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
BEGIN	248	IBCOMA	24C	LOAD	250	TFMP	254
PAAC	25C	PCAL	260	FOUT	264	ALOGIC	268
						AMHSC	258
						DPLET	26C

EQUIVALENCE DATA MAP							
SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
D	618	DT	618	TMAX	61C	PRINT	620
EN	628	AINO	62C	IDES	630	ISOT	634
ICXC	640	ICVH	644	ICZC	648	ICVHC	64C
PICD2	654	YHJ	668	YDI	66C	ZDI	670
KXR	678		67C	YR	680	KYH	684
KZ	68C	KZR	690	MZT	694	PAIP	698
TCIN	6A0	TGI	6A4	PIN	6A8	POUT	6AC
DESORB	6B4	C	6B8	WCIOT	6CB	CNI	6CC
A	710	EPS	714	TKI	7A8	YHR	7F8
HX	898					TWC	848

SCALAR MAP							
SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
I	938	NJ	93C	DTP	940	IVJ	944
MCO2	94C	MH20	950	TIME	954	N	958
NPLDT	960	K	964	KK	968	N	96C
TCOUT	974	TCOUTI	978	DIE	97C	PIAC	980
MTH20	988	MTCO2	98C	JIND	990	J	994
PCD	99C	LTH20	9A0	LYH20	9A4	LZ22	9A8
LTCO2	9B0	LXCU2	9B4	LYHC	9B8	FFFC	9BC
DMU	9C4	PTIN	9C8	PTOUT	9CC		

ARRAY MAP							
SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
HEL	9D0	PCU2	A2C	PH20	880	UMC	D40
						DMH	ED0

ORIGINAL PAGE IN  
OF POOR QUALITY

Refraction  
Standard

10

FORTRAN IV G LEVEL 20.1

MAIN

DATE = 72160

13/18/69

P175 0000

CR-115568

SVHSER-6040

XCDZ	1060	YH20	11E0	YH0C3	1380	7420	1510	D420	15A0
PHOUT	1830	DMHO	19C0	DL02	1050	PCJUT	1CE0	DM00	1E70
PLTIME	2000	PLPCT1	2700	PLPCT1	2EAO	PLPCTT	3770	PLMYC	3E40
PLMYC	4710	PLMIYH	4EE0	PLMZ42	5600	AP420	5E80	APC02	5010
WALK	61A0	UR	6330	IR	64C0	IS	6650	DM1	57E0
DTOT	6970	TFA	6800						

## FORMAT STATEMENT MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
1020	6EC0	1000	6EC9	1016	7067	1013	71E7	1005	720C
1001	721A	1002	7285	1003	7202	1004	72E7	1015	72FC
1006	7327	1007	733C	1009	7351	1010	7366	1011	7395
1012	73AA	1014	738F	1018	7304	1017	7407	1019	741A
1022	7420	1023	7450	1024	7459	1025	746E	1033	7483

\*OPTIONS IN EFFECT\* ID,BCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = MAIN, LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 258, PROGRAM SIZE = 35324

\*STATISTICS\* NO DIAGNOSTICS GENERATED

Hamilton  
StandardJ  
R

```

0001      SUBROUTINE TEMP(I,DT,TIME,N,JIND,CON,IKI,IHB,IWC,IHX,WCTOT,TCIN,      00000010
           X      WAIR,DMCO,DMMU,T3,T8,TOUT)      00000020
           C      SIMULATION OF AN AIR-AIR CROSSFLOW HEAT EXCHANGER      00000030
0002      REAL LB , K1 , K2 , K3 , MCB , K4 , MCHX ,      00000040
           X      KB , KHX , K11      00000050
0003      DIMENSION WAIR(100) , WCO2(100) , WH2O(100) , T(1:20),      00000060
           X      TMB(20) , TWC(20) , HX(20) , Q(100) , T8(100) ,      00000070
           X      T8PRIM(100), T8PRM(100), TCOU(100),      00000080
           X      THX(100), CON(16), TGI(10), DMCO(100), DMMO(100)      00000090
           C      SET VALUES FOR CONSTANTS DURING FIRST PASS      00000100
0004      IF(JIND).EQ.10      00000110
0005      1 IF(1-1)3,3,10      00000120
0006      3 CPE = CON(1)      00000130
0007      LB = CON(2)      00000140
0008      ABHXT = CON(3)      00000150
0009      AAMBT = CON(4)      00000160
0010      WHX = CON(5)      00000170
0011      WBED = CON(6)      00000180
0012      CPHX = CON(7)      00000190
0013      CPBED = CON(8)      00000200
0014      AB = CON(9)      00000210
0015      AHX = CON(10)      00000220
0016      KB = CON(11)      00000230
0017      KHX = CON(12)      00000240
0018      TAMB = CON(13)      00000250
0019      HAMB = CON(14)      00000260
0020      NPT1 = CON(15)      00000270
0021      NPT2 = CON(16)      00000280
0022      DELL = LB / N      00000290
0023      K3 = KB * AB / DELL      00000300
0024      K4 = KHX * AHX / DELL      00000310
0025      WC = WCTOT / N      00000320
0026      ABHX = ABHXT / N      00000330
0027      AAMB = AAMBT / N      00000340
0028      ACIX = ABHX * AAMB      00000350
0029      MCHX = WHX * CPHX / N      00000360
0030      MCB = WBED * CPBED / N      00000370
0031      DO 2 J = 1, N      00000380
0032      THX(J) = TGI(J)      00000390
0033      T8(J) = TGI(J)      00000400
0034      2 CONTINUE      00000410
           C      WRITE HEAT EXCHANGER INPUT      00000420
0035      WRITE(6,1011)      00000430
0036      1011 FORMAT('CHB#F#K1< TABLE')      00000440
0037      WRITE(6,1012) (THX(J),J=1,NPT1)      00000450
0038      1012 FORMAT(1X,10G12.6)      00000460
0039      WRITE(6,1012) (IHB(J),J=1,NPT1)      00000470
0040      WRITE(6,1013)      00000480
0041      1013 FORMAT('OHX#F#WC< TABLE')      00000490
0042      WRITE(6,1012) (TWC(J),J=1,NPT2)      00000500
0043      WRITE(6,1012) (HX(J),J=1,NPT2)      00000510
0044      10 CONTINUE      00000520
           C      CALCULATE CONSTITUENT WEIGHT FLOW      00000530
0045      WC(2(1)) = DMCO(1)*44.      00000540
0046      WH2O(1) = DMMO(1)*18.      00000550
           C      CALCULATE HEAT OF ADSORPTION      00000560

```

```

0047      QR(1) = DMH0(1) * 1400. + DMCH(1) * 1400.          00000570
0048      K1 = WAIR(1) + WCO2(1) + WH2O(1)          00000580
0049      IF(K1 .EQ. 0.) GO TO 11          00000590
0050      K2 = (WAIR(1) * .24 + WCO2(1) * .2 + WH2O(1) * .44) / K1  00000600
0051      GO TO 12          00000610
0052      11      K2 = 0.          00000620
0053      12      K11 = ABS(K1)          00000630
0054      IF(11 .EQ. 1) TGI = TG(1)          00000640
C      OBTAIN HEAT TRANSFER COEFFICIENT BETWEEN BED AND HEAT EXCHANGER AS A FUNCTION OF WEIGHT FLOW THROUGH BED  00000650
C      CALL UNLININPT1,IK1,IMH,K11,IM,IOF          00000660
0055      20      CALL UNLININPT1,IK1,IMH,K11,IM,IOF          00000670
0056      IF(10F .NE. 0) WRITE(6,1000) IOF          00000680
0057      1000  FORMAT(1'DK1 OFF TABLE - IOF=#,11)          00000690
C      OBTAIN HEAT TRANSFER COEFFICIENT BETWEEN HEAT EXCHANGER AND  00000700
C      AMBIENT AS A FUNCTION OF COOLANT FLOW RATE          00000710
0058      CALL UNLININPT2,TWC,HX,WC,HXX,IOF          00000720
0059      IF(10F .NE. 0) WRITE(6,1001) IOF          00000730
0060      1001  FORMAT(1'OWC OFF TABLE - IOF=#,11)          00000740
0061      IF(K11 .EQ. 0.) GO TO 21          00000750
0062      A = HB * AGHX / (K11 * K2)          00000760
0063      AA = EXP(-A)          00000770
0064      GO TO 22          00000780
0065      21      AA = 0.          00000790
C      CALCULATION OF HEAT FLOW FROM PROCESS GAS TO BED          00000800
0066      22      Q1 = (TGI - TB(1)) * K1 * K2 * (1. - AA)          00000810
0067      UBHX = HB * HXX / (HB + HXX)          00000820
C      CALCULATION OF HEAT FLOW FROM HEAT EXCHANGER TO BED          00000830
0068      Q2 = UBHX * ABHX * (THX(1) - TB(1))          00000840
0069      IF(1 - 11 * 0. * 0.30)          00000850
C      CALCULATION OF NODAL CONDUCTIVE HEAT FLOW IN BED          00000860
0070      30      Q3 = K3 * (TB(1) - 1) - TB(1)          00000870
C      CALCULATION OF NODAL CONDUCTIVE HEAT FLOW IN HEAT EXCHANGER  00000880
0071      Q7 = K6 * (THX(1) - 1) - THX(1)          00000890
0072      GO TO 50          00000900
0073      40      Q3 = 0.          00000910
0074      Q7 = 0.          00000920
0075      50      TFI = M160,70,70          00000930
C      CALCULATION OF NODAL CONDUCTIVE HEAT FLOW IN BED          00000940
0076      60      Q4 = K3 * (TB(1) - 1) - TB(1)          00000950
C      CALCULATION OF NODAL CONDUCTIVE HEAT FLOW IN HEAT EXCHANGER  00000960
0077      Q8 = K6 * (THX(1) - 1) - THX(1)          00000970
0078      GO TO 80          00000980
0079      70      Q4 = 0.          00000990
0080      Q8 = 0.          00010000
0081      80      CONTINUE          00010010
C      CALCULATE BED TEMPERATURE AND PROCESS GAS TEMPERATURE          00010020
0082      TB(1) = TB(1) + (Q1 + Q2 + QR(1) + Q3 + Q4) * DT / MCR  00010030
0083      TG(1) = TB(1) + (TGI - TB(1)) * AA          00010040
0084      TGI = TG(1)          00010050
0085      B = HXX * ACMX / (WC * CPC)          00010060
C      CALCULATION OF HEAT FLOW FROM COOLANT GAS TO HEAT EXCHANGER  00010070
0086      Q5 = WC * CPC * (1. - EXP(-B)) * (TCIN - THX(1))          00010080
0087      UAMB = HXX * HAMB / (HXX + HAMB)          00010090
C      CALCULATION OF HEAT FLOW FROM AMBIENT TO HEAT EXCHANGER          00010100
0088      Q6 = UAMB * AAMB * (TAMB - THX(1))          00010110
C      CALCULATE HEAT EXCHANGER AND COOLANT OUTLET TEMPERATURES  00010120

```

FORTAN IV C LEVEL 20.1

TEMP

DATE = 72140

13/18/09

0175 0003

CR-115568

SVHSR-6040

```

0089      THX(1) = THX(1) + (Q5 = Q2 + Q6 + Q7 + Q8)* DT / MCHX      00001133
0090      TOUT(1)=THX(1) + (TCIN - THX(1)) * EXP(-B)      00001140
0091      IF(1-N)/10,100,100      00001150
0092      100 TOUT1= 0.      00001160
0093      DO 105 I=1,N      00001170
0094      TOUT1= TOUT1+ TOUT(I)      00001180
0095      105 CONTINUE      00001190
      C      CALCULATION OF COOLANT OUTLET TEMPERATURE      00001200
0096      TOUT = TOUT1/N      00001210
0097      110 CONTINUE      00001220
0098      RETURN      00001230
0099      END      00001240
    
```

ORIGINAL PAGE IS  
OF POOR QUALITY

Hamilton  
Standard

U  
No

D-74

EDRTRAN IV G LEVEL 20.1

TEMP

DATE = 72140

13/18/09

P175.0004

CR-115568  
SVHSR-6040

## SUBPROGRAMS CALLED

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
IDCOM#	134	UNLIN	138	EXP	13C				

## SCALAR MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
JING	180	I	184	CPC	188	13	18C	A3HVT	190
AAMBT	194	WHX	198	WBED	19C	CPHX	1A0	CPRED	1A4
AR	1A8	AHX	1AC	KB	1B0	KHX	1B4	TAMP	1B8
HAMB	1BC	NPT1	1C0	NPT2	1C4	DELL	1C8	N	1CC
K3	1D0	K4	1D4	WC	1D8	WCTOT	1DC	A3HVT	1E0
AAMB	1E4	ACHX	1E8	MCHX	1EC	MCB	1F0	J	1F4
K1	1F8	K2	1FC	K11	200	YCI	204	H3	208
IDF	20C	HXX	210	A	214	AA	218	Q1	21C
UBHX	220	Q2	224	Q3	228	Q7	22C	Q4	230
QU	234	D7	238	B	24C	Q5	240	TCIN	244
HAMB	248	Q4	24C	THUT1	250	TCJT	254	TIME	258

## ARRAY MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
MAIR	25C	MCU2	260	WH20	3F0	T4I	587	T4P	584
TMC	588	HX	58C	OR	590	T3	720	TRPPIM	724
THXPRM	884	TCOUT	A44	THX	BD4	CON	D64	T5	D48
OMCU	D6C	OMMO	D70						

## FORMAT STATEMENT MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
1011	D74	1012	D87	1013	D90	1000	DA4	1001	D8E

\*OPTIONS IN EFFECT\* ID, MCD, SOURCE, MNLIST, DECK, LOAD, MAP

\*OPTIONS IN EFFECT\* NAME = TEMP, LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 99, PROGRAM SIZE = 5992

\*STATISTICS\* NO DIAGNOSTICS GENERATED

Hamilton  
Standard  
No. 1

```

0001      SUBROUTINE AMHSC(I,IND,JIND,ILES,DT,I,N,PH2J,PHOUT,PCJ2,PCOUT,
      X DH2J,DCJ2,DMH,DMC,XCJ2,TYH2J,YHJ2J,ZH2J)
0002      REAL KX,KXR,KY,KYR,KYH,KYHR,KZ,KZR,MZ,MZJ,MCJ2,MH2J
0003      COMMON/BLUK1/XR,YR,YHCR,ZR
0004      COMMON/BLUK3/PCAVG,PHAVG
0005      COMMON/BLUK2/CUN
0006      DIMENSION PH2J(100),PHOUT(100),PCJ2(100),PCOUT(100),DH2J(100),
      X DCJ2(100),DMH(100),DMC(100),XCJ2(100),YH2J(100),
      X YHJ2J(100),ZH2J(100),XR(100),YR(100),YHCR(100),
      X ZR(100),CUN(12),TYH2J(100),PHAVG(100),PCAVG(100),
      X T(100)
0007      EQUIVALENCE (CON(1),XOL 1),(CON(2),YOL 1),(CON(3),ZOL 1,
      X(CON(4),KX 1),(CON(5),KXR 1),(CON(6),KY 1),(CON(7),KYR 1,
      X(CON(8),KYH 1),(CON(9),KYHR 1),(CON(10),KZ 1),(CON(11),KZR 1,
      X(CON(12),MZ)
0008      MZ = MZT/N
0009      MH2J = 18.
0010      MCJ2 = 44.
      C
0011      CONVERT ULTIMATE CAPACITY FROM PERCENT TO LB-MOLES/LB
0012      XD = XOL/(100.*MCJ2)
0013      YD = YOL/(100.*MH2J)
0014      ZD = ZOL/(100.*MH2J)
0015      YH2J(1) = TYH2J(1) - YHJ2J(1)
0016      IF(JIND.EQ.-1) GO TO 3
0017      IF(IND=JIND).E.1,2
0018      2 IF(ILES)7,7,1
      PCAVG(1) = (PCJ2(1) + PCOUT(1))/2.
      C
0019      CALCULATE AVERAGE NODE PARTIAL PRESSURES IF NOT ON VACUUM DESCRIPTION
      PHAVG(1) = (PH2J(1) + PHOUT(1))/2.
0020      GO TO 7
0021      3 IF(ILE.GT.1) GO TO 1
0022      4 DO 6 J=1,100
0023      PCAVG(J) = (PCJ2(J) + PCOUT(J))/2.
0024      6 PHAVG(J) = (PH2J(J) + PHOUT(J))/2.
      C
0025      7 XR(1) = KX * PCAVG(1) * (XD - XCJ2(1)) - KXR * XCJ2(1)
0026      YR(1) = KY * PHAVG(1) * (YD - YH2J(1)) - KYR * YH2J(1)
0027      YHCR(1) = YH2J(1) * KYH * PCAVG(1) - YHJ2J(1) * KYHR
0028      ZR(1) = KZ * PHAVG(1) * (ZD - ZH2J(1)) - KZR * ZH2J(1)
0029      IF(IND)5,5,53
      C
0030      LIMITING H2O ADSORPTION RATE
      5 IF(YR(1)+ZR(1) - DMH(1)/MZ)30,30,20
0031      20 YR(1) = (YR(1) / (YR(1) + ZR(1))) * DMH(1) / MZ
0032      ZR(1) = DMH(1) / MZ - YR(1)
      C
0033      LIMITING CO2 ADSORPTION RATE
      30 IF(XR(1)+YHCR(1) - DMC(1)/MZ)60,60,50
0034      50 XR(1) = (XR(1) / (XR(1) + YHCR(1))) * DMC(1) / MZ
0035      YHCR(1) = DMC(1) / MZ - XR(1)
0036      GO TO 60
0037      53 DUM = (YH2J(1) + ZH2J(1))/DT
0038      IF(DUM + YR(1) + ZR(1))54,55,55
0039      54 ZR(1) = ZR(1) / (YR(1) + ZR(1)) * DUM
0040      YR(1) = DUM - ZR(1)
0041      55 DUM = (XCJ2(1) + YHJ2J(1))/DT
0042      IF(DUM + XR(1) + YHCR(1))56,60,60
0043      56 XR(1) = XR(1) / (XR(1) + YHCR(1)) * DUM

```

FORTRAN IV G LEVEL 2C.1

AMHSC

DATE = 72160

13/18/69

P175 0002

CR-115568  
SWISER-6040

0044		YHCR(I)=DUM-XR(I)	00001749
0045	60	CONTINUE	00001750
	C	CALCULATION OF 1H-MOLE/MODE OF ADSORBATES IN EACH SITE	00001751
0046		XCO2(I) = XCO2(I) + XR(I) * DT	00001773
0047		IYH2O(I) = IYH2O(I) + YR(I) * DT	00001783
0048		YHOCO(I) = YHOCO(I) + YHCR(I) * DT	00001790
0049		ZH2O(I) = ZH2O(I) + ZR(I) * DT	00001800
0050		YH2O(I) = IYH2O(I) - YHOCO(I)	00001810
0051		DH2O(I) = IYR(I) + ZR(I) * M7	00001820
0052		DCO2(I) = (XR(I) + YHCR(I)) * M7	00001830
0053		RETURN	00001840
0054		END	00001850

Hamilton  
StandardU  
A



COMMON BLOCK /BLOCK1 / MAP SIZE 640			
SYMBOL	LOCATION	SYMBOL	LOCATION
XR	0	YR	190
		YHCR	320
		ZR	480

COMMON BLOCK /BLOCK3 / MAP SIZE 320			
SYMBOL	LOCATION	SYMBOL	LOCATION
PCAVG	0	PHAVG	190

COMMON BLOCK /BLOCK2 / MAP SIZE 30			
SYMBOL	LOCATION	SYMBOL	LOCATION
CUN	0	XOL	0
KXR	10	KY	14
KZ	24	KZR	28
		MZT	20
		YGL	4
		KYR	18
		KYH	10
		KYHP	20

SCALAR MAP			
SYMBOL	LOCATION	SYMBOL	LOCATION
MZ	110	N	114
YD	124	ZD	128
IOES	138	J	130
		MD20	113
		I	120
		DUM	140
		DT	144
		MC12	110
		JIND	130
		IND	134

ARRAY MAP			
SYMBOL	LOCATION	SYMBOL	LOCATION
PH2D	148	PHOUT	140
DCU2	150	DMH	160
YHUCD	2FC	ZH2D	300
		PL02	150
		DMC	164
		TYH2D	304
		PCOUT	154
		XC02	168
		T	308
		DH2D	158
		YH2D	150

\*OPTIONS IN EFFECT\* ID,BCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = AMHSC , LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 54, PROGRAM SIZE = 2580

\*STATISTICS\* NO DIAGNOSTICS GENERATED

ORIGINAL PAGE  
OF POOR QUALITYHamilton  
Standard  
U  
No

FORTRAN IV G LEVEL 20.1

ALGIC

DATE = 72160

13/18/09

P175 0001

CR-115568  
SVHSER-6040

```

0001      SUBROUTINE ALGIC (TIME, ADSORB, DESORB, IND, JIND, IMAX, PRI, LAST, NPRINT) 0001001960
0002      IF (TIME) 5,5,10 000101870
0003      5 IF (IND) 6,6,7 000101880
0004      6 SWITCH = ADSORB 000101890
0005      GO TO 8 000101900
0006      7 SWITCH = DESORB 000101910
0007      8 JIND = -1 000101920
0008      GO TO 60 000101930
0009      10 IF (TIME-SWITCH) 150,20,20 000101940
0010      20 IF (IND) 30,30,40 000101950
0011      30 SWITCH = SWITCH + DESORB 000101960
0012      IND = 1 000101970
0013      JIND = 1 000101980
0014      GO TO 60 000101990
0015      40 SWITCH = SWITCH + ADSORB 000202000
0016      IND = 0 000202010
0017      JIND = 1 000202020
0018      GO TO 60 000202030
0019      50 JIND = 0 000202040
0020      60 CONTINUE 000202050
0021      IF (JIND) 92, 96, 96 000202060
0022      92 NHCY = 0 000202070
0023      NHCY = 2 * IMAX / (ADSORB + DESORB) 000202080
0024      GO TO 96 000202090
0025      96 NHCY = NHCY + 1 000202100
0026      IF (INT(NHCY - NHCY - 2)) 96, 98, 96 000202110
0027      98 NPRINT = PRI * LAST 000202120
0028      96 CONTINUE 000202130
0029      RETURN 000202140
0030      END 000202150

```

Hamilton  
StandardU  
A

FORTRAN IV G LEVEL 20.1

ALOGIC

DATE = 72140

13/18/09

R175 C002

CR-115568  
SVHSER-6040

SCALAR MAP			
SYMBOL	LOCATION	SYMBOL	LOCATION
TIME	100	END	104
JIND	114	NHCY	118
PRLAST	128		

\*OPTIONS IN EFFECT\* ID,HCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = ALOGIC , LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 30, PROGRAM SIZE = 890

\*STATISTICS\* NO DIAGNOSTICS GENERATED

Hamilton  
Standard

U  
No

```

0001      SUBROUTINE FOUT (TIME,DT,N,MOLWT,MZT,DMH,X1,X2,LTOT,PC1,PCM1, 00002160
           X PCM2,EFF) 00002170
0002      REAL MOLWT, MZ, MZT, LTOT 00002180
0003      DIMENSION X1(100), X2(100), LTOT(1),DMH(100) 00002190
0004      DIMENSION AX1(100), AX2(100) 00002200
0005      IF (TIME) 10,10,20 00002210
0006      10 H2TOT = 0. 00002220
0007      HCTOT = 0. 00002230
0008      EFF = 100. 00002240
0009      MZ = MZT/N 00002250
0010      AMTOT1 = 0. 00002260
0011      AMTOT2 = 0. 00002270
0012      20 DO 40 I=1,N 00002280
           C CALCULATE WEIGHT(LBS) OF CONSTITUENT ON EACH SITE/NODE 00002290
0013      AX1(I) = X1(I)*MZ*MOLWT 00002300
0014      AX2(I) = X2(I)*MZ*MOLWT 00002310
           C CALCULATE PERCENT LOADING OF CONSTITUENT PER NODE 00002320
0015      LTOT(I) = (AX1(I) + AX2(I))*100./MZ 00002330
0016      40 CONTINUE 00002340
           C CALCULATE AMOUNT OF CONSTITUENT THRU BED EACH TIME INTERVAL (LBS.) 00002350
0017      AMX1 = 0. 00002360
0018      AMX2 = 0. 00002370
0019      50 DO 50 I=1,N 00002380
           C CALCULATE WEIGHT(LBS) OF CONSTITUENT ON EACH SITE 00002390
0020      AMX1 = AMX1 + AX1(I) 00002400
0021      AMX2 = AMX2 + AX2(I) 00002410
0022      50 CONTINUE 00002420
           C CALCULATE TOTAL WEIGHT(LBS) OF CONSTITUENT ON BED 00002430
0023      AMTOT = AMX1 + AMX2 00002440
           C CALCULATE TOTAL LOADING OF CONSTITUENT ON BED 00002450
0024      PC1 = AMTOT*100./MZT 00002460
           C CALCULATE TOTAL LOADING OF CONSTITUENT ON EACH SITE 00002470
0025      PCM1 = AMX1*100./MZT 00002480
0026      PCM2 = AMX2*100./MZT 00002490
0027      FCT2 = DT * DMH(1) * MOLWT 00002500
0028      IF (TIME) 70,70,60 00002510
0029      60 IE(MOLWT=18.161,61,62 00002520
0030      61 H2TOT = H2TOT + FCT2 00002530
0031      IF (DMH(1)) EQ. 0.1 GO TO 65 00002540
           C CALCULATE REMOVAL EFFICIENCY 00002550
0032      AMTD = AMTOT-AMTOT1 00002560
0033      EFF = AMTD*100./H2TOT 00002570
0034      GO TO 70 00002580
0035      62 HCTOT = HCTOT + FCT2 00002590
0036      IF (DMH(1)) EQ. 0.1 GO TO 66 00002600
0037      AMTD = AMTOT-AMTOT2 00002610
0038      EFF = AMTD*100./HCTOT 00002620
0039      GO TO 70 00002630
0040      65 AMTOT1 = AMTOT 00002640
0041      H2TOT = 0. 00002650
0042      GO TO 70 00002660
0043      66 AMTOT2 = AMTOT 00002670
0044      H2TOT = 0. 00002680
0045      70 CONTINUE 00002690
0046      RETURN 00002700
0047      END 00002710

```

FORTRAN IV C LEVEL 20.1

FOUT

DATE = 72160

13/18/69

P175 C002

CR-115568  
SVHSR-6040

## SCALAR MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
TIME	E0	H2OTOT	E4	H2OTOT	E8	EFF	FC	M7	FD
MZT	E4	N	E8	AMT01	FC	AMT02	100	I	104
MULMT	108	AMX1	10C	AMX2	110	AMTOT	114	PCTI	118
PCM1	11C	PCN2	120	ECT2	124	OT	128	AMT10	12C
AMT20	130								

## ARRAY MAP

SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION	SYMBOL	LOCATION
X1	134	X2	138	L10T	13C	DMH	140	AXI	144
AK	204								

\*OPTIONS IN EFFECT\* ID,UCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = FOUT , LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 47, PROGRAM SIZE = 2044

\*STATISTICS\* NO DIAGNOSTICS GENERATED

ORIGINAL PAGE IS  
OF POOR QUALITYHamilton  
StandardU  
A

FORTRAN IV G LEVEL 20.1

PVAC

DATE = 72160

13/12/69

P175 C001

CR-115568  
SVHSER-6040

```

0001      SUPEROUTINE PVAC(I,DT,N,IIND,C,DMH,PCO2,PIN,PMU,DMH,DMC,      00302723
      X PHOUT,PCOUT,TG,DMH,DMC,A,EPS)      00302730
0002      COMMON/INPUT/PT,FACTH,FACTC      00302731
0003      COMMON/BLK3/PCO2,PH2O      00302740
0004      DIMENSION      DMH(100),DMH(100),DMC(100),DMH(100),      00302750
      X      DMCO(100),PH2O(100),PCO2(100),PT(100),C(4)      00302760
      X, DMH2O(100), DCO2(100),TG(100)      00302770
0005      REAL L      00302780
      C      SET VALUES FOR CONSTANTS DURING FIRST PASS      00302790
0006      IF(IIND).5.1      00302800
0007      1      VB = C(1)      00302810
0008      XMU= C(2)      00302820
0009      DIA = C(3)      00302830
0010      XLEN= C(4) *12.      00302840
0011      K= 555.      00302850
0012      L = XLEN/N      00302860
0013      PI = 3.1415927      00302870
0014      Q= A * DIA**2 * EPS**3 /(XMU*L * (1.-EPS)**2)      00302880
      X * 60. / (200.*555.*.359*144.*1728.)      00302890
0015      VNCDE = VB/N      00302900
0016      K = 1 + 1      00302910
0017      DO 2 J=1,K      00302920
      C      CALCULATE TOTAL PRESSURE      00302930
0018      PT(J) = PH2O(J) + PCO2(J)      00302940
0019      2      CONTINUE      00302950
0020      5      IF(I .GT. 1) GO TO 10      00302960
0021      DELW=Q/IG(I)      00302970
0022      FACTH=PIN * (PH2O(1) / (PH2O(1) + PCO2(1)))      00302980
0023      FACTC=PIN * (PCO2(1) / (PH2O(1) + PCO2(1)))      00302990
      C      CALCULATE AVERAGE TOTAL PRESSURE      00303000
0024      PTA = (PIN + PT(1))/2.      00303010
0025      DMI = DELW*PTA*(PIN-PT(1))      00303020
0026      IF (PT(1)) 6,6,7      00303030
0027      6      DMH(1) = 0.      00303040
0028      GO TO 8      00303050
0029      7      DMH(1) = PH2O(1)/PT(1)*DMI      00303060
0030      8      DMI(1) = DMI-DMH(1)      00303070
0031      PTA = (PT(1) + PT(2))/2.      00303080
      C      CALCULATE OUTLET FLOW THROUGH FIRST NODE      00303090
0032      DMU(1) = DELW*PTA * (PT(1)-PT(2))      00303100
0033      IF(IN .EQ. 1) GO TO 25      00303110
0034      GO TO 20      00303120
0035      10      IF(I .EQ. N) GO TO 25      00303130
0036      DELW=Q/TG(I)      00303140
      C      CALCULATE AVERAGE TOTAL PRESSURE AND OUTLET FLOW FOR NODES 2 THRU      00303150
0037      PTA = (PT(I) + PT(I+1))/2.      00303160
0038      DMU(I) = DELW*PTA * (PT(I)-PT(I+1))      00303170
0039      15      DMH(I) = DMH(I-1)      00303180
0040      DMI(I) = DMI(I-1)      00303190
      C      CALCULATE H2O AND CO2 OUTLET FLOW RATES - LB-MOLE/MIN/NODE      00303200
0041      20      K=1      00303210
0042      IF(DMU(I) .LT. 0.) K=K+1      00303220
0043      DMH(I)=PH2O(I)/PT(I)*DMU(I)      00303230
0044      DMCO(I)= DMU(I) - DMH(I)      00303240
      C      CALCULATE PARTIAL PRESSURES OF CO2 AND H2O AND TOTAL PRESSURE      00303250
0045      DELPC=((DMC(I)-DCO2(I)-DMCO(I))*R*TG(I)/VNCDE)*DT      00303260

```

Hamilton  
SundarU  
A

```

0046      DELPH=1/(DMH(1)-DH20(1)-DMH0(1))*2*Y(1)/VNODE1*DT      00003221
0047      IF(ABS(DELPC).GT. .1 * PC02(1)) DELPC=.1 * PC02(1)*DELPC/ABS(DEL 00003222
      XPC) 00003223
0048      IF(ABS(DELPH).GT. .1 * PH20(1)) DELPH=.1 * PH20(1)*DELPH/ABS(DEL 00003224
      XPH) 00003225
0049      PC02(1)=PC02(1) + DELPC 00003226
0050      PH20(1)=PH20(1) + DELPH 00003227
0051      IF (PC02(1)) 16, 17, 17 00003240
0052      16 PC02(1)=EACTC 00003250
0053      17 IF ( PH20(1)) 18,19,19 00003260
0054      18 PH20(1)=EACTH 00003270
0055      19 PT(1) = PH20(1) + PC02(1) 00003280
0056      PHOUT = PH20(1) 00003290
0057      PCOUT = PC02(1) 00003300
0058      IF(1.EQ. N) GO TO 23 00003310
0059      GO TO 30 00003320
      C 00003330
      CALCULATE AVERAGE TOTAL PRESSURE FOR LAST NODE 00003330
0060      25 PTA = (PT(1) + PCOUT)/2. 00003340
0061      DELW=Q/YG(1) 00003350
      C 00003360
      CALCULATE OUTLET FLOW OF LAST NODE 00003370
0062      DML(1) = DELW*PTA*(PT(1) + PCOUT) 00003380
0063      IF(1.EQ. 1) GO TO 20 00003390
0064      GO TO 15 00003400
0065      23 PHOUT = PH20(1) 00003410
0066      PCOUT = PC02(1) 00003420
0067      30 CONTINUE 00003430
0068      RETURN 00003440
0069      END

```

FORTRAN IV G LEVEL 20.1

PVAC

DATE = 72160

13/18/09

P175 C003

CR-115568  
SWHSR-6040

COMMON BLOCK /OUTPUT / MAP SIZE 198		COMMON BLOCK /BLOCK3 / MAP SIZE 320	
SYMBOL	LOCATION	SYMBOL	LOCATION
PT	0	FACTH	190
		FACTC	194

COMMON BLOCK /BLOCK3 / MAP SIZE 320	
SYMBOL	LOCATION
PC02	0
PH20	190

SCALAR MAP			
SYMBOL	LOCATION	SYMBOL	LOCATION
JIND	144	VB	148
R	158	L	150
A	160	EPS	170
J	180	DELW	184
DELPC	194	OT	198
POUT	1A8		

ARRAY MAP			
SYMBOL	LOCATION	SYMBOL	LOCATION
END	1AC	DMH	33C
C	34C	DM20	350

\*OPTIONS IN EFFECT\* ID,BCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = PVAC, LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 69, PROGRAM SIZE = 2760

\*STATISTICS\* NO DIAGNOSTICS GENERATED

Hamilton  
Standard



FORTHAN IV C LEVEL 20.1

PCAL

DATE = 72160

13/18/69

B175 CCG1

CR-115568  
SVHSR-6040

0001		SUBROUTINE PCAL II,DMI,DAD,PIN,POUT,DMQI	00003453
0002		DIMENSION DMI(1),DAD(1),PIN(1),POUT(1),DMQI(1)	00003453
0003		IF(DMI(1))15,10,5	00003473
0004	C	CALCULATE NODAL OUTLET PARTIAL PRESSURE	00003480
0005	5	IF(DAD(1)-DMI(1))16,7,7	00003473
0006	6	POUT(1) = (DMI(1)-DAD(1))* PIN(1)/DMI(1)	00003503
0007	C	CALCULATE NODAL OUTLET FLOW RATE OF CONSTITUENT IN LB-MOLES/MIN	00003513
0008	8	IF(POUT(1))18,8,10	00003523
0009	8	POUT(1) = 0.	00003533
0010	10	DMQI(1) = DMI(1)-DAD(1)	00003543
0011		GO TO 12	00003553
0012	7	DMQI(1) = 0.	00003563
0013		POUT(1) = 0.	00003573
0014	C	CALCULATE NODAL INLET FLOW RATE AND PARTIAL PRESSURE	00003583
0015	12	DMI(I+1) = DMQI(1)	00003593
		PIN(I+1) = POUT(1)	00003603
		RETURN	00003613
		END	00003623

ORIGINAL PAGE 1  
OF FOUR QUALITYHamilton  
Standard  
U  
A

FORTRAN IV G LEVEL 20.1

PCAL

DATE = 72160

13/18/09

0175 0002

CR-115568  
SWISER-6040

SYMBOL		LOCATION		SYMBOL		LOCATION		SYMBOL		LOCATION		SYMBOL		LOCATION	
I			C0												

SYMBOL		LOCATION		SYMBOL		LOCATION		SYMBOL		LOCATION		SYMBOL		LOCATION		
DMI			C4	DAD		CR			PIN		CC			PJUT		03

\*OPTIONS IN EFFECT\* ID,BCD,SOURCE,NOLIST,DECK,LOAD,MAP

\*OPTIONS IN EFFECT\* NAME = PCAL , LINECNT = 58

\*STATISTICS\* SOURCE STATEMENTS = 15, PROGRAM SIZE = 710

\*STATISTICS\* NO DIAGNOSTICS GENERATED

\*STATISTICS\* NO DIAGNOSTICS THIS STEP A

Hamilton  
StandardU  
A

F88-LEVEL LINKAGE EDITOR OPTIONS SPECIFIED MAP LIST  
 DEFAULT OPTION(S) USED - SIZE=(102400,16384)

CR-115568  
 SVHSER-604

MODULE MAP

CONTROL SECTION			ENTRY							
NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
MAIN	00	89FC								
TEMP	8A0C	1768								
AMHSC	A168	A14								
ALOGIC	AB80	37A								
FCUT	AF00	7FC								
PVAC	B700	AC8								
PCAL	C1C8	2C6								
BEGIN *	C49C	36E								
INCEXP *	C8C0	192	EXP	C800						
INCECUMH*	C998	F41	INCOMH	C998	EDINCSH	CA56	INTSWICH	D98F		
INCECUMH2*	D8E0	65D	SEODASD	DC58						
LOAD *	DF40	27C								
PPLOT *	E1C0	2274								
UNLIN *	10438	28E								
INCECVTH*	106F8	119D	ADCONH	106F8	FCVADUTP	107A2	FCVLOUTP	10832	FCV7OUTP	10982
			FCV1OUTP	10D30	FCVEOUTP	11232	FCVCOUTP	1144C	INTASWCH	11733
INCEFNTH*	11898	512	ARITH*	11898	ADISWICH	11C04				
INCFUVCH*	11DB0	44	OVCHK	11DB0						
INCFEXIT*	11DF8	1C	EXIT	11DF8						
INCEFIUS*	11E18	1378	FI0CS*	11E18	FI0CSHBP	11E1E				
INCERRM *	13190	58C	ERRMON	13190	INCERRE	131A8				
INCLOPT *	13750	300								
INCPOWER*	13A50	50	OVERFL	13A50						
INCSLOG *	13AA0	186	ALOG10	13AA0	ALOG	13AB8				
INCEMAXR*	13C58	C9	MAX1	13C58	MIN1	13C6E	AMAX1	13C84	AMIN1	13C94
INCEXPDR*	13D28	183	FKXPR*	13D28						
INCETRCH*	13E80	28E	INCTRCH	13E80	ERRTRA	13E88				
INCUTBI*	14140	20H								
PACK *	14348	182								
BLUK3	14400	320								

Hamilton  
 Standard

U  
 P

88-D

NAME	ORIGIN	LENGTH	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION	NAME	LOCATION
OUTPUT	147E0	198								
BLOK1	14986	640								
BLOK2	14FC8	30								


ENTRY ADDRESS 00  
TOTAL LENGTH 14FEB

\*\*\*MAIN DOES NOT EXIST BUT HAS BEEN ADDED TO DATA SET

CR-115568  
SWISER-6040

Hamilton  
Standard  
No.

## CHART TITLE - PROCEDURES



```

* PIH20, PIC02, *
* X0L, Y0L, Z0L, *
* KX, KY, KZ, *
* KX0, KY0, KZ0, *
* KZ3, MZ, PAIR, *
* Q, TCIN *
* * * * *
1
1
1 13
-----
/ WRITE TO DEV /
/ 6 /
/ VIA FORMAT /
/ 1016 /
/ FROM THE LIST /
-----
1
1
1 NOTE 14
* * * * *
* LIST = TGI, PIN, *
* POUT, ADSUR, *
* DESK00, D(41), *
* D(42), D(43), *
* WCT0T, D(44), *
* D(47), D(48), *
* D(51), D(52), *
* D(53), D(54), *
* D(55), D(56), *
* D(57), D(58), *
* D(59), D(60), *
* D(61), D(62), A, *
* EPS *
* * * * *

```

SET DATA ARRAY FOR  
AMHSC

```

13      |  NOTE 27
*****
*  BEGIN OF LOOP  *
*  14 1 = 1. 100  *
*****

03.03---|

INITIAL CONDITION FOR
DESCRIPTION

-----21
|  JAIR(1) = 1 |
|  (PAIR*Q/(R*TS)) |
|  *29. |
|  |
|  XR(1) = 0. |
|  |
|  YR(1) = 0. |
|  |
|  YHCR(1) = 0. |
|  |
|  ZR(1) = 0. |
|  -----
|

-----22
|  DM43(1) = 0. |
|  |
|  DC72(1) = 0. |
|  |
|  DM20(1) = 0. |
|  |
|  DM23(1) = 0. |
|  |
|  PCO2(1) = PICO2 |

```

/ 3.0]

**Hamilton Standard**

06/08/72

AUTOFLOW CHART SET - 4655

CR-115568  
SVHSR-6040

## CHART TITLE - PROCEDURES

/ 15 /

02.22---)\*

01

```

*-----*
| PH2O(I) = PIH2O |
| PHOUT(I) = PIH2O |
| PCOUT(I) = PIC02 |
| DMC(I) = 0. |
| DMH(I) = 0. |
*-----*

```

C2

```

*-----*
| TG(I) = TGI |
| TB(I) = TCIN |
*-----*

```

14

03

```

*-----*
| END OF DO |
| LOOP |
| YES |
| 21 |
| 04 |

```

04

```

*-----*
| TCOU = TCIN |
| TLOUTL = TCIN |
*-----*

```

```

*-----*
| END OF DO |
| LOOP |

```

YES

09

```

*-----*
| DIFF = |
| ABS(TCOU) - |
| TCOU |
| TCOU = TCOU |

```

13

02.19---)\*

NOTE 15

```

*-----*
| BEGIN DO LOOP |
| 15 I = 1, 100 |
*-----*

```

```

*-----*
| INITIAL CONDITION FOR |
| ADSORPTION |

```

16

```

*-----*
| PCAVG(I) = 0. |
| P1AVG(I) = 0. |
| WATER(I) = |
| (PAIR03/(R*TGI)) |
| *79. |
| XPI(I) = 0. |

```

17

```

*-----*
| Y3(I) = 0. |
| YHCR(I) = 0. |
| ZR(I) = 0. |
| DMH0(I) = 0. |
| DC02(I) = 0. |
| DMC0(I) = 0. |

```

18

```

*-----*
| PH2O(I) = 0. |

```

22

```

*-----*
| PTAC = |
| POUT*(PIC02/ |
| (PIC02*PIH2O)) |
| PTAC = PIUT - |
| PTAC |
| PC02(I) = PIC02 |
| PH2O(I) = PIH2O |

```

23

```

*-----*
| DMC(I) = |
| Q*PC02(I)/(Q*TCI) |
| DMH(I) = |
| Q*PH2O(I)/(Q*TCI) |
| TCOU = TCIN |
| TCOU = TCIN |

```

24

```

*-----*
| TCOU = TCIN |
| TCOU = TCIN |
| TCOU = TCIN |
| TCOU = TCIN |

```

17

```

*-----*
| PH2O(I) = 0. |

```

# Hamilton Standard





06/08/72

AUTOFLOW CHART SET - H465

CR-115568  
SWHSR-6040

## CHART TITLE - PROCEDURES

ORIGINAL PAGE 13  
OF FOUR QUALITYCALCULATIONS FOR N  
NODES EACH COMPUTING  
TIME INTERVALHamilton  
StandardU  
A

26 I NOTE 05  
\* \* \* \* \*  
\* CONTINUE \*  
\* \* \* \* \*

INITIAL CONDITIONS  
SET FOR EACH CASE

03.05\*--)

17

06

MTH20 = 0.

MFC02 = 0.

NOTE 07

\* \* \* \* \*  
\* BEGIN DO LOOP \*  
\* 20 I = 1, N \*  
\* \* \* \* \*

08

XCO2(I) =  
ICXC/(100.\*MFC02)

YH20(I) =  
IEYH/(100.\*MH20)

YHCO(I) =  
ICYHC/(100.\*MFC02)

09

ZH20(I) =  
ICZC/(100.\*MH20)

20 \* 10

NO

END OF DO  
LOOP

YES

/ WRITE TO DEV /  
/ VIA FORMAT /  
1005

12

TIME

(+)

125

IND

(+)

5

14

2002

5.01

2001

Hamilton  
Standard

U  
A

06/08/72

AUTOFLOW CHART SET - 4455

CR-115568  
SVHSER-6040

## CHART TITLE - PROCEDURES

ORIGINAL PAGE 11  
OF POOR QUALITYIS SYSTEM VACUUM  
DESORBING OR GAS  
PURGE DESORBING

04,16---)\*

2001 \* 01

IDES

1(-/0)

C9

34

2002 NOTE C2

\*\*\*\*\*  
\* BEGIN DO LOOP \*  
\* 35 J = 1, NJ \*  
\*\*\*\*\*

NOTE 03

\*\*\*\*\*  
\* BEGIN DO LOOP \*  
\* 35 I = 1, N \*  
\*\*\*\*\*SUBROUTINE USED FOR  
VACUUM DESORPTION

35 04

12 I H  
14 I PVAC H  
1. I (1,DT,N,1160, 0

05,01---11

09

PC02(I) = 0.

P420(I) = 0.

NOTE 10

\*\*\*\*\*  
\* BEGIN DO LOOP \*  
\* 2003 I = 1, N \*  
\*\*\*\*\*P40UT(I) =  
ABS(TG(I)\*DH20(I)  
\*R/O)PC0UT(I) =  
ABS(TG(I)\*DC02(I)  
\*R/O)

2003 \* 12

NO  
END OF DO  
LOOP

YES

13

PVAC(I) = 0.

IS SYSTEM PERFORMANCE  
ISOTHERMAL ??  
NONISOTHERMAL

05,08---11

120 \* 18

(-/0)

1507

2005 NOTE 10

\*\*\*\*\*  
\* BEGIN DO LOOP \*  
\* 2006 I = 1, N \*  
\*\*\*\*\*

121 \* 20

11 I  
12 I TEMP  
1. I (1,DT,TIME,N,  
10 I KC,ON,TKI,  
11 I TH3,TW3,HX,  
12 I WGT3,YG3,  
13 I WTR,DWCO,  
14 I DH40,TG,T3,  
15 I TC001

Standard

No

D-95




06/08/72

AUTOFLOW CHART SET - #465

CR-115568  
SVHSR-6040


## CHART TITLE - PROCEDURES

Hamilton  
Standard

No. 1

Line	Code	Text	Line	Code	Text	Line	Code	Text
1	PLPCOT(K) =	PCOUT(N)	1	PLMPCOT(K) =	PCOUT(N)	1	PLMPCOT(K) =	PCOUT(N)
2	MTG02 =		2	PLMPCOT(K) =	PCOUT(N)	2	PLMPCOT(K) =	PCOUT(N)
3	MTG02CAPC02(I)		3	PLMPCOT(K) =	PCOUT(N)	3	PLMPCOT(K) =	PCOUT(N)
4	*MZ/100.		4	PLMPCOT(K) =	PCOUT(N)	4	PLMPCOT(K) =	PCOUT(N)
5			5	PLMPCOT(K) =	PCOUT(N)	5	PLMPCOT(K) =	PCOUT(N)
6			6	PLMPCOT(K) =	PCOUT(N)	6	PLMPCOT(K) =	PCOUT(N)
7			7	PLMPCOT(K) =	PCOUT(N)	7	PLMPCOT(K) =	PCOUT(N)
8			8	PLMPCOT(K) =	PCOUT(N)	8	PLMPCOT(K) =	PCOUT(N)
9			9	PLMPCOT(K) =	PCOUT(N)	9	PLMPCOT(K) =	PCOUT(N)
10			10	PLMPCOT(K) =	PCOUT(N)	10	PLMPCOT(K) =	PCOUT(N)
11			11	PLMPCOT(K) =	PCOUT(N)	11	PLMPCOT(K) =	PCOUT(N)
12			12	PLMPCOT(K) =	PCOUT(N)	12	PLMPCOT(K) =	PCOUT(N)
13			13	PLMPCOT(K) =	PCOUT(N)	13	PLMPCOT(K) =	PCOUT(N)
14			14	PLMPCOT(K) =	PCOUT(N)	14	PLMPCOT(K) =	PCOUT(N)
15			15	PLMPCOT(K) =	PCOUT(N)	15	PLMPCOT(K) =	PCOUT(N)
16			16	PLMPCOT(K) =	PCOUT(N)	16	PLMPCOT(K) =	PCOUT(N)
17			17	PLMPCOT(K) =	PCOUT(N)	17	PLMPCOT(K) =	PCOUT(N)
18			18	PLMPCOT(K) =	PCOUT(N)	18	PLMPCOT(K) =	PCOUT(N)
19			19	PLMPCOT(K) =	PCOUT(N)	19	PLMPCOT(K) =	PCOUT(N)
20			20	PLMPCOT(K) =	PCOUT(N)	20	PLMPCOT(K) =	PCOUT(N)
21			21	PLMPCOT(K) =	PCOUT(N)	21	PLMPCOT(K) =	PCOUT(N)
22			22	PLMPCOT(K) =	PCOUT(N)	22	PLMPCOT(K) =	PCOUT(N)
23			23	PLMPCOT(K) =	PCOUT(N)	23	PLMPCOT(K) =	PCOUT(N)
24			24	PLMPCOT(K) =	PCOUT(N)	24	PLMPCOT(K) =	PCOUT(N)
25			25	PLMPCOT(K) =	PCOUT(N)	25	PLMPCOT(K) =	PCOUT(N)
26			26	PLMPCOT(K) =	PCOUT(N)	26	PLMPCOT(K) =	PCOUT(N)
27			27	PLMPCOT(K) =	PCOUT(N)	27	PLMPCOT(K) =	PCOUT(N)
28			28	PLMPCOT(K) =	PCOUT(N)	28	PLMPCOT(K) =	PCOUT(N)
29			29	PLMPCOT(K) =	PCOUT(N)	29	PLMPCOT(K) =	PCOUT(N)
30			30	PLMPCOT(K) =	PCOUT(N)	30	PLMPCOT(K) =	PCOUT(N)
31			31	PLMPCOT(K) =	PCOUT(N)	31	PLMPCOT(K) =	PCOUT(N)
32			32	PLMPCOT(K) =	PCOUT(N)	32	PLMPCOT(K) =	PCOUT(N)
33			33	PLMPCOT(K) =	PCOUT(N)	33	PLMPCOT(K) =	PCOUT(N)
34			34	PLMPCOT(K) =	PCOUT(N)	34	PLMPCOT(K) =	PCOUT(N)
35			35	PLMPCOT(K) =	PCOUT(N)	35	PLMPCOT(K) =	PCOUT(N)
36			36	PLMPCOT(K) =	PCOUT(N)	36	PLMPCOT(K) =	PCOUT(N)
37			37	PLMPCOT(K) =	PCOUT(N)	37	PLMPCOT(K) =	PCOUT(N)
38			38	PLMPCOT(K) =	PCOUT(N)	38	PLMPCOT(K) =	PCOUT(N)
39			39	PLMPCOT(K) =	PCOUT(N)	39	PLMPCOT(K) =	PCOUT(N)
40			40	PLMPCOT(K) =	PCOUT(N)	40	PLMPCOT(K) =	PCOUT(N)
41			41	PLMPCOT(K) =	PCOUT(N)	41	PLMPCOT(K) =	PCOUT(N)
42			42	PLMPCOT(K) =	PCOUT(N)	42	PLMPCOT(K) =	PCOUT(N)
43			43	PLMPCOT(K) =	PCOUT(N)	43	PLMPCOT(K) =	PCOUT(N)
44			44	PLMPCOT(K) =	PCOUT(N)	44	PLMPCOT(K) =	PCOUT(N)
45			45	PLMPCOT(K) =	PCOUT(N)	45	PLMPCOT(K) =	PCOUT(N)
46			46	PLMPCOT(K) =	PCOUT(N)	46	PLMPCOT(K) =	PCOUT(N)
47			47	PLMPCOT(K) =	PCOUT(N)	47	PLMPCOT(K) =	PCOUT(N)
48								

## CHART TITLE - PROCEDURES

ORIGINAL PAGE 1  
OF FOUR QUALITY

RECEIVING PAGE BLANK NOT FILMED

```

      I / VIA FORMAT /
      I / 1033 /
      I /-----/
      I / 06.14*--/
      I / 150 I NOTE 15
      I / CONTINUE /
      I /-----/
      I / 210 I NOTE 25
      I / CONTINUE /
      I /-----/
      I / 07
      I / WRITE TO DEV /
      I / 6 /
      I / VIA FORMAT /
      I / 1022 /
      I / FROM THE LIST /
      I /-----/
      I / NOTE 08
      I / LIST = PIN,
      I / (PT(I),I = 1,N),
      I / POUT
      I /-----/
      I / 07.23--/
      I / 1030 I 09
      I /-----/
      I / WRITE TO DEV /
      I / 6 /
      I / VIA FORMAT /
      I / 1023 /
      I /-----/
      I / 10
      I / WRITE TO DEV /
      I / 6 /
      I / VIA FORMAT /
      I / 1024 /
      I / FROM THE LIST /
      I /-----/
      I / 161 I 19
      I / 12 I 4
      I / 10 I ALOGIC H
      I / 10 I (TIME, ADSORB, H
      I / 12 I DESORB, IND, H
      I / 11 I JIND, TMAX, 4
      I / 1 I PRLAST, NPRINT) 4
      I /-----/
      I / 20
      I / ...
      I / 8.72.
      I / ... 163

```





```

I I .1,7,0,1,0.. * H
I I TOTALCO2LOADIN H
I I G * ,500) H

```

C5

```

I I PPLUT H
I I (PLTIME, H
I I PLPHOT,K, H
I I * * * H
I I .1,7,0,1,0.. * H
I I OUTLETPARTIALP H
I I RESSUREOFH2O * H
I I ,500) H

```

C6

```

I I PPLUT H
I I (PLTIME, H
I I PLPCOT,K, H
I I * * * H
I I .1,7,0,1,0.. * H
I I OUTLETPARTIALP H
I I RESSUREOFCO2 * H
I I ,500) H

```

C7

```

I I PPLUT H
I I (PLTIME, H
I I PLNTYH,K, * H
I I ( * H
I I .1,7,0,1,0.. * H
I I OUTLEYCOOLANTY H
I I EMPEPATIURE * H
I I ,500) H

```

C9

```

I I PPLUT H
I I (PLTIME, H
I I PLM242,K, H
I I * * * H
I I .1,7,0,1,0.. * H
I I OUTLETPRESSO H
I I ASTEMPERATJRE H
I I ,500) H

```

I 10

...

... 2.04.

... 10

Hamilton  
Standard

06/08/72

AUTJELJW CHART SET - 1455

CR-115568  
SVHSR-6040

## CHART TITLE - NON-PROCEDURAL STATEMENTS

REAL KX , KX2 , KY , KYR , KYH , KYHR , KZ ,  
 KZR , ICXC , ICYH , ICZC , ICYHC , MZT , MH2D , MCO2 ,  
 MYCO2 , LXC02 , LYH2D , LZH2 , LTH2D , LTC02 , LYHC ,  
 MZ , MTH2D , ISJT , IDES

DIMENSION D 2001 , HDL 201 , PC02 1001 , PH2D 1001 ,  
 DMC 1001 , DMH 1001 , XC02 1001 , YH2D 1001 , YMOCD 1001 ,  
 ZH2D 1001 ,  
 XR 1001 , YR 1001 , YHCX 1001 , Z2 1001 ,  
 OH2D 1001 , PHOUT 1001 ,

DMHO 1001 , DC02 1001 , PCOUT 1001 , DMCO 1001

## DIMENSION

PLTIME 5001 , PLPCTL 5001 , PLPHOT 5001 , PLPCST 5001

DIMENSION PLMXC 5001 , PLMYC 5001 , PLMYH 5001 , PLMZH2 5001

DIMENSION APH2D 1001 , APC02 1001 , CON 121 , C 41

DIMENSION WAIR 1001 , QR 1001 , TB 1001 , TC 1001 , CNI 161 ,

TK1 201 , THB 201 , TMC 201 , HX 201

EQUIVALENCE D 11 , DT 1 , D 21 , TMAX 1 ,

D 31 , PRINT 1 , D 41 , PLNT 1 , D 51 , FN 1 ,

D 61 , AIND 1 , D 71 , IDES 1 , D 81 , ISOT 1 ,

D 91 , XJ 1

EQUIVALENCE D 111 , ICXC 1 , D 121 , ICYH 1 ,

D 131 , ICZC 1 , D 141 , ICYHC 1 , D 151 , PH2D 1 ,

D 161 , PIC02 1

EQUIVALENCE D 211 , XHI 1 , D 221 , YDI 1 ,

D 231 , XHI 1 , D 241 , YDI 1 ,

Hamilton  
StandardU  
A

D 261,KY (, D 271,KYH (, D 281,KYH (,  
 D 291,KYHR (, D 301,KZ (, D 311,KZR (,  
 D 321,MZT (, D 331,PAIR (, D 341,Q (,  
 D 351,TCIN (, D 361,TGI (, D 371,PIV (,  
 D 381,PQUT (, D 391,ADSORB (, D 401,DESORB (,  
 D 411,C II (, D 451,WCTDT (, D 461,CVI II (

EQUIVALENCE D 1011,TK1 III, D 1211,T4B III,  
 D 1411,TWC III, D 1611,HX III, D 421, PRLAST  
 , D 631,AI, D 641,EPST

DIMENSION PCAVG 1001, PHAVG 1001

DIMENSION DMO 1001, DTOT 1001, PT 1001, TFA 1001

COMMON/BLOCK /PLAVG,PHAVG

COMMON/OUTPUT/PT, FACTH, FACTC

COMMON/BLOCK1/XR,YR,VHCR,ZR

COMMON/BLOCK2/CON

1020 FORMAT IH1, 20A41

1000 FORMAT @GINPUT@ /2X,

8H DT ,G12.6,8H TMAX ,G12.6,8H PRINT ,G12.6,  
 8H PLOT ,G12.6,8H FN ,G12.6,8H INJ ,G12.6/2X,  
 8H IDES ,G12.6,8H ISOT ,G12.6,8H XJ ,G12.6,  
 8H ICXC ,G12.6,8H ICYH ,G12.6,8H ICZC ,G12.6/2X,  
 8H ICYHC ,G12.6,8H PIH20 ,G12.6,8H PIC02 ,G12.6,

06/08/72

AUTOFLOW CHART SET - H455

CR-115568  
SVHSR-6040

## CHART TITLE - NON-PROCEDURAL STATEMENTS

ORIGINAL PAGE 1  
OF POOR QUALITY

8H XOL ,G12.6,8H YOL ,G12.6,8H ZOI ,G12.6/2X,  
 8H KX ,G12.6,8H KXR ,G12.6,8H KY ,G12.6,  
 8H KYP ,G12.6,8H KYH ,G12.6,8H KYHR ,G12.6/2X,  
 8H KZ ,G12.6,8H KZR ,G12.6,8H 47T ,G12.6,  
 8H PAIR ,G12.6,8H O ,G12.6,8H TCIN ,G12.6/1

1016 FORMAT 2X,

8H TGI ,G12.6,8H PIN ,G12.6,8H POUT ,G12.6,  
 8H ADSORB ,G12.6,8H DESORB ,G12.6,8H V6 ,G12.6/2X,  
 8H XMU ,G12.6,8H DIA ,G12.6,8H WCTOT ,G12.6,  
 8H CPC ,G12.6,8H LB ,G12.6,8H ABHXT ,G12.6/2X,  
 8H AAMBT ,G12.6,8H WHX ,G12.6,8H WRED ,G12.6,  
 8H CPHX ,G12.6,8H CPHED ,G12.6,8H AB ,G12.6/2X,  
 8H AHX ,G12.6,8H KB ,G12.6,8H KHX ,G12.6,  
 8H TAMB ,G12.6,8H NAMB ,G12.6,8H NPT1 ,G12.6/2X,  
 8H NPT2 ,G12.6,8H PRIAST ,G12.6,8H A ,G12.6,8H EPS

,G12.6/1

1013 FORMAT @OHX SUBROUTINE WILL NOT REACH SS2/I

1005 FORMAT 1HL, @OUTPUT@,1

1001 FORMAT ///2X-

8H TIME G12.6,8H PCT1 G12.6,8H TCOUT G12.6,20X,

8H EFFH G12.6,8H EFFC G12.6/2X,

8H LTH20 G12.6,8H LTC02 G12.6,8H LYH20 G12.6,8H L742

G12.6,8H LXC02 G12.6,8H LYHC G12.6/1

1002 FORMAT @OHT PCT ADSORBED BY NODH S2/

Hamilton  
StandardU  
R

1004	FORMAT 2	LT-20	2,13X,8G13.5I
1015	FORMAT 2	FLOW RATE	LB-MOLES/MIN( BETWEEN NOOFSDI
1006	FORMAT 2	CO2	2, 6X,8G13.5I
1007	FORMAT 2	H2O	2, 6X,8G13.5I
1009	FORMAT 2	TOTAL	2, 6X,8G13.5I
1010	FORMAT 2	RATE OF ADSORPTION	LB-MOLES/MIN( BY NOOES2I
1011	FORMAT 2	CO2	2,13X,8G13.5I
1012	FORMAT 2	H2O	2,13X,8G13.5I
1014	FORMAT 2	TOTAL	2,13X,8G13.5I
1018	FORMAT 2	PRESSURES BY NODE,	INCLUDING BOTH ENDS MM HG(2I
1017	FORMAT 2	CO2	2,9G13.5I
1019	FORMAT 2	H2O	2,9G13.5I
1022	FORMAT 2	TOTAL	2,9G13.5I
1023	FORMAT 2	TEMPERATURES	OF G F(2I
1024	FORMAT 2	GAS	2,13X,8G13.5I
1025	FORMAT 2	BED	2,13X,8G13.5I
1033	FORMAT 2		2I2I



```

/ WRITE TO DEV /
/      6      /
/ VIA FORMAT /
/    1212    /
/ FROM THE LIST /

```

```

      1  NOTE 2)
*****
* LIST = (HX(J),J =
*          1,NPT2)

```

10 1 NOTE 22  
\* \* \* \* \*  
\* CONTINUE \*  
\* \* \* \* \*

CALCULATE CONSTITUENT  
WEIGHT FLOW

	I	23
I	NC72(1) =	I
I	DMC7(1)*44.	I
I		I
I	PH22(1) =	I
I	DMH2(1)*18.	I

CALCULATE HEAT OF ADSORPTION

	I	25
I	02(I) =	
I	0000(I)	
I	*1600.0000(I)	
I	*1600.	
I		
I	<1 -	
I	WAIPI(I)EW72(I)	
I	EW72(I)	

[illegible]

```

      27
-----
      ( ? =
      {JA[R(I)}
      *.ZGdW22(I)*.64)
      /K)
-----

```

# Hamilton Standard

10




06/08/72

AUTOFLOW CHART SET - H455

CR-115568  
SVHSER-6040

CHART TITLE - SUBROUTINE TEMP(I,DT,TIME,N,JIND,CON,TK1,TMB,TWC,HX,WCVOT,TCIN,WA


 FLOWCHART  
 Standard  
 No.

```

      I INPI,TKI,THB, H
      I K11,HB,IUF)  H
      I                                     H

```

```

      I TRUE

```

```

      CALCULATION OF HEAT
      FLOW FROM PROCESS GAS
      TO BED

```

```

      06

```

```

      12

```

```

      22

```

```

      17

```

```

      FALSE

```

```

      IUF .NE. 0

```

```

      / WRITE TO DEV /

```

```

      Q1 = (TG1 -

```

```

      T3(I))

```

```

      *K1*K2*(1. - AA)

```

```

      (H-HX =

```

```

      19*HX/(HBSHX))

```

```

      I TRUE

```

```

      NOTE 13

```

```

      * * * * *
      LIST = 1LF
      * * * * *

```

```

      CALCULATION OF HEAT
      FLOW FROM HEAT
      EXCHANGER TO BED

```

```

      07

```

```

      / WRITE TO DEV /

```

```

      / VIA FORMAT /

```

```

      1000

```

```

      / FROM THE LIST /

```

```

      14

```

```

      18

```

```

      52

```

```

      22

```

```

      Q2 =

```

```

      UBHX*ABHX*(THX(I)

```

```

      - T3(I))

```

```

      Q3 = 0.

```

```

      Q7 = 0.

```

```

      * K11 .EQ. 0.

```

```

      I TRUE

```

```

      NOTE 08

```

```

      * * * * *
      LIST = IUF
      * * * * *

```

```

      I FALSE

```

```

      19

```

```

      50

```

```

      21

```

```

      OBTAIN HEAT TRANSFER
      COEFFICIENT BETWEEN
      HEAT EXCHANGER AND
      AMBIENT AS A FUNCTION
      OF COOLANT FLOW RATE

```

```

      15

```

```

      A =

```

```

      HB*ABHX/(K11*(2)

```

```

      AA = EXP(-A)

```

```

      (+)

```

```

      (C/+)

```

```

      14.01

```

```

      ... 30

```

```

      14.05

```

```

      ... 70

```

Standard  
11-11-70

11-11-70

06/08/72

AUTOFLOW CHART SET - H465

CR-115568  
SVHSR-6040

CHART TITLE - SUBROUTINE TEMP(I,DT,TIME,N,JEND,CON,TKI,THB,TWC,HX,WCTOT,TCIN,WA

ORIGINAL PAGE  
OF POOR QUALITY

13.19---)\*  
30 I 01  
CALCULATION OF NODAL  
CONDUCTIVE HEAT FLOW  
IN BED

Q3 = K3\*(TB(I) -  
I) - TB(I))  
I

CALCULATION OF NODAL  
CONDUCTIVE HEAT FLOW  
IN HEAT EXCHANGER

Q7 = K4\*(THX(I) -  
I) - THX(I))  
I

13.21.

... 50

CALCULATION OF NODAL  
CONDUCTIVE HEAT FLOW  
IN BED

13.21---I  
Q5  
Q4 = 0.  
Q8 = 0.  
I

80 I NITE 04  
\*\*\*\*\*  
CONTINUE  
\*\*\*\*\*

CALCULATE BED  
TEMPERATURE AND  
PROCESS GAS  
TEMPERATURE

Q7  
TH(I) =  
TB(I)  
L1Q1EQ2EQR(I)  
EQ3EQ4)\*DT/PCB  
TG(I) =  
TB(I)\*E(TGI -  
TB(I))\*AA  
TGI = TG(I)

08  
B =  
HXX\*ALHX/(WC\*CPG)  
I

CALCULATION OF  
HEATING FLOW TO HEAT

12

(-)

I - N

IIC/0)

100

13.21---)\*  
60 I 03

Q4 =  
K3\*(TB(16)) -  
TB(11)

CALCULATION OF NODAL  
CONDUCTIVE HEAT FLOW  
IN HEAT EXCHANGER

04

Q8 =  
K4\*(THX(16)) -  
THX(11)

CALCULATION OF HEAT  
FLOW FROM AMBIENT TO  
HEAT EXCHANGER

10

Q5 =  
UAMB\*AAAMB\*(TAMB -  
THX(11))

CALCULATE HEAT  
EXCHANGER AND COOLANT  
OUTLET TEMPERATURES

11

THX(1) =  
THX(11)\*Q5 -  
Q262566/75.29)  
\*DT/MCHX

TCOUT(1) =  
THX(11)\*TCIN -  
THX(1)\*EXP(-R)

TCOUT = 0.

NOTE 14

\*\*\*\*\*  
BEGIN DO LOOP  
105 I = 1, N  
\*\*\*\*\*

15

TCOUT1 =  
TCOUT1\*TCOUT(1)

105 16

END OF DO  
LOOP

YES

CALCULATION OF  
COOLANT OUTLET  
TEMPERATURE

17

TCOUT = TCOUT1/N

110 NOTE 18

CONTINUE

19

EXIT

CR-115568  
SVHSER-6040

Hamilton  
Standard

U  
A

06/08/72

AUTOFLOW CHART SET - H455

CR-115568  
SVHSER-6040

CHART TITLE - NON-PROCEDURAL STATEMENTS

REAL LB , K1 , K2 , K3 , MCR , K4 , MCHX ,

KB, KHX ,K11

DIMENSION WAIR 1001 , W072 1001 , #423 1001 , TX1 201 ,

THB 201 , TWC 201 , HX 201 , 31 1001 , TB 1001 ,

TBPRM 1001, THAPRM 1001, TCOJT 1001,

THX 1001, CON 161, TG 1001, DMCO 1001, DMH3 1001

1011 FORMAT #OH1WF K11 TABLE1

1012 FORMAT 1X,10G12.61

1013 FORMAT #CH1XWF K11 TABLE21

1000 FORMAT 20K1 OFF TABLE - 10F#2,111

1001 FORMAT #0WC OFF TABLE - 10F#2,111

ORIGINAL PAGE 1  
OF POOR QUALITY

Hamilton  
Standard

H  
A

CHART TITLE - SUBROUTINE AMHSC(I,IND,JIND,IOES,DT,T,N,PH2O,PHOUT,PCO2,PCOUT,DH2


```

      / AMHSC /
      -----
            I
04.14----I
            I                                O1
-----*-----
| MZ = MZI/N | |
| MH2O = 18. | |
| MC02 = 44. | |
-----*-----
            I
            I
            I
CONVERT ULTIMATE
CAPACITY FROM PERCENT
TO LB-MOLES/LB
            I
            I                                O2
-----*-----
| XI! = | |
| XOL/(100.*MC02) | |
| YD = | |
| YOL/(100.*MH2O) | |
| ZO = | |
| ZOL/(100.*MH2O) | |
| YHZO(I) = | |
| YHZO(I) - | |
| YHCO(I) | |
-----*-----
            I
            I
            * O3
          * *
        * *
    * * * TRUE
* JIND ,EQ. - 1 *-+
    * *
        * *
            * IFALSE , 17 .
            I , O1 .

```

# Hamilton Standard

ORIGINAL PAGE 1  
OF FOUR QUARTS



16.04\*--11  
06  
PCAVG(I) =  
(PCD2(I)&PCOUT(I))  
1/2.

CALCULATE AVERAGE  
NODE PARTIAL  
PRESSURES IF NOT BY  
VACUUM DESCRPTI

07  
PCAVG(I) =  
(PCD2(I)&PCOUT(I))  
1/2.

.17.06.  
... 7

Hamilton  
Standard



U  
A

06/08/72

AUTIFLOW CHART SET - H665

CR-115568  
SVHSER-6040

CHART TITLE - SUBROUTINE AMH, C(I, IND, JIND, IDES, DT, T, N, PH20, PHOUT, PCO2, PCOJT, PH2



## Hamilton Standard

23



16.05\*- - ) I

I		07
I	YHCR(I) =	I
I	YH20(I)	I
I	*KYH*PCAVG(I) -	I
I	YHUCO(I)*KYHR	I
I		I
I	ZR(I) =	I
I	KZ*PHAVG(I)*Z0 -	I
I	ZH20(I) -	I
I	KZR*ZH20(I)	I

LIMITING CO2  
ADSORPTION RATE

```

30      *      11
      *      *
      *      *
      *      *
      * X2(I) * (-/2)
      * CYMR(I) - *+
      * QMC(I)/M2 * 1
      *      *

```

```

50      1      12
*-----*
1      XP(I) =      1
1      (XP(I)/XP(I)      1
1      EYHCR(I))*DMC(I)      1
1      /47      1
1      1      1
1      YHCR(I) =      1
1      DMC(I)/47 - YR(I)      1


```

C5/08/72

AUTOFLOW CHART SET - 4455

CR-115568  
SVHSER-6040

CHART TITLE - SUBROUTINE AMHSC(I,IND,JIND,TUES,DT,T,N,PH20,PH00T,PC0J2,PC0J1,DH2

Hamilton  
StandardU  
A



06/08/72

AUTOFLOW CHART SET - H4A5

CR-115568  
SVHSER-6040

CHART TITLE - NON-PROCEDURAL STATEMENTS

REAL KX,KXR,KY,KYR,KYH,KYHR,KZ,KZR,MZ,MZT,MC02,MH2D

COMMON/BLOCK1/XP,YR,VHCR,ZR

COMMON/BLOCK3/PCAVG,PHAVG

COMMON/BLOCK2/CON

DIMENSION PH2D 1001,PHOUT 1001,PC02 1001,PCOUT 1001,DH2D 1001,

DC02 1001,DH 1001 ,DMC 1001 ,XC02 1001 ,YH2D 1001,

YH0D 1001 ,Z42D 1001 ,XR 1001 ,YR 1001 ,YHCR 1001,

ZR 1001,CON 121,TVH2D 1001,PHAVG 1001,PCAVG 1001,

T 1001

EQUIVALENCE CON 11,X01 1, CON 21,Y01 1, CON 31,Z01 1,

CON 41,KX 1, CON 51,KXR 1, CON 61,KY 1, CON 71,KYR 1,

CON 81,KYH 1, CON 91,KYHR 1, CON 101,KZ 1, CON 111,KZT 1,

CON 121,MZT1

Hamilton  
Standard  
No. 1

06/08/72

AUTODELOW CHART SET - H465

CR-115568  
SWISER-6040

CHART TITLE - SUBROUTINE ALOGIC(TIME, ADSORB, DESORB, IND, JIND, TMAX, PRELAST, NPRINT)

/ ALOGIC /

08.19\*--)

01

TIME

(+)

10

04

((-/0)

\* TIME - SWITCH \*

(-)

50

09

JIND = 0

(10/+)

20.06\*--)

60

NOTE 10

\*\*\*\*\*

CONTINUE

\*\*\*\*\*

5

02

IND

(+)

20

05

((-/0)

IND

(+)

(0) \*

JIND

(+)

95

14

VHCY = VHCYE1

6

03

SWITCH = ADSORB

((-/0)

20

(-)

17

96

30

06

SWITCH =

SWITCH DESORB

IND = 1

JIND = 1

92

12

VHCY = 0

VHCY =

2.0 TMAX / (ADSORB

(-/+)

VHCY =

VHCY = 2

# Hamilton Standard

06/08/72

A-100104 CHART SET - H455

CR-115568  
SWISER-6040

CHART TITLE - SUBROUTINE FOUT(TIME,DT,N,MOLWT,MZT,DMH,X1,X2,LTOT,PCTL,PCMI,PCM2

ORIGINAL PAGE 1  
OF POOR QUALITY

```

      / FOUT /
      -----
      05.23*--)|
      *
      * 02
      *
      * (+) *
      * TIME *
      *
      *
      * (-/0)
      *
      *
      * 10 | 03
      *-----*
      * H2OTOT = 0. |
      * H3OTOT = 0. |
      * EFF = 100. |
      * MZ = MZT/N |
      * AMTOT1 = 0. |
      * AMTOT2 = 0. |
      *-----*
      * 20 | NDTF 04
      * * * * *
      * MSGIN DD LOOP *
      * 40 I = 1, N *
      * * * * *
      *-----*
      * CALCULATE WEIGHT LOSS
      * OF CONSTITUENT ON
      * EACH STIFF/NOFF
      *

```

Hamilton  
Standard

H

CR-115568  
SVHSR-6040

```

      AX1(I) =
      X1(I)*M2*MOLWT
      AX2(I) =
      X2(I)*M2*MOLWT

```

```

      CALCULATE PERCENT
      LOADING OF
      CONSTITUENT PER NODE

```

```

      06
      -----
      LTOT(I) =
      (AX1(I)+AX2(I))
      *100./M2

```

```

      40 * 07

```

```

      40 *
      -----
      END OF DO
      LOOP

```

```

      YES

```

```

      CALCULATE AMOUNT OF
      CONSTITUENT THRU BED
      EACH TIME INTERVAL
      LBS./

```

```

      122.01

```

Hamilton  
Standard

U  
H




06/08/72

AIRFLOW CHART SET - 4465

CR-115568  
SVHSR-6040

CHART TITLE - SUBROUTINE FOUT(TIME,DT,N,MOLWT,MZT,DMH,X1,X2,LTOT,PCTL,PCN1,PCN2)

Harrison  
Standard  
J

CALCULATE TOTAL  
WEIGHT LBS/L OF  
CONSTITUENT ON BED

\* MCLWT = 14. \*  
\* \* \* \*

\* \* \* 14  
\* \* \*  
\* \* \* TRUE

\* DMH(1) .EQ. \*  
\* 0. \*  
\* \* \*

05

11-70

65 1 17

AMT01 = AMXLEAMX2

AMT012 = AMT01

FALSE

AMT012 = 0.

CALCULATE TOTAL  
LOADING OF  
CONSTITUENT ON BED

01 10  
\* \* \*  
H20TOT =  
H20TOT\*FCT2

22.08--11

70 1 VOTE 13

\* \* \* \* \*

\* CONTIN IF \*

\* \* \* \* \*

06

PCT1 =

11

AMT01\*100./H2T

AMT20 = AMT01 +

AMT012

EFF =

AMT20\*100./H2T

119

EXIT

CALCULATE TOTAL  
LOADING OF  
CONSTITUENT ON EACH  
SITE

\* \* \* TRUE  
\* DMH(1) .EQ. \*  
\* 0. \*  
\* \* \*

IF FALSE

07

PCN1 =

AMX1\*100./H2T

PCN2 =

AMX2\*100./H2T

FCT2 =

DT\*DMH(1)\*MCLWT

CALCULATE REMOVAL  
EFFICIENCY

12

AMT10 = AMT01 -

AMT01

EFF =

AMT20\*100./H2T

65 1 16

AMT01 = AMT01

AMT012 = 0.

22.18.

70

Hamilton  
Standard  
As

06/08/72

AUTOFLOW CHART SET - H455

CR-115568  
SVHSER-6040

CHART TITLE - NON-PROCEDURAL STATEMENTS

REAL MOUT, MZ, MZT, LTOT

DIMENSION X1 1001, X2 1001, LTOT 11, DMH 1001

DIMENSION AX1 1001, AX2 1001

Hamilton  
Standard

U  
P

06/08/72


AUTOFLOW CHART SET - 4455

CR-115568  
SWHSR-6040

CHART TITLE - SUBROUTINE PVAC11,DT,N,JIND,C,DH2O,DCO2,PIV,PJUT,DMHO,DMCO,PHJUT,


/ PVAC /

05.04---)\*

SET VALUES FOR  
CONSTANTS DURING  
FIRST PASSHamilton  
StandardU  
A


ORIGINAL PAGE 11  
OF POOR QUALITY

CR-115568  
SVHSER-6040



REVISION  
Standard

CHART TITLE - SUBROUTINE PVAC(I,DT,N,JIND,C,DH2O,SCO2,PIN,POUT,QMHO,QMCO,PHOUT.



# Hamilton Standard

CALCULATE H2O AND CO2  
OUTLET FLOW RATES -  
LB-MOLE/MIN/NODE

24.16\*-11

20

05

K = 1

06

FALSE

DMO(I) .LT.

0.

TRUE

07

K = K+1

FALSE \*ABS(DELPH) \*

.GT.

\*.1\*PH2O(I) \*

TRUE

13

DELPH =

.1\*PH2O(I)

\*DELPH/ABS(DELPH)

14

PCO2(I) =

PCO2(I)+DELPH

PH2O(I) =

PH2O(I)+DELPH

(0/\*)

PH2O(I)

18

18

PH2O(I) = FACTH

19

19

PT(I) =

PH2O(I)+PCO2(I)

PHOUT = PH2O(N)

PCOUT = PCO2(N)

20

TRUE

.EQ. V

FALSE

21

21

PHOUT = PH2O(N)

PCOUT = PCO2(N)

22

NOTE 22

CONTINUE

23

EXIT

RAMMION  
Standard

U  
A

06/08/72

AUTOFLOW CHART SET - 4465

CR-115568  
SVHSER-6040

CHART TITLE - NON-PROCEDURAL STATEMENTS

COMMON/OUTPUT/PT, FACTH, FACTC

COMMON/BLOCK3/PCD2,PH2D

DIMENSION DMD 1001,DMH 1001,DMC 1001,DMHD 1001,

DMCO 1001,PH2D 1001,PCD2 1001,PT 1001, C 41

DM2D 1001, DCU2 1001,TS 1001


REAL 1


Hamilton  
Standard

U  
R



CHART TITLE - SUBROUTINE PCAL(I,DMI,DAD,PIN,POUT,PNI)

ORIGINAL PAGE 1  
OF 1008 QUINTEHamilton  
StandardU  
A



06/08/72

AUTOFLOW CHART SET - 1465

CR-115568  
SWISER-6040

CHART TITLE - NON-PROCEDURAL STATEMENTS

DIMENSION DMT 11,DAD 11,PIN 11,POUT 11,3ND 11

Horizontal  
Standard

U  
A

TEST NO. \_\_\_\_\_

HAMILTON STANDARD

PAGE 1 OF 6

PLAN OF TESTJOB: Desiccant Humidity Control SystemPLAN PREPARED BY: P. J. LundePROJECT & ORDER: E61-100-000A

APPROVED BY: \_\_\_\_\_

INSTRUCTION: Large Scale Improved HS-C Material  
Demonstration TestTEST ENGINEER: H. KolnsbergTIME PERIOD: January 1972 TO January 1972

1. WHAT IS ITEM BEING TESTED?
2. WHY IS TEST BEING RUN? WHAT WILL RESULTS SHOW OR BE USED FOR?
3. DESCRIBE TEST SET UP INCLUDING INSTRUMENTATION. ATTACH SKETCH OF INSTALLATION.
4. ITEMIZE RUNS TO BE MADE GIVING LENGTH OF EACH AND READINGS TO BE TAKEN.
5. SPECIAL INSTRUCTIONS: SAFETY PRECAUTIONS FOR OPERATORS AND HANDLING EQUIPMENT. OBSERVATIONS BY SIGHT, FEEL, OR HEARING. LIST POINTS OF OBSERVATION WHICH MIGHT CONTRIBUTE TO ANALYSIS OF (A) PERFORMANCE OF UNITS, (B) INCIPIENT TROUBLE BEFORE IT OCCURS, AND (C) CAUSE OF FAILURE.
6. HOW WILL DATA BE USED OR FINALLY PRESENTED? GIVE SAMPLE PLOT, CURVE, OR TABULATION AS IT WILL BE FINALLY PRESENTED.

NUMBER ENTRY AS LISTED ABOVE AND DESCRIBE BELOW1. 5 lbs. HS-C, prepared by Hamilton Standard.2. To demonstrate improved HS-C material for use on shuttle for  
desiccant and CO<sub>2</sub> control, in a full scale test.3. The conditioned air to the canister is run in a closed loop, i.e. air  
effluent from the canister is reconditioned and becomes incoming air by  
the addition of water and CO<sub>2</sub>. The CO<sub>2</sub> added is weighed and reported for  
each cycle, but this is not possible with the water because the water is  
stored within the rig and cannot be easily measured.Air must be added to the loop once each cycle to compensate for the  
ullage lost during desorption; this air is weighed and reported.During the adsorption cycle the control valves will be as shown and air  
flow directed through the test canister. The CO<sub>2</sub> partial pressure at  
the canister inlet will be maintained constant by adding CO<sub>2</sub> under  
closed loop control. The CO<sub>2</sub> cylinder will be weighed after each cycle.

PRECEDING PAGE BLANK NOT FILMED

## TEST PLAN

## Test Requirements

## A. Test Equipment Requirements

Hamilton Standard test rig #88 will be used for this test program (see Figure 1). It will provide a stream of conditioned air to the HS-C material under test with automatically controlled pressure, flow rate, CO<sub>2</sub> partial pressure, dew point, and temperature. The conditioned air shall be maintained for the selected adsorption time while the canister is cooled by a constant temperature water coolant. At the expiration of this time desorption begins automatically with the isolation of the test canister from the conditioned air and the application of a high vacuum to the HS-C in its canister. The water coolant is maintained, and heats the canister during desorption. The entire cycle is repeated until the results repeat, when the system is said to be in "cycle equilibrium."

## B. Reliability

The reliability of the test equipment must be such that the initial and final test runs are reproduced within the run tolerance (see item E below).

## C. Loads

Not applicable.

## D. Predicted Environments

Not applicable.

## E. Allowable Tolerances

Each run shall be repeatable to the "run tolerance," defined as  $\pm 10\%$  on CO<sub>2</sub> and H<sub>2</sub>O capacity.

## F. Applicable Standards

None.



LARGE SCALE TESTS  
RIG 88 BLOCK DIAGRAM

See Figure 30, Page 39 of text

FIGURE 1

Dew point, pressure, inlet gas temperature, bed temperature and cycle times will be automatically controlled to test values by Rig 88. Desorption vacuum will depend on rig capacity.

The HS-C canister is to be set up on Rig 88 as shown in Figure 1. Rig 88 will be adjusted to give the desired experimental conditions during cyclic operation.

Required measurements are as follows:

	<u>Units</u>	<u>Accuracy</u>
Cycle Time	Minutes	±1% of Interval
Air Flow Rate	in H <sub>2</sub> O Reported in CFM	±10% of Flow
Inlet Temperature	°F	±2°F
Inlet Pressure	psia	±0.2 psia
Hygrometer (dew point)	°F	±2°F
Water Temperature	°F	±2°F
Inlet and Outlet CO <sub>2</sub>	volts Reported as mm Hg	±2% of full scale (full scale = 5 mm)
Weight CO <sub>2</sub> Added	lbs	±.02 lbs
Weight Air Added	lbs	±.02 lbs
Desorption Vacuum	Microns	±5% of non-linear scale of Hastings gauge, as calibrated for air.

4. HS-C Bed Weight, 5 lbs, Maximum

Nine runs will be made, with test conditions as follows:

Nominal:

Pressure	14.7 psi
P <sub>CO<sub>2</sub></sub>	5.0 mm Hg
T <sub>gas Inlet</sub>	70°F



Continued

Dew Point	52°F
Bed Temperature	80°F
Inlet Flow	20 cfm*
Half-cycle Time	30 minutes*
Desorption Conditions	80°F - Exact desorption pressure will depend on rig considerations since this variable is not under direct control. Target pressure is 20 microns.

\*Or as appropriate for the HS-C system design.

Specific Tests:

Run 1	Nominal conditions
Run 2	Increased cycle time
Run 3	Decreased cycle time
Run 4	Decreased dew point (46°F)
Run 5	Increased dew point (57°F)
Run 6	Increased air inlet flow (3/2 nominal; or maximum rig capability)
Run 7	Decreased air inlet flow (2/3 nominal)
Run 8	Decreased P <sub>CO2</sub> (3 mm)
Run 9	Nominal conditions

Each run will be continued until a cyclic equilibrium is reached such that the breakthrough curves for water and CO<sub>2</sub> are essentially identical for two successive cycles.

The sequence and numbering of these tests 2-8 may be varied to more efficiently utilize the test equipment and manpower.

During each cycle of record the following variables will be measured at least once or preferably continuously recorded on strip charts.

- Inlet Dew Point (recorded as water coolant temperature)
- Outlet Dew Point
- Inlet P<sub>CO2</sub>
- Outlet P<sub>CO2</sub>
- Total Pressure
- Inlet Temperature
- Bed Coolant Temperature
- Inlet Flow
- Cycle Times
- Desorption Pressure
- Air Cylinder Weight
- CO<sub>2</sub> Cylinder Weight



Continued

A cycle of record will be selected by noting that the controlled variables have been constant for two successive cycles, and successive tracings of the recorder charts for outlet  $P_{CO_2}$  and dew point show no trends and in general agree  $\pm 1/8$ -in on the 10-in strip chart. Past experience indicates three cycles are generally sufficient if conditions are held steady.

The cyclic capacity for Run 9 shall be demonstrated at the end of 168 hours of testing as at least 2% for carbon dioxide and 4% for water vapor.

Hamilton  
Standard

U  
DIVISION OF UNITED AIRCRAFT CORPORATION  
A.

CR-115568  
SVHSER-6040

MASTER TEST PLAN

DESICCANT HUMIDITY CONTROL

LARGE SCALE HS-C

OCTOBER 1971

Prepared by:

P. J. Lunde  
P. Lunde


Approved by:

W. A. Blecher  
W. Blecher

Approved by:

Fred H. Greenwood  
F. Greenwood  
Program Manager





## PLAN OF TEST

JOB: Desiccant Humidity ControlPLAN PREPARED BY: P. J. LundePROJECT & ORDER: B77-400-100AAPPROVED BY: W. A. BlecherINSTRUCTION: Large Scale HS-CTEST ENGINEER: H. KolnsbergTIME PERIOD: October 1971TO November 1971

1. WHAT IS ITEM BEING TESTED?
2. WHY IS TEST BEING RUN? WHAT WILL RESULTS SHOW OR BE USED FOR?
3. DESCRIBE TEST SET UP INCLUDING INSTRUMENTATION. ATTACH SKETCH OF INSTALLATION.
4. ITEMIZE RUNS TO BE MADE GIVING LENGTH OF EACH AND READINGS TO BE TAKEN.
5. SPECIAL INSTRUCTIONS: SAFETY PRECAUTIONS FOR OPERATORS AND HANDLING EQUIPMENT. OBSERVATIONS BY SIGHT, FEEL, OR HEARING. LIST POINTS OF OBSERVATION WHICH MIGHT CONTRIBUTE TO ANALYSIS OF (A) PERFORMANCE OF UNITS, (B) INCIPIENT TROUBLE BEFORE IT OCCURS, AND (C) CAUSE OF FAILURE.
6. HOW WILL DATA BE USED OR FINALLY PRESENTED? GIVE SAMPLE PLOT, CURVE, OR TABULATION AS IT WILL BE FINALLY PRESENTED.

## NUMBER ENTRY AS LISTED ABOVE AND DESCRIBE BELOW


1. 5-10 lbs. HS-C prepared in house.

2. To demonstrate feasibility of HS-C material for use on shuttle for desiccant and CO<sub>2</sub> control in a full scale test.

3. The conditioned air to the canister is run in a closed loop, i.e. air effluent from the canister is reconditioned and becomes incoming air by the addition of water and CO<sub>2</sub>. The CO<sub>2</sub> added is weighed and reported for each cycle, but this is not possible with the water because the water is stored within the rig and cannot be easily measured.

Air must be added to the loop once each cycle to compensate for the ullage lost during desorption; this air is weighed and reported.

During the adsorption cycle the control valves will be as shown and air flow directed through the test canister. The CO<sub>2</sub> partial pressure at the canister inlet will be maintained constant by adding CO<sub>2</sub> under closed loop control. The CO<sub>2</sub> cylinder will be weighed after each cycle.





MASTER TEST PLAN

Test Requirements

A. Test Equipment Requirements

Hamilton Standard test rig #88 will be used for this test program (see Figure 1). It will provide a stream of conditioned air to the HS-C material under test with automatically controlled pressure, flow rate, CO<sub>2</sub> partial pressure, dew point, and temperature. The conditioned air shall be maintained for the selected adsorption time while the canister is cooled by a constant temperature water coolant. At the expiration of this time desorption begins automatically with the isolation of the test canister from the conditioned air and the application of a high vacuum to the HS-C in its canister. The water coolant is maintained, and heats the canister during desorption. The entire cycle is repeated until the results repeat, when the system is said to be in "cyclic equilibrium".

B. Reliability

The reliability of the test equipment must be such that the initial and final test runs are reproduced within the run tolerance (see item E below).

C. Loads

Not applicable

D. Predicted Environments

Not applicable

E. Allowable Tolerances

Each run shall be repeatable to the "run tolerance", defined as  $\pm 10\%$  on CO<sub>2</sub> and H<sub>2</sub>O capacity.

F. Applicable Standards

None

Dew point, pressure, inlet gas temperature, bed temperature and cycle times will be automatically controlled to test valves by Rig 88. Desorption vacuum will depend on rig capacity.

The HS-C canister is to be set up on Rig 88 as shown in Figure 1. Rig 88 will be adjusted to give the desired experimental conditions during cyclic operation.

Required measurements are as follows:

	<u>Units</u>	<u>Accuracy</u>
Cycle Time	Minutes	+ 1% of Interval
Air Flow Rate	in H <sub>2</sub> O Reported in CFM	+ 10% of Flow
Inlet Temperature	°F	+ 2°F
Inlet Pressure	psia	+ 0.2 psia
Hygrometer (dew point)	°F	+ 2°F
Water Temperature	°F	+ 2°F
Inlet and Outlet CO <sub>2</sub>	volts Reported as mm Hg	+ 2% of full scale (full scale = 5 mm)
Weight CO <sub>2</sub> Added	lbs	+ .02 lbs
Weight Air Added	lbs	+ .02 lbs
Desorption Vacuum	Microns	+ 5% of non-linear Scale of Hastings gauge, as calibrated for air.

#### 4. HS-C Bed Weight, 10 lbs Maximum

Fifteen runs will be made, with test conditions as follows:

Nominal:

Pressure	14.7 psia
P <sub>CO<sub>2</sub></sub>	3.0 mm Hg
Tgas Inlet	70°F
P <sub>O<sub>2</sub></sub>	3.1 psia (atmospheric air)
Dew Point	52°F
Bed Temperature	80°F



4. Continued

Inlet Flow	50 cfm*
Half-cycle Time	30 minutes*
Desorption Conditions	80°F - Exact desorption pressure will depend on rig considerations since this variable is not under direct control. Target pressure is 50 microns.

\*Or as appropriate for the HS-C system design

Specific Tests:

Run 1	Nominal conditions
Run 2	Increased air inlet temperature (75°F)
Run 3	Decreased air inlet temperature (65°)
Run 4	Decreased dew point (46°F)
Run 5	Increased dew point (57°)
Run 6	Increased bed temperature (90°F)
Run 7	Decreased bed temperature (70°F)
Run 8	Increased PCO <sub>2</sub> (5/3 nominal)
Run 9	Decreased PCO <sub>2</sub> (1/2 nominal)
Run 10	Increased air inlet flow (3/2 nominal; or maximum rig capability)
Run 11	Decreased air inlet flow (2/3 nominal)
Run 12	Increased cycle time (3/2 nominal)
Run 13	Decreased cycle time (2/3 nominal)
Run 14	Increased desorption pressure. Exact pressure will depend on rig considerations since this variable is not under direct control. Target pressure is 100 microns.
Run 15	Nominal conditions

Each run will be continued until a cyclic equilibrium is reached such that the breakthrough curves for water and CO<sub>2</sub> are essentially identical for two successive cycles.

The sequence and numbering of these tests 2-14 may be varied to more efficiently utilize the test equipment and manpower.

During each cycle of record the following variables will be measured at least once or preferably continuously recorded on strip charts.

Inlet Dew Point (recorded as water coolant temperature)  
 Outlet Dew Point  
 Inlet PCO<sub>2</sub>  
 Outlet PCO<sub>2</sub>  
 Total Pressure  
 Inlet Temperature  
 Bed Coolant Temperature  
 Inlet Flow  
 Cycle Times  
 Desorption Pressure  
 Air Cylinder Weight  
 CO<sub>2</sub> Cylinder Weight

4. Continued

A cycle of record will be selected by noting that the controlled variables have been constant for two successive cycles, and successive tracings of the recorder charts for outlet  $PCO_2$  and dew point show no trends and in general agree  $\pm 1/8$ -in on the 10-in strip chart. Past experience indicates three cycles are generally sufficient if conditions are held steady.

At the end of Run 1 or 15 the circulating airstream will be sampled and analyzed for the toxicants listed in paragraph 3.4.4 of the SOW.



**Hamilton  
Standard**

**U**  
DIVISION OF UNITED AIRCRAFT CORPORATION  
**A®**

CR-115568  
SVHSER-6040

APPENDIX F

DATA SUMMARY SHEETS

LARGE SCALE TESTS

# Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

## LOG OF TEST

### ENGINEERING LABORATORIES

RIG NO. 88 HS-C SORBENT PARAMETRIC PLAN OF TEST NO. 9.3 lbs HS-C as bed (wet)  
 TYPE OF TEST RUN SERIES I SERIAL NO. 6 11 PART NO. 1 23 24 9  
 W.P.I. NO. DATE 11-5-1971 SHEET 1 OF 1  
 ENGINEER PL, HK, CD  
 OPERATORS

	UNITS →	hrs		lbs	lbs	lbs	MIN	MIN	μ	°F	°F	°F	in H <sub>2</sub> O	PSIA	CFM	W. Hg	ft
DATE	TIME BEGIN ADS	SINCE START	CYCLE NO.	WT CO <sub>2</sub> BEGIN ADS	Δ CO <sub>2</sub> END ADS	Δ AIR END ADS	ADS TIME	DES TIME	VACUUM END DES	INLET AIR	INLET CAN COOL	INLET Dew PT	CAN ΔP	ADS PRESS	ADS FLOW	INLET P <sub>CO<sub>2</sub></sub>	FT LEFT ON ROLL
"1/5	1335	0	1	155.87	.07	—	22	45	35	74	82	52	2.0	14.6	30	3.4	34
	1445	1.1	2	155.80	.12	—	22	45	30	74	82	52	2.0	14.6	29	3.6	33
	1555	2.2	3	155.68	.11	—	22	45	30	74	103	56	3.2	14.45	40	3.8	32
	1707	3.3	4	155.57	.19	—	22	45	20	75	76	56	3.0	14.5	40	3.5	31
	1820	4.4	5	155.38	.14	—	22	45	30	75	78	54	3.0	14.55	41	3.9	30
	1928	5.5	6	155.24	.14	—	22	45	30	69	78	52	3.0	14.5	40.5	3.8	29
	2126	6.6	7	154.61	.09	—	22	62	35	69	79	49	2.9	14.7	40.5	3.5	27
	2250	8.7	8	154.52	.12	—	22	61	150	69	79	52	2.9	14.65	40.5	3.7	26
"1/6	0015	10.1	9	154.40	.13	—	23	62	150	69	79	52	2.9	14.7	40.5	3.9	25
	0142	11.5	10	154.27	.13	—	22	62	39	69	79	52	3.0	14.7	40.5	3.8	23
	0306	12.9	11	154.14	.14	—	22	62	35	69	78	52	2.9	14.7	40.5	3.8	22
	0431	14.3	12	154.00	.14	—	22	63	36	69	78	57	3.0	14.7	40.5	3.8	21
	0557	15.7	13	153.86	.15	—	23	64	37	69	78	52	2.9	14.7	40.5	3.8	20
	0722	17.1	14	153.71	.13	—	22	62	48	69	78	57	2.9	14.7	40.5	3.8	19
	0840	18.5	15	153.58	.14	—	42	60	45	70	78	52	2.9	14.7	40.5	4.1	18
SHUT DOWN																	

REMARKS:

PAGE NO.

REPORT NO.

PRECEDING PAGE BLANK NOT FILMED



HSF 1753 4/67

# Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.



DIVISION OF UNITED AIRCRAFT CORPORATION

## LOG OF TEST ENGINEERING LABORATORIES

SHEET 2 OF 2

RIG NO. 88

TYPE OF TEST HS-C SORBENT PARAMETER

PLAN OF TEST NO.

DATE

ENGINEER

OPERATORS

W.P.I. NO.

RUN SERIES I

SERIAL NO.

PART NO.

AD.	UNITS	HRS	CYCLE	WT CO <sub>2</sub>	Δ CO <sub>2</sub>	Δ AIR	min	min	μ	°F	°F	°F	in H <sub>2</sub> O	psia	CFM	mmHg	ft
DATE	TIME	SINCE	N.O.	BEGIN	END	END	ADS	DES	VACUUM	INLET	INLET	INLET	CAN	ADS	ADS	INLET	FT LEFT
	BEGIN	START		ADS	ADS	ADS	TIME	TIME	END DES	AIR	CAU	DEWPT	AP	PRESS	FLOW	PROZ	ON ROLL
11-8	1240	19.2	16	153.40	.15	—	30	47	12	71	79	54*	3.2	14.05	40.5	3.2	14
	1350	20.3	17	153.25	.15	—	30	45	15	71	79	56*	4.8	14.8	60	3.3	13
	1510	21.7	18	153.10	.16	—	32	45	15	71	79	56*	3.2	~11.75	42	5.1	12
11-9	0845	22.5	19	152.94	.245	—	35	1020	60	70	79	54*	3.4	14.7	42.5	5.0	8
	1008	23.8	20	152.69	.17	—	34	47	18	70	79	55*	3.4	14.8	42	5.0	7
	1127	25.2	21	154.15	.16	—	33	45	18	70	80	57*	4.	14.9	43	5.1	5
	1235	26.4	22	153.95	.15	.15	33	35	25	70	80	55*	~4	~14.9	~43	~5	4
	1405	27.8	23	153.80	.15	.15	30	60	140*	70	80	54*	3.2	14.7	41.2	4.85	3
	1510	29.0	24	153.65	.15	.28	31	35	20	70	81	45*	3.4	14.7	42	4.9	2
	1627	30.3	25	153.50	.15	—	30	45	30	70	80	44	3.0	14.7	41.3	4.8	1
11-10	0912	40.0	26	153.35	.225	.16	32	960	4	70	82	52	3.2	14.7	41.5	5.0	98
	1030	41.3	27	153.13	.15	.16	32	45	15	70	82	52	3.1	14.65	41.2	3.1	97
	1135	42.4	28	152.99	.13	.20	31	32	25	70	82	52	3.2	14.8	41.5	3.0	96
	1252	43.6	29	152.86	.14	—	32	45	15	71	82	52	3.3	14.75	41.5	3.05	96
1	1415	44.9	30	152.72	.15	.31	33	45	15	71	82	52	3.2	14.75	41.5	3.0	95

### REMARKS

\* D.P. probably out of cal. Water temp indicates 52°F D.P., or may be recorder problem \*\*

\*\* Recorder "insane" on mv range

+ single (other) end desorb

# water 43°F

REPORT NO.

CR-115568  
SMHSR-6040

**Hamilton Standard**  
WINDSOR LOCKS, CONNECTICUT • U.S.A.

**U  
A.**

**LOG OF TEST**  
ENGINEERING LABORATORIES

SHEET **3** OF **11**BIG NO. **88**

TYPE OF TEST

**AS-C SORBENT PARAMETER**

PLAN OF TEST NO.

DATE

ENGINEER

OPERATORS

W.P.I. NO.

**RW SERIES I**

SERIAL NO.

PART NO.

AD	UNITS	HRS	CYCLE	WT CO <sub>2</sub>	Δ CO <sub>2</sub>	Δ AIR	min	min	μ	OF	OF	OF	in H <sub>2</sub> O	PSIA	CFM	mmHg	St
TIME	TIME	SINCE	NO.	BEGN	END	END	ADS	DES	VACUUM	INLET	INLET	INLET	CAN	ADS	ADS	P <sub>CO2</sub>	FT LGFT
DOWN	DOWN	START			ADS.	ADS	TIME	TIME	END	AIR	CAN	DEW	AP	PRESS	FLOW		ON ROLL
									DES.		COOLANT	PT					
<b>10</b>	1534	46.2	31	152.47	.15	.18	31	45	15	71	82	53	3.0	14.7	41	3.0	92
	1655	47.4	32	152.32	.14	.19	30	45	15	71	82	51	3.0	14.7	41.2	3.05	91
	1815	48.6	33	152.18	.14	—	30	45	20	71	82	51	2.9	14.7	41.2	3.05	90
	2000	50.	34	152.04	.15	fortwo .36	33	45	15	70	80	50	2.7	14.7	40.7	3.0	89
	2120	51.3	35	151.89	.15	.19	30	45	15	71	77	50	2.7	14.7	40.7	3.0	88
	2237	51.5	36	151.74	.14	.18	30	47	15	70	79	44	2.7	14.7	40.7	3.0	86
	2353	52.7	37	151.60	.14	.18	30	45	15	70	80	44	2.7	14.7	40.7	3.0	85
<b>11</b>	0110	54.0	38	151.46	.13	.18	30	45	15	70	80	44	2.7	14.7	40.7	3.0	84
	0228	55.2	39	151.33	.15	.18	30	45	15	70	81	57	2.7	14.7	40.7	3.0	83
	0346	56.5	40	151.18	.14	.18	30	45	15	70	80	57	2.8	14.7	40.7	3.0	82
	0502	57.7	41	151.04	.14	.17	30	45	15	70	80	57	2.8	14.7	40.7	3.0	81
	0621	59.0	42	150.89	.14	.18	30	45	15	70	80	51	2.8	14.7	40.7	3.0	80
	0738	60.2	43	150.75	.14	.18	30	45	15	70	80	52	2.8	14.7	40.7	3.0	79
	0855	61.4	44	150.61	.14	.17	30	45	15	70	81	51	2.8	14.7	40.7	3.0	78
	1013	62.6	45	150.47	.14	.17	30	45	15	75	80	51	2.8	14.7	40.7	3.0	77

REMARKS:

PAGE NO.

REPORT NO.

CR-115568  
SVHSER-6040



E-6

HSP 1773 4/67

**Hamilton Standard**  
WINDSOR LOCKS, CONNECTICUT • U.S.A.

DIVISION OF UNITED AIRCRAFT CORPORATION

U  
A.

**LOG OF TEST**  
**ENGINEERING LABORATORIES**

SHEET 4 OF

RIG NO. 88  
TYPE OF TEST  
W.P.I. NO.

HS-C SORBENT PARAMETER  
RUN SERIES I

PLAN OF TEST NO.  
SERIAL NO.

6

11

PART NO. 13

1

23

24

9

DATE  
ENGINEER  
OPERATORS

A.D.	UNITS →	HRS		16s	16s	16s	min	min	μ	OF	OF	OF	inlet	psia	CFM	mmHg	ft
TIME	SINCE	CYCLE	WT CO <sub>2</sub>	Δ CO <sub>2</sub>	Δ AIR	ADS	ADS	DES.	VACUUM	INLET	INLET	INLET	CAN	ADS	ADS	PO <sub>2</sub>	FT LEFT
BEGIN	START	NO	BEGIN	END	END	ADS	ADS	DES.	DES,	AIR	CAN	DEW	DP	PRESS	FLOW	PO <sub>2</sub>	ON ROLL
11-11	1134	63.9	46	150.33	.14	.16	30	45	13	75	82	52	2.7	14.7	40.5	3.0	75
	1247	65.2	47	150.19	.14	.16	}	}	13	76	82	52	2.7	14.7	40.5	3.0	74
	1406	66.5	48	150.05	.10	.15			13	76	83	52	2.7	14.7	40.5	3.0	73
	1524	67.8	49	149.95	.14	.15			13	61	83	52	2.7	14.7	40.5	3.0	72
	1641	69.1	50	149.81	.14	.14			13	60	83	52	2.7	14.7	40.5	3.0	71
	1759	70.4	51	149.67	.14	.16			15	65	83	52	2.7	14.7	40.5	3.0	70
	1916	71.7	52	149.53	.14	.18			15	65	83	52	2.7	14.7	40.5	3.0	69
	2032	73.0	53	149.39	.14	.21			15	68	84	52	2.7	14.7	40.5	3.0	68
	2151	74.3	54	149.25	.15	.27			15	70	80	52	2.7	14.7	40.5	3.0	67
	2310	75.6	55	149.10	.14	.18			15	70	81	51	2.7	14.7	40.5	3.0	66
11-12	0028	76.9	56	148.96	.145	.18	}	}	12	70	82	50	2.7	14.7	40.5	3.0	65
	0144	78.2	57	148.825	.145	.14			15	70	80	50	2.7	14.7	40.5	3.0	64
	0303	79.5	58	148.68	.14	.16			16	70	82	50	2.7	14.7	40.5	3.0	63
10 CAN	0420	80.8	59	148.54	.17	.17			12	70	67	50	2.7	14.7	40.5	3.0	62
10 CAN	0538	81.1	60	148.37	.13	.20			22	70	67	50	2.7	14.7	40.5	3.0	60

REMARKS:

PAGE NO.

REPORT NO.

CR-115568  
SVISER-6040

HSF 1753 4/67

Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

DIVISION OF UNITED AIRCRAFT CORPORATION  
U  
ALOG OF TEST  
ENGINEERING LABORATORIES

SHEET 5 OF 1

RIG NO. 88

TYPE OF TEST

W.P.I. NO.

HS-C SORBENT PARAMETER

PLAN OF TEST NO.

SERIAL NO.

6

11

PART NO.

1

23

DATE

ENGINEER

OPERATORS

24

9

UNITS →		HRS		lbs	lbs	lbs	min	min	in	°F	°F	°F	in H <sub>2</sub> O	PSIA	CFM	mm Hg	ft		
DATE	TIME	SINCE	CYCLE	WT CO <sub>2</sub>	A CO <sub>2</sub>	Δ AIR	ADS	DES	VACUUM	INLET	INLET	INLET	CAN	ADS	ADS	ADS	P <sub>CO<sub>2</sub></sub>	# Bt on roll	
	BEG/END	START	NO.	BEG/END	BEG/END	BEG/END	TIME	TIME	END/DES	AIR	CAN	CO <sub>2</sub>	DEW PT	AP	PRESS	FLOW			LO CAN
11/12	0812	93.7	62	148.105	.135	.18	30	45	20	70	68	49	2.7	14.7	40.5	3.0	58		
	0928	94.9	63	147.97	.13	.18	30	45	17	70	68	50	2.7	14.7	40.5	3.0	57	"	
	1217	96.85	64	147.84	.14	.19	30	82.5	9	70	80	49	2.7	14.7	40.5	3.0	55	3/4 500	
	1408	98.7	65	147.70	.16	.19	30	82.5	9	70	81	50	2.7	14.7	40.5	3.0	53	"	
	1606	100.6	66	147.54	.16	.19	30	82.5	20	70	81	50	2.7	14.7	40.5	3.0	51	"	
	1708	101.6	67	147.38	.12	.15	20	30	28	71	81	50	2.7	14.7	40.5	3.0	57	3/4 500	
	1800	102.5	68	147.26	.12	.15	20	30	15	71	81	50	2.7	14.7	40.5	3.0	50	"	
	1857	103.5	69	147.14	.12	.15	20	30	20	71	82	50	2.7	14.7	40.5	3.0	49	"	
	1956	104.5	70	147.02	.14	.15	30	45	22	70	82	50	2.7	14.7	40.5	3.0	48	ADAM	
	2116	105.8	71	146.88	.14	.15	30	45	23	71	82	49	2.7	14.7	40.5	4.95	47		
	2231	107.0	72	146.74	.16	.18	30	45	18	71	82	48	2.7	14.7	40.5	5.0	46		
11/13	2346	108.3	73	146.58	.15	.17	30	45	17	71	82	47	2.7	14.7	40.5	4.8	45	P <sub>CO<sub>2</sub></sub> = 5	
	0105	109.6	74	146.43	.15	.19	30	45	20	70	82	46	2.7	14.7	40.5	4.8	44	"	
	0222	110.8	75	146.28	.15	.18	30	45	20	71	82	45	2.7	14.7	40.5	4.8	43	"	
	0339	113.0	76	146.13	.10	.19	30	45	20	70	82	44	2.7	14.7	40.5	1.6	42		
	0455	114.2	77	146.03	.10	.19	30	45	17	70	82	43	2.7	14.7	40.5	1.6	41	P <sub>CO<sub>2</sub></sub> = 15	

REMARKS

PAGE NO.

REPORT NO.

CR-115568  
SVHSR-6040



HSF 1728 4/67

**Hamilton Standard** DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

**LOG OF TEST**  
ENGINEERING LABORATORIES

SHEET 6 OF 6  
DATE 11-13-71  
ENGINEER HK, PL, CD  
OPERATORS M, OT, OLA

ING NO. 88  
TYPE OF TEST HS-C SORBENT PARAMETRIC  
W.P.I. NO. RUN SERIES I SERIAL NO. AN OF TEST NO. PART NO.

DATE	UNITS →	HRS	—	LBS	LBS	LBS	MIN	MIN	W	OF	OF	OF	in H <sub>2</sub> O	PSIA	CFM	REMARKS
TIME	TOTAL	CYCLE	WT	ΔCO <sub>2</sub>	ΔAIR	ADS	DES	VACUUM	INLET	INLET	INLET	CAV	ADSORB	ADSORB	INLET	FEET
BEGIN	SINCE	NO.	CO <sub>2</sub>			TIME	TIME	END DES	AIR T	CAN COOL	DEW PT	PESS	PRESS	FLOW	PCO <sub>2</sub>	ON
ADSORB	START	○	BEGIN	END	END			ADS				DROP				ROLL
			BEGIN	END	END											
			ADS.	ADS.	ADS.											
11-13		76							14+	6	11	13+	1+	23+	24+	9+
		77														
	0611	115.5	78	145.93	.10	.19	30	45	18	70	82	43	2.7	14.7	40.5	1.35 40
	0729	116.7	79	145.82	.13	.19	30	45	16	70	82	43	2.7	14.7	40.5	2.8 38
ADM	0842	118.0	80	145.69	.145	.17	30	45	11	70	82	51	5.6	14.8	60	2.9 38
HI	1005	119.2	81	145.545	.150	.16	30	45	15	70	80	50	5.4	14.75	60	3.3 37
ROW	1123	120.5	82	145.395	.145	.17	30	45	19	70	80	51	5.5	14.7	60	3.3 36
✓	1237	121.8	83	145.25	.14	.18	30	45	18	71	80	51	5.6	14.7	60	3.3 35
LO	1356	123.1	84	145.11	.135	.23	30	45	19	69.72*	78.82*	45*	1.3	14.7	26	3.3 34
FLO	1513	124.4	85	144.975	.135	.21	30	45	19	71	80	51	1.4	14.65	26	3.2 33
↓	1627	125.6	86	144.84	.135	.19	30	45	17	71	80	52	1.4	14.68	26.2	3.2 31
✓	1744	126.9	87	144.715	.135	.19	30	45	20	71	80	51	1.4	14.65	26	3.1 30
HI	1902	128.2	88	144.58	.160	.10	30	45	18	71	80	51	2.7	14.7	40.5	4.9 29
P <sub>CO2</sub>	2018	129.5	89	144.42	.160	.160	30	45	18	71	80	51	2.7	14.7	40.5	4.9 28
↓	2135	130.8	90	144.26	.150	.170	30	45	20	72	82	51	2.7	14.7	40.5	4.9 27

REMARKS: \* Ran out of water, recorder insane

PAGE NO.

REPORT NO.

# Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

## LOG OF TEST

### ENGINEERING LABORATORIES

SHEET 7 OF

DATE 11-13-71

ENGINEER PL. H.K. CD

OPERATORS

RIG NO.

88

TYPE OF TEST  
W.P.I. NO.

HS-C SORBENT PARAMETRIC

PLAN OF TEST NO.

SERIAL NO.

PART NO.

RUN SERIES I

DATE	UNITS →	HRS	—	LBS	LBS	LBS	MIN	MIN	μ	°F	°F	°F	IN. H <sub>2</sub> O	PSIA	CFM	MM Hg	FT
1971	TIME	TOTAL SINCE	CYCLE NO	WT CO <sub>2</sub>	Δ CO <sub>2</sub>	Δ A <sub>IR</sub>	ADS TIME	DES TIME	VACUUM END DES	INLET AIR	INLET CAV COOL	INLET DP	CAV DP	ADSORB PRESS	ADSORB FLOW	INLET P CO <sub>2</sub>	LEFT ON
	BEGIN ADSORB	START		BEGIN ADS.	END ADS.	END ADS.			14	6	11	13	1	23	24	9	ROLL
11/13	2251	132.05	91	144.11	.15	.17	30	45	18	72	82	51	2.7	14.7	40.5	4.9	26
11/14	0009	133.35	92	143.96	.11	.17	30	45	17	71	80	51	2.7	14.7	40.5	1.8	25
LD	0125	134.6	93	143.85	.11	.18	30	45	17	71	80	51	2.7	14.7	40.5	1.4	24
Rear	0241	135.9	94	143.74	.11	.18	30	45	15	71	80	51	2.7	14.7	40.5	1.5	23
↓	0357	137.2	95	143.63	.11	.18	30	45	15	71	80	51	2.7	14.7	40.5	1.5	22
↓	0514	138.4	96	143.52	.11	.18	30	45	15	71	80	51	2.7	14.7	40.5	1.5	21
ADM	0630	139.7	97	143.40	.14	.18	30	45	15	70	80	51	2.7	14.7	40.5	1.3/3.0	20
↓	0746	141.0	98	143.26	.14	.18	30	45	15	71	80	52	2.8	14.7	40.5	3.0	18
HI	0903	142.3	99	143.12	.09	.18	30	45	1000*	71	80	52	2.75	14.7	40.5	3.0	17
VAC	1019	143.5	100	143.03	.09	.18	30	45	1000*	71	80	52	2.75	14.7	40.5	3.0	16
I	1136	144.8	101	142.94	.12	.18	30	45	160*	71	80	52	2.75	14.7	40.5	3.0	15
HI	1252	146.0	102	142.82	.12	.18	30	45	165*	71	80	52	2.75	14.7	40.5	3.0	14
VAC	1408	147.2	103	142.70	.12	.18	30	45	160*	71	80	51	2.75	14.7	40.5	3.0	13
↓	1526	148.5	104	142.58	.14	.18	30	45	20	71	80	51	2.70	14.7	40.5	3.0	12
ADM	1642	149.7	105	142.44	.14	.18	30	45	25	71	80	51	2.70	14.7	40.5	3.0	11

REMARKS

\*Single end desorb. 100g<sub>u</sub> measured low pressure side. 160g<sub>u</sub> high pressure side

↑ turn village tube alone

↑ turn bottom valve alone

CR-115568  
SVHSR-6040



**HAMILTON STANDARD**  
WINDSOR LOCKS, CONNECTICUT - U.S.A.

**U  
A.**  
DIVISION OF UNITED AIRCRAFT CORPORATION

**LOG OF TEST**  
**ENGINEERING LABORATORIES**

SHEET 8 OF 11  
DATE 11-14-71  
ENGINEER PL, HK, CD  
OPERATORS 24 9

BIG NO. 88

TYPE OF TEST

HS-C SORBENT PARAMETRIC

PLAN OF TEST NO.

8.84 lbs HS-C

W.P.I. NO.

RUN SERIES I

SERIAL NO.

6

11

PART NO.

1

23

24

9

UNITS →	HRS			lbs	lbs	min	min	μ	°F	°F	°F	in H <sub>2</sub> O	PSIA	CFM	mm Hg	ft	
TIME BEGIN ADS	SINCE START	CYCLE NO.	WT CO <sub>2</sub> BEGIN ADS	Δ CO <sub>2</sub> END ADS	Δ AIR END ADS	ADS TIME	DES TIME	VACUUM END DES	INLET AIR	INLET CAN/COOL	INLET JEN PT	CAN Δ P	ADS PRESS.	ADS FLOW	INLET P <sub>CO<sub>2</sub></sub>	FT LEFT IN ROLL	
1800	150.9	106	142.30	.14	.19	30	45	25	70	80	51	2.7	14.7	40.5	3.0	10	
1915	152.1	107	142.16	.14	.19	30	45	20	70	80	50*	2.7	14.7	40.5	3.0	9	
2031	153.7	108	142.02	.14	.19	30	45	21	70	80	50*	2.8	14.7	40.3	3.0	8	
0006	157.3	109	<del>141.89</del> 141.87	.195	.18	30	181.3	7	70	79	51	2.6	14.7	40.2	5.0	5	
0231	159.7	110	<del>141.85</del> 141.85	.185	.18	30	113	10	70	79	52	2.7	14.7	40.6	5.0	3	
0503	162.1	111	141.49	.185	.14**	30	120	9	70	79	51	2.7	14.7	40.6	5.05	1	
0734	164.3	112	141.38	.20	.16	30	120	6	72	80	51	2.7	14.7	40.5	5.0	29	
1006	166.8	113	141.05	.18	.18	30	120	10	68	—	—	51	2.7	14.7	40.5	5.0	27
1321	170.05	114	140.92	.185	.19	30	165	7	—	—	—	51	2.7	14.7	40.5	5.0	24
1553	172.3	115	140.74	.20	.18	30	120	8	—	—	—	52	2.7	14.7	40.6	5.0	22
1754	174.6	116	140.54	.18	.18	30	90	8	—	—	—	52	2.7	14.7	40.6	5.0	20
1957	176.6	117	140.36	.18	.16	30	90	8	—	—	—	52	2.7	14.7	40.5	5.0	19
2112	177.8	118	140.18	.16	.17	30	45	25	—	—	—	52	2.7	14.7	40.5	5.0	17.5
2228	179.0	119	140.02	.11	.18	30	45	25	+	+	+	42	2.7	14.65	40.5	3.0	16
2344	180.2	120	139.91	.13	.18	30	45	23	+	+	+	42	2.7	14.7	40.5	3.0	15.5

REMARKS

\* Ref charge low

† TC readings off on recorder - thermometer indicates 68°F at can inlet

\*\* Wts changed

⊕ vacuum ~5 @ 0930

CR-115568  
SVHSR-6040

HSF 1738 4/67

# Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

 DIVISION OF UNITED AIRCRAFT CORPORATION  
 U  
A

## LOG OF TEST

### ENGINEERING LABORATORIES

 SHEET 9 of 11  
 DATE 11-18-71  
 ENGINEER PL, HK, CD  
 OPERATORS 24 9

RIG NO. 88

TYPE OF TEST

HS-C SORBENT PARAMETRIC

PLAN OF TEST NO.

8.84 lbs HS-C

W.P.I. NO.

RUN SERIES I

SERIAL NO. 14

6

11

PART NO.

1

23

24

9

UNITS →	HRS		lbs	lbs	lbs	min	min	μ	°F	°F	°F	in H <sub>2</sub> O	psia	CFM	mm Hg	ft
TIME BEGIN ADS	SINCE START	CYCLE NO.	WT CO <sub>2</sub> BEGIN ADS	ΔCO <sub>2</sub> END ADS	ΔAIR END ADS	ADS TIME	DES TIME	VACUUM END DES	INLET AIR	INLET CAN COOL	INLET DEW PT	CAN ΔP	ADS PRESS	ADS FLOW	INLET P <sub>can</sub>	FT LEFT ON COLL
0102	181.4	121	139.78	.13	.18	30	45	23	+	+	42	2.7	14.7	40.5	3.0	14
0219	182.6	122	139.65	.13	.18	30	45	25	+	+	42	1.4	14.7	26.0	3.0	13
0335	183.8	123	139.52	.12	.13	30	45	25	+	+	42	1.4	14.7	26.0	3.0	12
0451	185.0	124	139.40	.12	.17	30	45	25	+	+	42	1.4	14.7	26.0	3.0	11
0608	186.2	125	139.28	.13	.18	30	45	25	+	+	47-40	4.5	14.7	55.0	3.0	10
0726	186.5	126	139.15	.13	.21	30	45	13	+	+	47-40	4.5	14.7	55.0	3.0	9
0859*	187.8	127	139.02	.14	.27	30	45	12	+	+	38	4.6	14.7	55.0	3.0	8
1015	189.1	128	138.88	.13	.18	30	45	10	+	+	43	4.4	14.7	55.0	3.0	7
1133	190.4	129	138.75	.14	.17	30	45	20	+	+	42	4.7	14.7	55.0	3.0	6
1249	191.7	130	138.61	.135	.18	30	45	25	+	+	43	4.6	14.7	55.0	3.0	5
1407	193.0	131	138.47	.135	.11	30	45	22	+	+	42.5	4.8	14.7	55.0	3.0	3
1507	194.0	132	138.350	.125	.18	30	30	22	+	+	40.0	2.7	14.7	40.5	5.0	3
1609	195.0	133	138.21	.135	.19	30	30	21	68	77	42	2.7	14.7	40.6	5.0	2
1715	196.1	134	138.075	.13	.12	30	30	22	70	76	42	2.7	14.7	40.6	5.0	97
1816	197.1	135	137.95	.135	.18	30	30	22	70	77	42	2.7	14.7	40.6	5.0	96

## REMARKS

+ TC readings off on recorder - thermometer indicates 68°F at can inlet, can 77°F on pressure gauge.

\* 18 MIN HOLD WHILE LIRA CAL

@ 100% on recorder flow is 55 CFM AP = 38 in H<sub>2</sub>O

F-11

PAGE NO

RECORD NO

CR-115568  
SVHSR-6040



HSF 1738 4/67

**Hamilton Standard** DIVISION OF UNITED AIRCRAFT CORPORATION  
WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

**LOG OF TEST**  
**ENGINEERING LABORATORIES**

FIG NO. 88  
TYPE OF TEST  
W.P.I. NO.

HS-C SORBENT PARAMETRIC PLAN OF TEST NO.  
RUN SERIES I SERIAL NO. 14 6 11 PART NO 1 23 24 9

8.84165 HS-C

SHEET 10 OF  
DATE 11-16-71  
ENGINEER PL, HK, CD  
OPERATORS

UNITS →	WRS		lbs	lbs	lbs	min	min	in	°F	°F	°F	in H <sub>2</sub> O	PSIA	CFM	min Hg	ft
TIME	SRVCE	CYCLE	WT CO <sub>2</sub>	A CO <sub>2</sub>	A AIR	ADS	DES	VACUUM	INLET	INLET	INLET	CAN	ADS	ADS	INLET	FT LEFT
BEGIN	START	NO.	BEGIN	END	END	TIME	TIME	END DES	AIR	CAN CO <sub>2</sub>	DEW PT	AP	PRESS	FLOW	P <sub>cor</sub>	ON ROLL
11/16 1918	198.1	136	137.815	.135	.18	30	30	22	70	78	52	2.7	14.7	40.5	5.0	95
2020	199.1	137	137.68	.135	.18	30	30	25	70	78	52	2.7	14.7	40.5	5.0	94
2022	200.1	138	137.595	.145	.18	30	30	26	70	78	52	2.7	14.7	40.5	5.0	93
2224	201.1	139	137.40	.145	.18	30	30	26	70	78	62	2.7	14.7	40.5	5.0	92
2325	202.1	140	137.255	.145	.18	30	30	32	70	78	62	2.7	14.7	40.5	5.0	91.5
11/17 0026	203.1	141	137.11	.15	.17	30	30	33	70	77	58	4.6	14.7	56	5.0	91
0128	204.1	142	136.96	.15	.17	30	30	25	70	77	51	4.6	14.7	56	5.0	90
0229	205.2	143	136.81	.14	.23	30	30	28	70	77	42	4.6	14.7	56	5.0	89
0502	207.7	144	136.67	.18	.19	30	120	10	71	78	51	2.7	14.7	40.2	5.0	87
0734	210.2	145	136.49	.18	.19	30	120	9	72	78	51	2.7	14.7	40.2	5.0	85
1004	212.7	146	136.31	.19	.18	30	120	10	70	77	51	2.7	14.7	40.2	4.9	83
1236	215.3	147	136.12	.19	.17	30	120	7	70	77	51	2.6	14.7	40.2	5.0	81
1345	216.4	148	135.93	.115*	.17	30	45	20	70	80	51	2.6	14.7	40.5	3.0	80
1502	217.7	149	135.815	.135	.19	30	45	20	70	81	51	2.8	14.7	41.2	3.0	79
1618	219	150	135.68	.145	.19	30	45	30	70	81	51	2.8	14.7	41.3	3.0	78

REMARKS: \*changed weights

PAGE NO.

REPORT NO.

CR-115568  
SVHSR-6040

HSF 1758 4/67

**Hamilton Standard**  
 WINDSOR LOCKS, CONNECTICUT • U.S.A.

 DIVISION OF UNITED AIRCRAFT CORPORATION  
 U  
A

**LOG OF TEST**  
 ENGINEERING LABORATORIES

SHEET 11 OF 11

DATE 12-2-71

ENGINEER W. BLECHER

OPERATORS W. KOUNSBERRY

RIG NO. 88

TYPE OF TEST

HSC SORBENT - HALF BED

PLAN OF TEST NO.

4.40<sup>H</sup> HS-C

W.P.I. NO.

RUN SERIES II

SERIAL NO.

PART NO.

UNITS →	HRS		LBS	LBS	LBS	MIN	MIN	μ	°F	°F	°F	IN. H <sub>2</sub> O	PSIA	CFM	MM Hg	FT
TIME BEG ADS	SWICE START	CYCLE NO.	WT CO <sub>2</sub> BEG ADS	Δ CO <sub>2</sub> END ADS	Δ AIR END ADS	ADS TIME	DES TIME	VACUUM END DES	INLET AIR	INLET CAN COOL	INLET DEW PT	CAN ΔP	ADS PRESS	ADS FLOW	INLET PCO <sub>2</sub>	LEFT OVER
12/2 1045	2.4	1	134.45	.085	.19	38	38	14	70	80	51		14.5	20	4.8	54
1203	3.7	2	134.365	.085	.18	39	41	13	72	80	53		14.53	20	4.8	53
1320	5.0	3	134.28	.085	.18	39.5	39	13	72	81	53		14.55	20	4.9	52
1450	6.5	4	134.195	.085	.18	49.5	49.6	9.5	72	80	52		14.53	20	5.0	50
1630	8.1	5	134.11	.085	.18	45.5	50.5	9.5	72	80	53	0.4	14.45	20	5.0	48
1746	9.4	6	134.025	.085	.18	30.74	31.0	17	72	80	53	0.4	14.45	20	5.0	47
1847	10.4	7	133.94	.08	.19	30.36	29.7	18	72	81	53	0.4	14.45	20	5.0	47
1950	11.5	8	133.86	.07	.18	30.4	29.22	14	72	81	52	0.4	14.44	20	4.9	46
2101	12.7	9	133.79	.075	.18	40.0	39.94	12	72	81	51	0.4	14.44	20	4.9	45
2224	14.0	10	133.715	.075	.13	40.0	39.95	14	72	80	56	1.75	14.46	40	4.9	44
12/3 0927	15.4	11	133.64	—*	.15	30.1	45.02	14	72	83	59	1.75	14.5	40	4.9	42
1044	16.7	12	133.44	.085	.20	30.1	44.92	12	70	82	50	1.75	14.45	40	4.9	40
1200	18.0	13	133.355	.090	.18	30.0	45.07	9	70	82	51	0.4	14.43	20	4.9	39
1317	19.3	14	133.265	.085	.18	30.0	45.07	9	70	82	51	0.4	14.43	20	4.9	38
1428	20.4	15	133.18	.08	.18	39.5	39.37	10	70	82	51	0.4	14.43	20	4.9	37
1550	21.8	16	133.11†	.08	.18	41.08	39.85	12	70	82	50	0.4	14.43	20	4.9	36

REMARKS:

\* CO<sub>2</sub> BOTTLE DISTURBED DURING ADSORB - SCALE READING CHANGED† SCALE WEIGHTS CHANGED - Δ CO<sub>2</sub> VALID

PAGE NO.

REPORT NO.

 CR-115568  
 SVHSR-6040



Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

DIVISION OF UNITED AIRCRAFT CORP.

CR-115568  
SVHSER-6040LOG OF TEST  
ENGINEERING LABORATORIESDATE 3-13-72 1 OF 2  
ENGINEER PLJ  
OPERATORS URIRIG NO. 81

TYPE OF TEST

W.P.I. NO.

WATER & CO<sub>2</sub> CAPACITY

## CALCULATIONS

PLAN OF TEST NO.

SERIAL NO.

PART NO.

E-14	UNITS →			LBS	LBS								
	TIME	SERIES	CYCLE NO.	BED WT	CO <sub>2</sub> REMOVED	CO <sub>2</sub> CAPTY.	% H <sub>2</sub> O REM. EFF.	LBS H <sub>2</sub> O REMOVED	% H <sub>2</sub> O CAPTY.	CFM AIR FLOW	CFM/LB SPECIFIC FLOW RATE	BED	
		I	19	8.83	0.245	2.77							
		I	21	8.83	0.16	1.82							
		I	26	8.83	0.225	2.55	40.9	.338	3.83				
		I	41	8.83	0.14	1.58	42.6	.392	4.44	40.7			
		I	43	8.83	0.14	1.58	SAME AS 47 or 52						
		I	47	8.83	0.14	1.58	42.8	.324	3.67	40.5			
		I	52	8.83	0.14	1.58	42.6	.324	3.67	40.7			
		I	57	8.83	0.145	1.64							
		I	63	8.83	0.13	1.46	55.0	.381	4.3	40.5			
		I	66	8.83	0.16	1.81							
		I	68	8.83	0.12	1.36							
		I	70	8.83	0.14	1.58	42.2	.354	4.00	40.3	4.55		
		I	82	8.83	0.145	1.64	38.3	.418	4.72	60	6.78		
		I	87	8.83	0.135	1.52	55.5	.26	2.94	26	2.94		
		I	91	8.83	0.15	1.70	43.5	.318	3.6	40.5			
		I	96	8.83	0.11	1.24	43.4	.317	3.59	40.5			

REMARKS:

CR-115568  
SVHSER-6040

Hamilton Standard

MIDDLETOWN, CONNECTICUT • U.S.A.

DIVISION OF UNITED AIRCRAFT CORP.

U  
ACR-115568  
SVHSER-6040LOG OF TEST  
ENGINEERING LABORATORIESDATE 3-15-72 LET 2 OF 2  
ENGINEER PJ DRM  
OPERATORS \_\_\_\_\_

RIG NO. \_\_\_\_\_

TYPE OF TEST \_\_\_\_\_

W.P.I. NO. \_\_\_\_\_

WATER & CO<sub>2</sub> CAPACITY  
CALCULATIONS

PLAN OF TEST NO. \_\_\_\_\_

SERIAL NO. \_\_\_\_\_

PART NO. \_\_\_\_\_

UNITS →			LBS	LBS	%		%	LBS	%		CFM	CFM/LB BED		
TIME	SERIES	CYCLE NO.	BED WT.	CO <sub>2</sub> REMOVED	CO <sub>2</sub> CAPY.		H <sub>2</sub> O REM EFF.	H <sub>2</sub> O REMOVED	H <sub>2</sub> O CAPY		AIR FLOW	SPECIFIC FLOW RATE		
	I	100	8.83	0.09	1.02									
	I	101	8.83	0.12	1.36									
	I	109	8.83	0.195	2.21		42.5	.1310	3.51		40.6			
	I	113	8.83	0.18	2.03									
	I	115	8.83	0.20	2.26									
	I	121	8.83	0.13	1.47		43.4	.1225	2.55		40.5	4.58		
	I	124	8.83	0.12	1.36		52.5	.1172	1.95		26	2.94		
	I	131	8.83	0.135	1.53		35.2	.1248	2.80		55	6.21		
	I	137	8.83	0.135	1.53		44.4	.1353	4.0		40.5	4.58		
	I	138	8.83	0.145	1.64									
	I	147	8.83	0.19	2.15									
	II	7-8	4.42	0.075	1.70									
	II	12	4.42	0.085	1.92		20.7	.1142	3.21					

REMARKS: \_\_\_\_\_

CR-115568  
SVHSER-6040

REPORT NO.



88

TYPE OF TEST  
W.P.I. NO.

HS-C SERIES III

2000gm HSC or 4.4 LBS.

PLAN OF TEST NO.  
SERIAL NO.

PART NO.

DATE 2-23-72  
ENGINEER JAC, JRM  
OPERATORS

UNITS	TIME	CYCLE	LEFT	HRS	LBS	LBS	LBS	MIN	MIN	W	°F	°F	°F	in H <sub>2</sub> O	PSIA	CFM	MMHG	%	LBS	%	%	LBS	%
11.2	12.28	1	47	0	132.65	.095	—	30	40	10	70	70	50	2.5	14.6	40.5	5.0						
23	1358	2	46	1.1	132.51	.095	—	30	42	10	70	70	48	2.5	14.55	40	4.9						
23	1514	3	45	2.4	132.415	.095	—	30	42	15	70	70	50	2.6	14.42	40	5.1						
23	1628	4	44	3.7	132.325	.090	168.48	32	42	15	70	70	51	2.7	14.6	40	5.0						
23	1730	5	43	4.9	132.235	.09		32	38	10	70	70	51	2.6	14.6	40	5.0						
23	1842	6	42	6.1				30	41	15	70	70	51	2.6	14.63	40	5.0						
23	1954	7	41	7.3				30	40	15	70	70	51	2.6	14.68	40	4.95						
23	2104	8	40	8.5				30	40	12	70	70	51	2.7	14.63	40	5.0						
23	2216	9	39	9.7				30	40	10	70	70	51	2.7	14.63	40	4.95						
23	2327	10	38	10.8				30	40	12	70	70	51	2.7	14.63	40	5.0						
24	0039	11	37	12.0				30	38	10	70	70	51	2.6	14.62	40	4.95						
24	0151	12	36	13.2				30	40	12	70	70	51	2.7	14.62	40	4.95						
24	0302	13	35	14.4				30	38	12	70	70	51	2.7	14.61	40.5	5.0						
24	0413	14	34	15.6				30	40	12	70	70	51	2.6	14.62	40.5	5.0						
24	0524	15	33	16.8				30	40	10	70	70	51	2.7	14.60	40.5	5.0						
24	0636	16	32	18.0				31	40	10	70	70	51	2.7	14.61	40.5	5.0						
24	0748	17	31	19.2				30	40	8	70	70	51	2.7	14.61	40.5	5.0						
24	0858	18	30	20.4	131.075	.1160	165.98	30	40	10	70	70	51	2.8	14.61	40.5	5.0						
24	1021	19	29	21.7	131.080	.090		41	40	10	70	70	51	2.7	14.6	40	5.0						
24	1140	20	28	23.1	130.700	.090	165.75	42	40	15	70	70	51	2.7	14.61	40	5.0						
24	1304	21	27	24.5	—	—		40	15	70	70	51	2.7	14.61	40	5.0							
24	1426	22	25	25.8	130.720	.180		40	40	12	70	70	51	2.7	14.61	40	4.95						
24	1548	23	24	27.1	130.680	.090	164.60	40	40	10	70	70	51	2.7	14.61	40.5	4.95						

1.160  
13.075 2.02 32.1 .235 5.84

REMARKS ① NEW CO<sub>2</sub> BOTTLE WT 134.380 INSTALLED

CR-115568  
SMER-6040

Hamilton Standard  
WINDSOR LOCKS, CONNECTICUT - U.S.A.

U  
A.

OG OF TEST  
ENGINEERING LABORATORIES

DATE 2-24-72  
ENGINEER PJS  
OPERATORS DRM

NO. 98  
TYPE OF TEST H5-C  
W.P.I. NO. SERIES III

2000 gms H5-C (4.4 #)

PLAN OF TEST NO.  
SERIAL NO. PART NO.

TIME	CYCLE	FT	IN'S	LBS	LBS	LBS	LBS	MIN	MIN	K	OF	OF	OF	"H <sub>2</sub> O	PSIA	CFM	MMHG	% SINE	LBS	%	%	LBS	%
TIME	NO.	INCH	INCH	START	END	START	END	TIME	TIME	END	INLET	INLET	INLET	CAN	ADJ	ADJ	INLET	FLOW	CO <sub>2</sub>	CO <sub>2</sub>	H <sub>2</sub> O	H <sub>2</sub> O	H <sub>2</sub> O
1712	24	23	28.6	19.3	30.0			40	40	10	70	70	51	2.8	14.4	40	4.95	-					
1834	25	22	30.0					40	40	10	70	70	51	2.7	14.4	40	4.95	-					
1956	26	21	31.3					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
2118	27	20	32.7					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
2240	28	19	34.1					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
2404	29	17	35.4					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
25026	30	16	36.8					40	40	10	70	70	51	2.7	14.4	40.5	4.95	-	1.00	2.03	26.0	.2635	5.76
250248	31	15	38.2					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
250410	32	14	39.6					40	40	10	70	70	51	2.7	14.4	40	5.0	-					
250533	33	13	41.0					40	40	10	70	70	51	2.7	14.4	40.5	5.0	-					
250656	34	12	42.3					40	40	10	70	70	51	2.7	14.4	40.5	4.95	-					
250818	35	11	43.7	1.0	1.080	1.624	2.20	40	40	10	70	70	51	2.7	14.4	40.5	4.95	33					
250943	36	9	45.1	1.33	1.30	.090	1.622	.18	40	40	10	71	71	51	2.8	14.4	40.5	5.0	32				
251102	37	8	46.4	1.39	1.20	.090	1.6203	.19	40	40	10	71	71	51.5	2.8	14.43	40.5	5.0	32				
251227	38	7	47.8	1.33	1.00	.085	1.6188	.15	40	40	25	72	72	51	2.9	14.43	41	5.0	33				
251352	39	6	49.3	1.33	1.035	.080	1.6167	.21	40	40	35	70	70	51	2.7	14.4	40.5	4.95	35				
251506	40	5	50.8	1.32	1.155	.080		30	30	28	75	75	48.5	1.1	14.58	17.5	5.0	-					
251615	41	4	51.8	1.32	1.18	.080		30	30	10	75	75	48	1.1	14.58	17	5.0	-					
251715	42	3	52.8	1.32	1.205	.070		30	30	15	74	74	49	1.1	14.54	17	5.0	-					
251834	43	64	54.1					30	30	15	75	75	48	1.1	14.6	17	5.0	-					
251936	44	63	55.1					30	30	15	75	75	48	1.1	14.57	17	5.0	-					
252039	45	63	56.1					30	30	15	75	75	47	1.1	14.56	17	5.0	-					
252142	46	62	57.1					30	30	18	75	75	47	1.1	14.53	17	5.0	-					

CR-115568  
SMISER-6040



ORIGINAL PAGE IS  
OF POOR QUALITY

Hamilton Standard

WINDSOR LOCKS, CONNECTICUT • U.S.A.

U  
A.

OG OF TEST  
ENGINEERING LABORATORIES

DATE 2-28-72  
ENGINEER PJP  
OPERATORS PJP dlm

NO. 85  
TYPE OF TEST HS-C  
W.P.I. NO. SERIES III

PLAN OF TEST NO.

SERIAL NO.

PART NO.

TEST NO.	UNITS	TIME	FT	MRS	LBS	LBS	LBS	LBS	MIN	MIN	IN	°F	°F	°F	"H <sub>2</sub> O	PSIA	CFM	MM Hg	% SOLID
			NO.	CELL	STORE	UT. CO <sub>2</sub>	AD. CO <sub>2</sub>	UT. AIR	AD. AIR	ADS	TIME	INLET	INLET	INLET	CAN	DO <sub>2</sub>	ADS	15.4	NO. CO <sub>2</sub>
242244		47	61	58.2					30	30	15	74	74	46	1.0	14.54	17	5.0	-
242348		48	60	59.3					30	30	15	75	75	46	1.0	14.53	17	5.0	-
240051		49	59	60.3					30	30	15	75	75	45	1.0	14.53	17	5.0	-
240150		50	58	61.4					30	30	15	74	74	46	1.0	14.54	17	5.0	-
240256		51	58	62.4					30	30	20	74	74	47	1.0	14.54	17	5.0	-
240358		52	57	63.5					30	30	20	74	74	46	1.0	14.54	17	5.0	-
240500		53	56	64.5					30	30	20	74	74	45	1.1	14.54	17	5.0	-
240603		54	55	65.5					30	30	15	74	74	46	1.1	14.54	17	5.0	-
240705		55	54	66.6					30	30	12	74	74	46	1.1	14.54	17	5.0	-
240807		56	53	67.6					30	30	15	74	74	47	1.0	14.54	17	5.0	-
240909		57	52	68.6					30	30	10	74	74	47	1.1	14.54	17	5.0	-
241012		58	51	69.7		1.225	158.17	8.50	30	30	12	75	75	44	1.1	14.54	17	5.0	-
241114		59	51	70.7	131.475	.095	173.28	.20	30	30	10	76	76	45	1.1	14.47	17	5.0	-
241217		60	50	71.8	131.315	.080	173.08	.20	30	30	8	75	75	45	1.1	13.68	17	5.0	-
241319		61	49	72.8	131.345	.07	172.92	.16	30	30	10	74	74	49	1.0	13.5	17	5.0	-
241421		62	48	73.9					30	30	20	74	74	50	0.9	13.5	17	5.0	-
241524		63	47	74.9	131.17	.155			30	30	10	74	74	50	1.0	14.1	17	4.95	-
241621		64	46	75.8	130.9	.08	172.41	.51	30	30	20	74	74	52	1.0	14.1	17	4.95	-
241723		65	45	76.9	131.018	.08	172.21	.20	30	30	15	74	74	52	1.0	14.1	16	4.95	-
241826		66	44	77.9	130.78				30	30	15	74	74	52	1.0	14.13	16	4.95	-
241928		67	44	79.0					30	30	12	73	73	52	1.0	14.13	16	4.90	-
242030		68	43	80.0					30	30	15	74	74	52	1.0	14.13	16	4.90	-
242132		69	42	81.0					30	30	15	74	74	52	1.0	14.13	16	4.90	-

REMARKS

CR-115568  
SMISER-6040

Hamilton Standard  
WINDSOR LOCKS, CONNECTICUT - U.S.A.

U  
A.

ORIGINAL PAGE 15  
OF POOR QUALITY

OG OF TEST  
ENGINEERING LABORATORIES

DATE 2-26-72  
ENGINEER DJF  
OPERATORS DCM

NO. 88  
TYPE OF TEST H.S. - C SERIES III  
W.P.I. NO.

PLAN OF TEST NO.  
SERIAL NO.

PART NO.

IN	TIME	UNITS	FT	HRS	LBS	LBS	LBS	LBS	MIN	MIN	H	°F	°F	°F	H <sub>2</sub> O	PSIA	CFM	MMHG	%SCALE	LBS	%O <sub>2</sub>	%H <sub>2</sub> O	LBS	%H <sub>2</sub> O
26	223	70	41	82.1					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
26	233	71	40	83.1					30	30	12	74	74	52	1.0	14.12	16	4.90	-					
27	0029	72	39	84.1					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0142	73	38	85.2					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0244	74	38	86.2					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0346	75	37	87.3					30	30	18	74	74	52	1.0	14.12	16	4.95	-					
27	0449	76	36	88.3					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0551	77	35	89.3					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0653	78	34	90.4					30	30	20	74	74	52	1.0	14.12	16	4.95	-					
27	0755	79	33	91.4					30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	0857	80	32	92.4	1.0	1.265	169.81	1.90	30	30	15	74	74	52	1.0	14.12	16	4.95	-					
27	1000	81	32	93.5	1.29.115				30	30	15	74	74	52	1.0	14.12	16	4.95	35					
27	1102	82	31	94.5	1.55	169.00	.31		30	30	15	74	74	52	1.0	14.12	16	4.95	34					
27	1204	83	30	95.6	1.29.50	.08	168.82	.18	30	30	15	74	74	52	1.0	14.12	16	4.95	35	.08	1.82	42.0	.1577	3.63
27	1306	84	29	96.6	1.29.40	.08	168.65	.17	30	30	15	74	74	52	1.0	14.12	16	4.95	35					
27	1408	85	28	97.6	1.29.40	.085	168.49	.16	30	30	15	74	74	52	2.7	14.15	40	4.95	34					
27	1510	86	27	98.7	1.29.315	.080	168.34	.15	30	30	17	74	74	52.5	2.7	14.2	39.5	4.95	34					
27	1618	87	26	99.7	1.29.235				30	30	20	74	74	54	2.7	14.2	39.5	4.9	-					
27	1715	88	26	100.8					30	30	20	74	74	53	2.7	14.2	39.5	4.9	-					
27	1817	89	25	101.8					30	30	17	74	74	54	2.7	14.2	39.5	4.9	-					
27	1920	90	24	102.8					30	30	18	74	74	53	2.7	14.2	39.7	4.95	-					
27	2022	91	23	103.9					30	30	17	74	74	53	2.7	14.2	39.7	4.95	-					
27	2124	92	22	104.9					30	30	15	74	74	53	2.7	14.2	39.7	4.95	-					

REMARKS

CR-115568  
SWISER-6040

CH 10048



Hamilton Standard  
WINDSOR LOCKS, CONNECTICUT - U.S.A.

U  
A.

OG OF TEST  
ENGINEERING LABORATORIES

SHEET 5 of 9  
DATE 2-27-72  
ENGINEER PJJ/DRM  
OPERATORS

ING NO. 88  
TYPE OF TEST H5-C SERIES III  
W.P.I. NO.

PLAN OF TEST NO.  
SERIAL NO. PART NO.

72	UNITS	FT	IN/S	LBS	LBS	LBS	LBS	MIN	MIN	H	OF	OF	OF	"H <sub>2</sub> O	PSIA	CFM	mm Hg	% SCALD	
72	TIME	FIELD	LEFT	SIXTH	WHEEL	LEO <sub>2</sub>	WT. AIR	AS AIR	POS	POS	VARIA	INLET	INLET	INLET	CAV	POS	POS	FLOW	FLOW
72	TIME	FIELD	LEFT	SIXTH	WHEEL	LEO <sub>2</sub>	WT. AIR	AS AIR	POS	POS	VARIA	INLET	INLET	INLET	CAV	POS	POS	FLOW	FLOW
272326	93	21	105.9						30	30	16	74	74	53	2.7	14.2	39.5	4.95	-
272328	94	20	107.0						30	30	15	74	74	53	2.7	14.2	39.5	4.95	-
280031	95	19	108.0						30	30	15	74	74	53	2.7	14.2	39.5	4.95	-
280133	96	19	109						30	30	15	74	74	53	2.7	14.2	39.5	4.95	-
280235	97	18	110.1						30	30	15	74	74	53	2.7	14.2	39.5	4.95	-
280338	98	17	111.1						30	30	20	74	74	53	2.7	14.2	39.5	4.95	-
280440	99	16	112.2						30	30	20	74	74	53	2.7	14.2	39.5	4.95	-
280542	100	15	113.2						30	30	18	74	74	53	2.7	14.2	39.5	4.95	-
280644	101	14	114.2						30	30	20	74	74	53	2.7	14.18	39.5	4.95	-
280747	102	13	115.3			1.295	165.44	2.70	30	30	18	74	74	53	2.7	14.18	39.5	4.95	35
280849	103	12	116.3	122.74		0.80	165.41	.17	30	30	18	74	74	53	2.7	14.18	39.5	4.95	34
280952	104	12	117.4	123.60		0.80			30	30	18	74	74	53	2.7	14.18	39.5	4.9	-
281053	105	11	118.4	127.18		.130			30	47	20	74	74	53	2.7	14.18	39.5	4.9	-
281212	106	10	119.8	127.65					30	30	40	73	73	50.5	2.7	14.05	39.5	4.95	-
281314	107	9	120.8			.125	164.71	.76	30	30	50	73	73	50.5	2.7	14.15	39.5	4.95	35
281417	108	8	121.9	127.85		0.80	164.84	.17	30	30	40	73	73	51	2.7	14.15	39.5	4.95	34
281519	109	7	122.9	127.46					30	30	40	73	73	51	2.7	14.15	39.5	4.95	-
281624	110	6	123.9			.160	164.12	.36	30	30	40	73	73	51	2.7	14.15	39.5	4.95	34
281725	111	97	124.9	127.285					30	30	50	72	72	50	2.6	14.15	39.5	4.95	-
281828	112	96	126.0						30	30	40	72	72	51	2.6	14.15	39.5	4.95	-
281930	113	75	127.0						30	30	30	72	72	50	2.6	14.14	39.5	4.95	-
282032	114	94	128.0						30	30	30	72	72	51	2.65	14.15	39.5	4.95	-
282135	115	93	129.1						30	30	30	72	72	51	2.6	14.16	39.5	4.95	-

REMARKS

CR-115568  
SWHSE-6040

# Hamilton Standard

WINDSOR LOCKS, CONNECTICUT - U.S.A.

U  
A

## OG OF TEST ENGINEERING LABORATORIES

SHEET 6 of 9  
DATE 2-19-72  
SHOWN BY PJF DRAM  
OPERATORS

NO. 88  
TYPE OF TEST H5-C SERIES III  
W.P.I. NO.

PLANT OF TEST NO.  
SERIAL NO.

PART NO.

UNITS IN	TIME	FT	HRS	LBS	LBS	LBS	LBS	MIN	MIN	IN	OF	OF	OF	"H.D	PSIA	CFM	MMHG	% SENS	LBS	%	%	LBS	%
TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME	TIME
252237	116	92	130.1					30	30	20	70	73	51	2.7	14.15	39.5	4.90	-					
252257	117	91	131.2					30	30	*	70	73	51	2.7	14.15	39.5	4.95	-					
252342	118	90	132.2					30	30	*	70	73	51	2.7	14.09	40	5.0	-					
252344	119	89	133.2					30	30	*	70	73	51	2.7	14.09	39.5	5.1	-					
252346	120	88	134.3					30	30	*	70	72	51	2.7	14.07	39.5	5.0	-					
252349	121	87	135.3					30	30	*	70	72	51	2.7	14.08	40	5.1	-					
252351	122	86	136.4					30	30	*	70	73	51	2.7	14.07	40	5.0	-					
252353	123	86	137.4					30	30	*	70	73	51	2.7	14.07	40	5.1	-					
252355	124	85	138.4					30	30	*	70	73	52	2.7	14.10	39.5	5.1	-					
252357	125	84	139.5					30	30	*	70	73	52	2.6	14.17	39.5	4.95	-					
252359	126	83	140.5	126.005	0.075	141.43	.19	30	30	12	70	73	51	2.6	14.18	39.5	4.85	35					
252362	127	82	141.5	126.000	0.090	141.25	.18	30	30	12	70	72	51	2.6	14.87	39.5	4.90	34					
252365	128	81	142.6	126.000	0.080	141.16	.19	30	30	18	70	73	51	2.6	14.10	39.5	4.95	35					
252367	129	80	143.6	126.000				30	30	10	70	72	52	2.6	14.4	39.5	4.95	-					
252369	130	79	144.7			160.71	.35	30	30	15	70	73	51	2.5	14.4	39.5	4.95	35					
252372	131	79	145.7	126.200	0.075	141.25	.23	30	30	10	70	73	51	2.7	14.4	39.5	4.95	34					
252375	132	78	146.7	126.200	0.080	141.25	.20	30	30	12	70	73	51	2.6	14.25	39.5	4.95	36	.080	1.82	27.9	.014	4.87
252377	133	77	147.8	126.100	0.055	141.25	.20	30	30	12	70	73	51.5	2.6	14.28	39.5	4.95	35					
252379	134	76	148.8	126.000				30	30	15	70	73	52	0.5	14.15	13	4.95	-					
252382	135	75	149.9					30	30	12	70	73	51	0.5	14.18	13	4.95	-					
252384	136	74	150.9					30	30	15	70	73	51	0.5	14.18	13	4.95	-					
252386	137	73	151.9					30	30		70	73	51	0.5	14.15	13	4.95	-					
252389	138	73	153					30	30		70	73	51	0.5	14.15	13	4.9	-					

REMARKS \* VACUUM SYSTEM FAILURE

CR-115568  
SWISER-6040



Hamilton Standard  
WINDSON LOCKS, CONNECTICUT • U.S.A.

U  
A.

OG OF TEST  
ENGINEERING LABORATORIES

DATE 2-29-72 SHEET 7 of 9  
ENGINEER OPERATOR RSC DCR

NO. 88  
TYPE OF TEST HS-C  
W.P.I. NO. SERIES III

PLAN OF TEST NO.  
SERIAL NO. PART NO.

UNITS	TIME	24218 R.O.	FT LEFT R.O.	1K'S START	LBS START	LBS DEP AFTER 40S	LBS DEP AFTER 10S	LBS DEP AFTER 10S	MIN TIME AUS	MIN TIME AUS	IN VACUUM R.O. IN	°F INLET AIR	°F INLET CAN COOLANT	°F INLET O.P.	"H <sub>2</sub> O CAN O.P.	PSIA ADS PRESS	CFM ADS FLOW	mm Hg INLET CO <sub>2</sub>	% SPND CONC FLOW
21	2232	189	72	154					30	30	10	70	73	51	0.5	14.15	93	4.9	-
21	2354	140	71	155.1					30	30	10	70	73	51	0.5	14.15	93	4.9	-
1	0087	141	70	156.1					30	30	12	70	73	51	0.5	14.15	93	4.9	-
1	0139	142	69	152.1					30	30	10	70	73	51	0.5	14.18	93	4.9	-
1	0242	143	68	152.1					30	50	15	70	73	51	0.5	14.18	93	4.9	-
1	0344	144	67	152.2					30	30	20	70	73	50.5	0.5	14.18	93	4.9	-
1	0447	145	67	160.3					30	30	10	70	73	51	0.5	14.18	93	4.9	-
1	0549	146	66	161.3					30	30	15	70	73	51	0.5	14.18	93	4.9	-
1	0652	147	65	162.4					30	30	10	70	73	51	0.5	14.18	93	4.9	-
1	0754	148	64	163.4		1.075	164.62	2.63	30	30	12	70	73	51	0.5	14.18	93	4.9	-
1	0857	149	63	164.4	124.765	0.075	164.93	1.19	30	30	12	70	73	51	0.5	14.16	93	4.95	37
1	1035	150	62	166.0	124.810	0.080	167.29	1.19	40	40	12	70	70	51	2.7	14.23	40	4.9	38
1	1157	151	60	167.4	124.810	0.080	169.07	1.17	40	40	12	70	73	51	2.7	14.23	41	4.95	-
1	1320	152	59	168.8	124.730	0.085	169.92	1.15	40	40	10	70	73	51	2.7	14.25	41	4.95	35
1	1444	153	58	170.2	125.310	0.085	169.75	1.17	40	40	12	70	73	51.5	2.7	14.2	41	4.95	35
1	1608	154	57	171.6	124.910				40	40	15	70	73	51.5	2.6	14.2	41	4.95	34
1	1731	155	56	173.0					40	40	10	70	73	51.5	2.6	14.2	41	4.95	-
1	1855	156	55	174.4					40	40	12	70	73	51.5	2.6	14.2	41	4.95	-
1	2019	157	54	175.8					40	40	10	70	73	51	2.6	14.2	41	4.95	-
1	2142	158	52	177.2					40	40	10	70	73	52	2.6	14.2	41	4.95	-
1	2306	159	51	178.6					40	40	10	70	73	52	2.6	14.2	41	4.95	-
2	0030	160	50	180					40	40	10	70	73	52	2.6	14.2	41	4.95	-
2	0153	161	49	181.4					40	40	10	70	73	51.5	2.6	14.2	41	4.95	-

REMARKS \* READJUSTED CO. NOzzle SUPPORT

CR-115568  
SWISER-6040

Hamilton Standard  
WINDSOR LOCKE, CONNECTICUT - U.S.A.

U  
A.

OG OF TEST  
ENGINEERING LABORATORIES

DATE 3-2-77  
ENGINEER PJM  
OPERATOR PJM

SIG NO. SE  
TYPE OF TEST THS-C  
W.P.I. NO. SERIES III

PLAN OF TEST NO.  
SERIAL NO.

PART NO.

TIME	NO	FT	INCH	LBS	LBS	LBS	LBS	MIN	MIN	H	F	F	F	H <sub>2</sub> O	PSIA	CFM	MM Hg	REACT	LBS	%	%	LBS	%
TIME	NO	FT	INCH	LBS	LBS	LBS	LBS	MIN	MIN	H	F	F	F	H <sub>2</sub> O	PSIA	CFM	MM Hg	REACT	LBS	%	%	LBS	%
2 0317	162	48	182.8					40	40	10	70	73	51.5	2.6	14.2	41	4.95	-					
2 0741	163	47	184.2					40	40	10	70	73	51.5	2.6	14.2	41	4.95	-					
2 0605	164	45	185.6					40	40	10	70	73	51.5	2.6	14.2	41	4.95	-					
2 0728	165	44	187			1000	161.45	2.10	40	40	10	70	73	51.5	2.6	14.2	41	4.95	34				
2 0734	166	43	189.1	123.90	105	161.48	.17	40	85	6	70	72.5	51	2.6	14.2	41	4.9	35					
2 1058	167	41	190.5	123.805	090	161.31	.17	40	40	10	70	72.5	51	2.6	14.2	41	4.95	34					
2 1222	168	40	191.9	123.715	080	161.12	.19	40	40	12	70	72	51	2.6	14.2	41	4.95	-					
2 1347	169	39	193.3	123.635	080	-		40	40	10	70	72.5	51.5	2.6	14.22	41	4.95	-					
2 1538	170	38	195.1	123.555	085	160.75	.37	40	40	12	70	72.5	51.5	2.6	14.22	41	4.95	35					
2 1702	171	36	196.5	123.570				40	40	12	70	72.5	51.5	2.5	14.2	41	4.95	-					
2 1826	172	35	197.9					40	40	10	70	72.5	51	2.5	14.2	41	4.95	-					
2 1950	173	34	199.3					40	40	15	70	72.5	51	2.5	14.2	41	4.95	-					
2 2107	174	33	200.7					40	40	15	70	72.5	51	2.5	14.2	41	4.95	-					
2 2287	175	32	202.1					40	40	18	70	72.5	51	2.5	14.2	41	4.95	-					
3 0001	176	31	203.5					40	40	15	70	72.5	51	2.5	14.2	41	4.95	-					
3 0126	177	29	204.9					40	40	20	70	72.5	51	2.5	14.2	41	4.95	-					
3 0249	178	28	206.3					40	40	16	70	72.5	51	2.5	14.2	41	4.95	-					
3 0412	179	27	207.7					40	40	20	70	72.5	51	2.5	14.2	41	4.95	-					
3 0537	180	26	209.1					40	40	15	70	72.5	51	2.5	14.2	41	4.95	-					
3 0701	181	25	210.5			895	158.70	2.05	40	40	15	70	72.5	51	2.5	14.2	41	4.95	-				
3 0825	182	23	211.9	122.85	070	158.51	.19	40	40	15	70	72.5	51	2.4	14.2	41	4.95	35					
3 0949	183	22	213.3	122.80	075			40	40	20	70	72	50.5	2.5	14.2	41	4.9	-					
3 1111	184	21	214.7	122.410	080	158.12	.39	40	40	15	70	72.5	50.5	2.5	14.2	41	4.9	-					

REMARKS

CR-115568  
SWER-6040



## WINDHOLM LOGS, CONNECTICUT - U.S.A.

MOORE

TYPE OF TEST

TYPE OF TEST

W.P.I. NO. \_\_\_\_\_

HS-C SERIES III

PLAN OF TEST NO.

1994, 1995, 1996, 1997, 1998, 1999, 2000, 2001, 2002, 2003, 2004, 2005, 2006, 2007, 2008, 2009, 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, 2018, 2019, 2020, 2021, 2022, 2023, 2024, 2025, 2026, 2027, 2028, 2029, 2030, 2031, 2032, 2033, 2034, 2035, 2036, 2037, 2038, 2039, 2040, 2041, 2042, 2043, 2044, 2045, 2046, 2047, 2048, 2049, 2050, 2051, 2052, 2053, 2054, 2055, 2056, 2057, 2058, 2059, 2060, 2061, 2062, 2063, 2064, 2065, 2066, 2067, 2068, 2069, 2070, 2071, 2072, 2073, 2074, 2075, 2076, 2077, 2078, 2079, 2080, 2081, 2082, 2083, 2084, 2085, 2086, 2087, 2088, 2089, 2090, 2091, 2092, 2093, 2094, 2095, 2096, 2097, 2098, 2099, 2100, 2101, 2102, 2103, 2104, 2105, 2106, 2107, 2108, 2109, 2110, 2111, 2112, 2113, 2114, 2115, 2116, 2117, 2118, 2119, 2120, 2121, 2122, 2123, 2124, 2125, 2126, 2127, 2128, 2129, 2130, 2131, 2132, 2133, 2134, 2135, 2136, 2137, 2138, 2139, 2140, 2141, 2142, 2143, 2144, 2145, 2146, 2147, 2148, 2149, 2150, 2151, 2152, 2153, 2154, 2155, 2156, 2157, 2158, 2159, 2160, 2161, 2162, 2163, 2164, 2165, 2166, 2167, 2168, 2169, 2170, 2171, 2172, 2173, 2174, 2175, 2176, 2177, 2178, 2179, 2180, 2181, 2182, 2183, 2184, 2185, 2186, 2187, 2188, 2189, 2190, 2191, 2192, 2193, 2194, 2195, 2196, 2197, 2198, 2199, 2200, 2201, 2202, 2203, 2204, 2205, 2206, 2207, 2208, 2209, 2210, 2211, 2212, 2213, 2214, 2215, 2216, 2217, 2218, 2219, 2220, 2221, 2222, 2223, 2224, 2225, 2226, 2227, 2228, 2229, 2230, 2231, 2232, 2233, 2234, 2235, 2236, 2237, 2238, 2239, 2240, 2241, 2242, 2243, 2244, 2245, 2246, 2247, 2248, 2249, 2250, 2251, 2252, 2253, 2254, 2255, 2256, 2257, 2258, 2259, 2260, 2261, 2262, 2263, 2264, 2265, 2266, 2267, 2268, 2269, 2270, 2271, 2272, 2273, 2274, 2275, 2276, 2277, 2278, 2279, 2280, 2281, 2282, 2283, 2284, 2285, 2286, 2287, 2288, 2289, 2290, 2291, 2292, 2293, 2294, 2295, 2296, 2297, 2298, 2299, 2300, 2301, 2302, 2303, 2304, 2305, 2306, 2307, 2308, 2309, 2310, 2311, 2312, 2313, 2314, 2315, 2316, 2317, 2318, 2319, 2320, 2321, 2322, 2323, 2324, 2325, 2326, 2327, 2328, 2329, 2330, 2331, 2332, 2333, 2334, 2335, 2336, 2337, 2338, 2339, 2340, 2341, 2342, 2343, 2344, 2345, 2346, 2347, 2348, 2349, 2350, 2351, 2352, 2353, 2354, 2355, 2356, 2357, 2358, 2359, 2360, 2361, 2362, 2363, 2364, 2365, 2366, 2367, 2368, 2369, 2370, 2371, 2372, 2373, 2374, 2375, 2376, 2377, 2378, 2379, 2380, 2381, 2382, 2383, 2384, 2385, 2386, 2387, 2388, 2389, 2390, 2391, 2392, 2393, 2394, 2395, 2396, 2397, 2398, 2399, 2400, 2401, 2402, 2403, 2404, 2405, 2406, 2407, 2408, 2409, 2410, 2411, 2412, 2413, 2414, 2415, 2416, 2417, 2418, 2419, 2420, 2421, 2422, 2423, 2424, 2425, 2426, 2427, 2428, 2429, 2430, 2431, 2432, 2433, 2434, 2435, 2436, 2437, 2438, 2439, 2440, 2441, 2442, 2443, 2444, 2445, 2446, 2447, 2448, 2449, 2450, 2451, 2452, 2453, 2454, 2455, 2456, 2457, 2458, 2459, 2460, 2461, 2462, 2463, 2464, 2465, 2466, 2467, 2468, 2469, 2470, 2471, 2472, 2473, 2474, 2475, 2476, 2477, 2478, 2479, 2480, 2481, 2482, 2483, 2484, 2485, 2486, 2487, 2488, 2489, 2490, 2491, 2492, 2493, 2494, 2495, 2496, 2497, 2498, 2499, 2500, 2501, 2502, 2503, 2504, 2505, 2506, 2507, 2508, 2509, 2510, 2511, 2512, 2513, 2514, 2515, 2516, 2517, 2518, 2519, 2520, 2521, 2522, 2523, 2524, 2525, 2526, 2527, 2528, 2529, 2530, 2531, 2532, 2533, 2534, 2535, 2536, 2537, 2538, 2539, 2540, 2541, 2542, 2543, 2544, 2545, 2546, 2547, 2548, 2549, 2550, 2551, 2552, 2553, 2554, 2555, 2556, 2557, 2558, 2559, 2560, 2561, 2562, 2563, 2564, 2565, 2566, 2567, 2568, 2569, 2570, 2571, 2572, 2573, 2574, 2575, 2576, 2577, 2578, 2579, 2580, 2581, 2582, 2583, 2584, 2585, 2586, 2587, 2588, 2589, 2590, 2591, 2592, 2593, 2594, 2595, 2596, 2597, 2598, 2599, 2600, 2601, 2602, 2603, 2604, 2605, 2606, 2607, 2608, 2609, 2610, 2611, 2612, 2613, 2614, 2615, 2616, 2617, 2618, 2619, 2620, 2621, 2622, 2623, 2624, 2625, 2626, 2627, 2628, 2629, 2630, 2631, 2632, 2633, 2634, 2635, 2636, 2637, 2638, 2639, 2640, 2641, 2642, 2643, 2644, 2645, 2646, 2647, 2648, 2649, 2650, 2651, 2652, 2653, 2654, 2655, 2656, 2657, 2658, 2659, 2660, 2661, 2662, 2663, 2664, 2665, 2666, 2667, 2668, 2669, 2670, 2671, 2672, 2673, 2674, 2675, 26

ENGINEERING LABORATORIES

DATE 3-3-78  
INCHARGE PLS  
OPERATORS PLS

DATE 11/11/2011

OPERATORS *[Signature]*

[illegible]

### QUESTIONS

① LEZRO CO<sub>2</sub> SCALE

\* VACUUM VALVE FAILURE, SYSTEM AUTOMATICALLY SHUT DOWN

② H5-C WT. ESTABLISHED AT 4.0" AFTER TEST. 0.4" LOST TO VACUUM SYSTEM THROUGH FAILED BED SEAL

CR-115568  
SMSER-6040